

MASTER

ADVANCED ALKALINE WATER ELECTROLYSIS
TASK 2 SUMMARY REPORT


MODEL FOR ALKALINE WATER
ELECTROLYSIS SYSTEMS

TELEDYNE ENERGY SYSTEMS
110 West Timonium Road
Timonium, Maryland 21093

April 1980

Work supported by the
DIVISION OF THERMAL AND MECHANICAL STORAGE
OFFICE OF ADVANCED CONSERVATION TECHNOLOGIES
UNITED STATES DEPARTMENT OF ENERGY

DEPARTMENT OF ENERGY AND ENVIRONMENT
BROOKHAVEN NATIONAL LABORATORY
UPTON, NEW YORK 11973



DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

MASTER

BNL 51276

UC-94d

(Energy Storage-Chemical - TIC-4500)

ADVANCED ALKALINE WATER ELECTROLYSIS TASK 2 SUMMARY REPORT

MODEL FOR ALKALINE WATER ELECTROLYSIS SYSTEMS

Prepared by

M.R. YAFFE

Principal Investigators

J.N. Murray

M.R. Yaffe

TELEDYNE ENERGY SYSTEMS

110 West Timonium Road

Timonium, Maryland 21093

Prepared for the

ENERGY STORAGE AND CONVERSION DIVISION

DEPARTMENT OF ENERGY AND ENVIRONMENT

Under Subcontract No. 480421-S

BROOKHAVEN NATIONAL LABORATORY

ASSOCIATED UNIVERSITIES, INC.

UPTON, NEW YORK 11973

UNDER CONTRACT NO. DE-AC02-76CH00016 WITH THE
UNITED STATES DEPARTMENT OF ENERGY

DIVISION OF THERMAL AND MECHANICAL STORAGE

DISCLAIMER

This book was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency, contractor or subcontractor thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency, contractor or subcontractor thereof.

Printed in the United States of America
Available from
National Technical Information Service
U.S. Department of Commerce
5285 Port Royal Road
Springfield, VA 22161
Price: Printed Copy \$11.00; Microfiche \$3.50

TABLE OF CONTENTS

	<u>Page</u>
Title Page	i
Notice	ii
Table of Contents	iii
List of Figures and Tables	iv
1.0 SUMMARY	1-1
2.0 INTRODUCTION	2-1
2.1 Contract Background	2-1
2.2 Purpose of Task 2, Contract 480421-S	2-2
3.0 DESCRIPTION OF MODEL	3-1
3.1 Model Development	3-1
3.2 Test or Benchmark Case Studies	3-17
4.0 SENSITIVITY STUDIES	4-1
4.1 Study One. Effect of Plant Size	4-1
4.2 Study Two. Effects of Temperature: 80 KW Unit	4-9
4.3 Study Three. Optimization of Cell Sizes and Current Densities: 80 KW Unit	4-13
4.4 Study Four. Effect of Electricity Costs and Unit Utilization (Duty Factor): 80 KW Unit	4-16
5.0 DISCUSSION	5-1
5.1 Model for Alkaline Water Electrolysis Systems: "MAWES"	5-1
5.2 The Study: A Discussion of Findings	5-4
5.3 Advanced Alkaline Water Electrolysis Program Direction, Some Suggestions	5-6
5.4 A Preliminary Comparison of Advanced Alkaline (AAWE) and Solid Polymer (SPE) Electrolysis: 1 MW System	5-7
6.0 ACKNOWLEDGMENTS	6-1
7.0 REFERENCES	7-1
APPENDICES	
Appendix A - Input Parameters: Run No. 4, 3 March 1980	A-1
Appendix B - Output Parameters: Run No. 4, 3 March 1980	B-1
Appendix C - Data Deck Structure, Input Deck	C-1
Appendix D - MAWES Listing	D-1

LIST OF FIGURES AND TABLES

<u>Figure</u>		<u>Page</u>
3-1	The Potential Problem of Optimization Studies	3-4
3-2	Objective Function Calculation Design Section	3-7
3-3	Objective Function Calculation Cost and Revenue Requirement Section	3-8
3-4	Conceptual Shunt Current Bypassing Center Cell	3-10
3-5	Systems Component Block Diagram	3-12
4-1	Levelized Gas Price vs Size, Baseline Technology	4-2
4-2	First Year Gas Price vs Size, Baseline Technology	4-3
4-3	Price vs Size for Baseline Technology, 2.5¢/KWH	4-5
4-4	Levelized Gas Price vs Size, C-AN Cathode Technology	4-6
4-5	First Year Gas Price vs Size, Advanced Cathode Technology	4-7
4-6	Price vs Size, Advanced Cathode Technology, 2.5¢/KWH	4-8
4-7	Gas Price vs Cell Area, Baseline Technology	4-11
4-8	Levelized Hydrogen Price from 80 KW System vs Module Operating Temperature: 85% Plant Utilization, 2.5¢/KWH	4-12
4-9	Module Efficiency Values vs Temperature, 80 KW Size	4-14
4-10	Levelized Gas Price vs Temperature and Current Density for Baseline (Ni-200) Cathode/Asbestos Technology. Optimum Cell Area is $\sim 0.25 \text{ M}^2$; 80 KW, 2.5¢/KWH	4-15
4-11	Levelized Gas Price vs Temperature and Current Density for Advanced Cathode (C-AN)/Asbestos Technology. Optimum Cell Area is $\sim 0.25 \text{ M}^2$; 80 KW, 2.5¢/KWH	4-17
4-12	Overall Efficiency vs Temperature, 80 KW Systems	4-18
4-13	Levelized Gas Price vs Electricity Cost and Duty Factor, Baseline Technology	4-20
4-14	Levelized Gas Price vs Electricity Cost and Duty Factor, Advanced Cathode Technology	4-21
4-15	Levelized Gas Price vs Electricity Cost and Duty Factor, Two Technologies	4-22

LIST OF FIGURES AND TABLES (CONTINUED)

<u>Tables</u>		<u>Page</u>
3-1	Components Cost - Baseline Case: 255 SLM H₂ Out	3-22
3-2	Module Cost Breakdown	3-23
4-1	Study One: C-AN vs Ni Screen Technologies, 80 and 1000 KW Plants @ 60°C, 6000 A/M²	4-10
5-1	Economic Input Variables for SPE/AAWE Comparison	5-8
5-2	Existing Technology - 1 MW Electrolyzer	5-10
5-3	Goal Technology - 1 MW Electrolyzer	5-11

1.0 SUMMARY

Task 2 of the Teledyne Energy Systems (TES) contract with the Brookhaven National Laboratory (BNL), BNL-480421-S involved the establishment of an engineering and economic model for the evaluation of various options in water electrolysis. The model, verification of the specific coding and four case studies are described in this summary report.

In brief terms, this new Fortran IV coded model has been prepared and has the following features.

- (1) Based on operator controlled input or default values, starting with the required D.C. to the electrolysis module, a module is "designed" and the support plant is subsequently "designed."
- (2) The manufacturing costs of both items are then calculated and subsequently recalculated into initial plant costs to the customer.
- (3) The operating power costs as well as the associated operating costs for the plant are calculated.
- (4) The costs are then evaluated with respect to a capitalization approach, suggested originally by EPRI (Ref. 6), and with respect to distinct inflation values for power and other operating costs to yield a levelized hydrogen cost, or alternatively defined, a time averaged weighted hydrogen cost.

The model, described in general terms in Section 3.1 of this report and detailed as Appendix C, was tested by evaluation of a nearly commercial technology, i.e., an 80 KW alkaline electrolyte system, operating at 60°C, which delivers approximately 255 SLM, hydrogen for applications such as electrical generator cooling or semiconductor manufacturing. The general output from these calculations are described in Section 3.2

and are presented in detail in Appendix A and Appendix B.

The calculated cost of hydrogen from this installed nonoptimized case system with an initial cost to the customer of \$87,000 was \$6.99/Kg H₂ (\$1.67/100 SCF) on a 20-year levelized basis using 2.5¢/KWH power costs. This compares favorably to a levelized, average merchant hydrogen cost value of \$9.11/Kg H₂ (\$2.17/100 SCF) calculated using the same program.

The flexibility of the program was tested by evaluation of four "cases."

The first case (Section 4.1) showed the expected lowering of the cost of hydrogen as the plant size is increased from 80 KW case to 1000 KW, the largest size requested for this study by BNL. With a preestablished 6000 A/M² (600 ma/cm² = 557 amp/ft²), levelized hydrogen costs of \$5.30/Kg H₂ were calculated for the conventional Ni-200 wire screen technology at 125°C and \$4.60/Kg H₂ was shown for the advanced cathode (C-AN) technology for the 1000 KW plant size.

The general effects of temperature for only the 80 KW plant size were studied for both electrode technologies and this case is described in Section 4.2. Approximately a 9% cost savings was calculated by increasing the operating temperature of the Ni screen from 55°C to 125°C and an additional 9% cost savings realized by utilization of the C-AN cathodic technology.

Using the model to optimize the module design parameters of cell area, operating current density and operating temperature for again the 80 KW case (Study 3, Section 4.3), the minimum costs were found to be \$5.92/Kg H₂ and \$5.34/Kg H₂ for the Ni-200 screen and C-AN cathode technology, respectively. Both electrode technologies optimized with an 125°C operating temperature and an approximately 0.25 M² cell area, the baseline technology minimizing at 5000 ± 500 A/M² whereas the C-AN technology minimized at 6000 ± 500 A/M² operating current density. These values correspond closely to 4500 ± 500 A/M² value found in an earlier study and used in most of ARIES testing to date.

As BNL had originally requested plant duty or utilization factor be considered, Study 4 (Section 4.4) was concerned with the effects of both duty factor and electricity costs. The general finding was that a rather broad based insensitivity existed with respect to duty factor for the range of 60 to 100%. This finding was distinct from previous studies and was caused in general by two factors--the predominance of the electricity cost on the cost of gas relative to the other factors, and the "fact" that inflation affects the electrical and operating costs but does not significantly affect the cost of an installed plant.

Finally, with the usefulness of the program demonstrated, a comparison of "existing technology" cases for both advanced alkaline cells and the SPE (solid polymer electrolyte) was attempted. The results (Section 5.4) show the advanced alkaline technology to be superior to the SPE technology when attempting to base the comparison on a similarly sized, optimized and costed basis. Evaluation of the stated goals of both technologies was also attempted and the general findings were nearly identical costs of hydrogen from the two approaches. The reader must therefore decide on which technology is the more credible.

Several features of the model could be further refined and several additional subroutines which would increase the usefulness of the model are suggested. The specific values contained in the report were, of course, the particular results of the preselected estimates of the author after considerable consultation at TES. However, a critical review by an independent party which would lead to more accurate hydrogen costs is the next order of priority. The case studies discussed in this report have shown the next proposed experimental studies to lower the internal resistance of the electrode separator and improve the anode is the proper near term approach. Establishing the relationship of module operating temperature and module life would, as discussed, then be the next order of priority.

1-2

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

2.0 INTRODUCTION

2.1 CONTRACT BACKGROUND

For the past four years, Teledyne Energy Systems (TES) has been working on a series of tasks for the development of advanced alkaline water electrolysis systems funded by the Department of Energy (DOE) under the direction of the Chemical/Hydrogen Energy Storage Systems Division and monitored by the Electrochemical Group at Brookhaven National Laboratory (BNL). Summarizing tersely, the main thrust of past efforts has been to identify approaches to achieve high efficiency electrolyzers. There are several feasible improvements in cell hardware technology, namely using improved (lower polarization) anodes and cathodes and less resistive separators. Also, since there are no easily accessible parasitic reaction pathways, elevation of operating temperature results in lower cell polarization and cell resistive losses with little loss in current efficiency. This further increases the operating efficiency of hydrogen production.

The original contract task was a materials study designed to identify and characterize stable thermoplastics that could be used for cell frame structural materials at temperatures up to 150°C (Ref. 8). Next, a high temperature applied research sized electrolyzer was built as a test bed for new technology. This system, called ARIES, was used in the following tasks to characterize the performance of baseline technology at temperatures up to 125°C. The baseline technology consisted of nickel-200 wire screen electrodes and bipolars, chrysotile asbestos interelectrode separators, polysulfone cell frames, and 316 stainless steel plumbing. The following two tasks again used the ARIES system in a series of six advanced electrode screening tests, and an extended test of a five-cell electrolysis module containing Teledyne proprietary cathodes (C-110) and Teflon-bonded nickel-200 powder anodes. Also tested for a short time were cells

containing shear spun polybenzimidazole (PBI) fibrid, cast felt interelectrode separators. Although no significantly improved anode had been found, the best cathode identified, the proprietary C-AN cathode, showed on the order of 300 mV lower polarization at $\sim 5000 \text{ A/M}^2$ compared to the baseline technology cathode (Ref. 7).

2.2 PURPOSE OF TASK 2, CONTRACT 480421-S

This short history brings us to the present task, the development of a computerized model for alkaline water electrolysis systems (MAWES) which can allow one to optimize the critical system component parameters and predict the cost of hydrogen produced from an arbitrary technology electrolysis system.

This type of design and economic model is necessary for many reasons. First, in order to judge the effect of technical improvements, one cannot look solely at the energy conversion efficiency of the improved system but must also consider the cost of improvements as they affect the cost of the product, hydrogen. This means a complete cost/price analysis must be done for every change in design. The price sensitivity is affected by an improvement in voltage efficiency, for example, by decreasing the input power but, the electrode usually causes a capital equipment cost increase. Also, the sizes required for heat exchangers and pumps may change since less waste heat is generated. The net change in hydrogen price may increase for a small, capital intensive system bought at high interest rates. On the other hand, for a large, power intensive system purchased in an era when power costs are inflating, the price of gas may decrease. Obviously, the sensitivity is dependent on many interrelated economic and design factors.

The second general use of this model lies in its ability to predict areas in which improvement should be concentrated. From previous output, one may be able to detect which components or subsystems deserve further attention for purposes of price reduction

and which ones have relatively minor cost effect. In addition, there may be parametric optimizations performed that allow the designer to do design trade-off studies, for example, one trade-off may be the module temperature rise versus heat exchanger size. Normally, the model is used to detect the optimum cell current density, number of cells and cell area. Many other such trade-offs can be envisioned and the model is designed to investigate these using, again, the cost of product gas as the ultimate judge of improvement.

In order to do a complete analysis, the model should be able to predict required sizes for the major system components and predict prices corresponding to those sizes. Of course, there is no way to do an *ab initio* calculation: several design curves must be input. Also, there are some points where the design seems to be a matter of historical preference (i.e., educated guesses) and no parametric design data is available. In these areas absolute values must be part of the input.

A major goal of this task is to use the developed model as an optimization tool. Therefore, the program must have optimization techniques built in as part of its operation. These techniques and the techniques for calculation of design and cost values are described in the following section.

2-4

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

3.0 DESCRIPTION OF MODEL

3.1 MODEL DEVELOPMENT

3.1.1 Optimization Method

A design study of the type described in the task definition is, in essence, a classical nonlinear, constrained, optimization problem. In this case, the value to be optimized (minimized) is the price of product hydrogen. This price is not constant in an inflationary era, however, and careful attention must be paid to selecting the proper time-average price called the "Levelized Gas Price," P_L . Once the definition is made one still must relate this value to a rather large set of independent design and economic parameters. For this study the parameter list is some 262 variables long and is given in Appendix A. In an unconstrained problem the objective is to find a minimum price, P_L in a 262 dimension space, obviously a problem to be avoided.

There are two types of constraints encountered, range constraints and parametric constraints. The first type fall into the category of linear constraints and, as suggested, simply limit the allowable range of a given variable. For example, instead of an operating temperature (T) range of -273 to ∞ °C, one may only want to consider: $50^\circ\text{C} \leq T \leq 150^\circ\text{C}$, or one may want to set a variable constant, e.g., $100^\circ\text{C} \leq T \leq 100^\circ\text{C}$ (or $T = 100^\circ\text{C}$). The second type of constraint, the parametric constraint is more difficult to handle. In this case there is some additional function of one or more variables which must be less than a specified value. For example, the cell voltage is not given in the parameter list and must be calculated from electrode characteristic curves, temperature and current density. As a parametric constraint though we have defined that the cell voltage (V) must not be endothermic ($V > 1.48$ volt). The program must then test for

these and similar cases and set P_L arbitrarily high so that this out-of-bounds case does not appear as a minimum. The range constraints are more easily handled by never allowing any variable out of range at the outset.

The nonlinear constrained optimization program can be stated mathematically as:

$$\text{Minimize } P_L = f(X_1, X_2, \dots, X_{262})$$

subject to range constraints,

$$L_i \leq X_i \leq U_i \quad \text{for } i = 1 \text{ to } 262$$

and parametric constraints

$$C_j \leq f_j(X_1, \dots, X_{262}) \quad \text{for a set of } j\text{'s.}$$

The size of this problem is still unmanageable and is even further complicated by the presence of the constraints in all but the case of total constraint described above, i.e., $X_i = \text{constant}$. This constraint reduces the dimension of the problem space by one, each time it is employed. In this program only 15 or fewer variables are allowed to vary, the others being fixed at the program initialization. The operator is allowed the flexibility of choosing which set of 15 (out of 262) he wishes to investigate. He may choose fewer or allow none at all to vary and the problem degenerates to a simple function evaluation. Several techniques exist for optimizing constrained functions, notably the SUMT algorithm (Ref. 1) or the "Complex" algorithm (Ref. 2). Most require large numbers of function evaluations and are suitable for relatively simple functions. In this case, however, the function is anything but simple and requires on the order of 900 Fortran IV statements to evaluate.

This brings one face to face with the implicit problem in all optimizations: one must optimize the optimization. That is to say, one must gain as much information about the minimum at the least expense in computer time. Also one would like to know which variables are the truly sensitive ones and which can be eliminated from further consideration in addition to the optimum conditions. Another problem to contend with is the local versus global minimum problem. As illustrated in Figure 3-1, depending on the starting point, the minimum found may not be the true global minimum but only a local minimum for a small region of the variable space. No mathematical solution to this pitfall is known to this author.

To handle these problems for purposes of this contract, a simple grid search technique has been adopted where the specified variables are further constrained to discrete values within their allowed range. For example, one may see a statement in the output that looks like:

6.CCD = 4000 to 8000 in 5 steps

Roughly translated this means variable #6 (cell current density) has an allowed range of 4000 A/M² to 8000 A/M² and the program will test it five equally spaced values (4000, 5000, 6000, 7000, and 8000 A/M²). * If there is another variable set up with two steps (e.g., 5.CAR = .05 to .10 Step 2) and a third with three steps (e.g., 3.PTMOD = 75 to 125 in 3 steps), the program will set up a 5 x 2 x 3 grid or array of values and then proceed to evaluate the objective function of each of the 30 points. The best result is saved and all information about it is printed. In addition, the program will find various suboptima, i.e., given a fixed value of the third variable the optimum of the 5 x 2 sub-

* Variable mnemonics are translated in Appendix A. All units are S.I. unless otherwise defined.




FIGURE 3-1. THE POTENTIAL PROBLEM OF OPTIMIZATION STUDIES

array can be detected. The variable ranges, number of steps, and the order of execution can all be controlled by the program operator as well as the choice of which 15 parameters are allowed to be variables. All of these assignments are carried out by the main program, "MAWES." The name "MAWES" is an acronym for "Model for Alkaline Water Electrolysis Systems."

Besides sequencing the variables through the various grid points and remembering optimum results, the main program has two other important tasks. The first is the initialization of all the other fully constrained parameters. It does this by two methods, internal initialization and data statement or external initialization. The program internally sets all parameters to a baseline or default value using a block data subroutine. If the operator wishes to modify any value, a data reading algorithm allows the change. The new information is supplied using data cards and is not an internal part of the program. The last task of the main program is calling the output subroutines and most importantly calling the subroutine which actually calculates the objective function, the price of hydrogen, based upon the 262 parameters. This subroutine is named, "ESTIM," and the calculation is described in Section 3.1.2.

3.1.2 Objective Function

The price of hydrogen required to offset the fixed and operating costs of a water electrolysis system is a very complicated function of several design and economic parameters. The starting point for any trade-off study is obviously the plant size, which can be described by its input power or by the amount of gas output. One must compare similar sized plants and the optimum design for one size will not necessarily be optimum for another. To complicate the issue, the two size parameters are not

self-consistent, e.g., a 90% efficient 100 KW(in) plant produces more hydrogen than a 60% efficient 120 KW(in) plant. The chosen starting point is the plant D.C. busbar power.

In a computerized model such as this, one can not do a completely detailed design study especially if the goal is to optimize among the engineering and economic trade-offs. Chilton's Chemical Engineer's Handbook (Ref. 3) describes studies like this as "order of magnitude" estimates since generalized size versus cost curves are used in finding component costs rather than using firm price quotations. Obviously a full set of quotes and engineering drawings cannot be made for each computer iteration in the 262 dimensioned space. Chilton's estimates that this type of estimate will yield at best a $\pm 40\%$ final figure, but for doing design optimization studies this is more than adequate as long as the cases compared are not extremely different. Therefore, one should be cautious in comparing numbers generated here with firm numbers from other studies.

The model itself is structured in three segments, first a block of design routines size the individual components and calculate efficiencies, then a block of costing routines take those sizes along with manufacturing costs and rates for consumables to generate capital and operating costs. Finally, the last routine uses the above in a levelized revenue requirement calculation to yield the objective function, the levelized price of hydrogen. This levelized price is a time average weighted value to account for various rates of inflation in operating expenses. It is not the first year gas price but is more truly representative of the type of cost one should use in business decisions.

Figures 3-2 and 3-3 are block diagrams of the objective calculation. Subroutine calls are handled by the main subroutine, "ESTIM." "ESTIM" also makes a few early design calculations. These are discussed in the following section. "ESTIM" also handles the parametric constraints discussed in Section 3.1.1.




FIGURE 3-2. OBJECTIVE FUNCTION CALCULATION
DESIGN SECTION




FIGURE 3-3. OBJECTIVE FUNCTION CALCULATION
COST & REVENUE REQUIREMENT SECTION

NOTE: In the next three sections (3.1.2.1, 3.1.2.2 and 3.1.2.3) whenever an input parameter is mentioned, the number in parentheses following refers to its position in the input list in Appendix A.

3.1.2.1 Design Routines

The cell voltage is calculated using subroutine "VOLTCLC" from interpolating the parametric coefficients (E, S and R) at three input temperatures (#8-#19). Given the cell voltage, area (#5), current density (#6) and D.C. input power (#1), the number of cells are calculated. This is rounded to the nearest integer and the D.C. power is adjusted accordingly. If the number of cells is larger than some arbitrary maximum (#33), the stack is divided into multiple modules. Busbar currents and voltages are calculated assuming cells electrically in series and modules in parallel. The voltage efficiency is calculated defining the isothermal cell voltage at operating temperature and standard state concentrations as 100% voltage efficiency. At this point, "ETAREC" and "ETACUR" are called. "ETACUR" calculates the net effect of shunt currents on current efficiency (η_i). In this type of system the current efficiency is near unity because of the absence of any side reactions and because of the low gas solubility in concentrated caustic. For 25 w/o KOH, solubility is on the order of 10^{-4} molar for both gases (Ref. 4). There are shunt current paths in the electrolysis module, however, which bypass one or more cells, reducing the current efficiency as shown conceptually in Figure 3-4. "ETACUR" treats this effect using a linearized Kirchhoff's law technique to solve self-consistently for the loop currents. If these currents are small and do not change the cell impedance significantly, this technique is valid. For larger shunt currents, a nonlinear technique must be used. The current efficiency is ultimately a function of electrolyte conductivity (in turn a function of temperature and concentration), number of cells, cell voltage and cell impedance. "ETAREC" is the rectifier efficiency and is considered a constant 95% value.





FIGURE 3-4. CONCEPTUAL SHUNT CURRENT BYPASSING CENTER CELL

After η_1 is calculated, "ESTIM" calls either a round or rectangular module design routine depending on operator controlled input parameter "AMSTY" (#31). These routines calculate the cell frame annular thickness given internal pressure, temperature and a derated modulus of elasticity. The circular frame calculations are based on hoop stress and required seal length arguments. The rectangular case uses a beam loading calculation on the longest dimension to give the maximum plastic tensile stress. In addition, the amount of plastic and seal areas are found. Each of these routines calls an end plate and tie rod design routine. End plate thicknesses are calculated based on maximum deflection (#35) under load arguments. Tie rods are sized according to sealing loads, separator compression, and operating pressure. Tie rod safety factors (#55) are included, along with temperature effects (#51). Ultimately, these routines return design parameters such as end plate thicknesses and masses, tie rod lengths and diameters and associated costs.

The next routine called, "MANANAL," calculates the required fluid mass flow through the electrolysis module based on a cursory heat balance routine given the electrolyte temperature difference across the module (#25). Individual cell flow is calculated using a momentum balance technique described in Ref. 5. Maximum cell flow is detected for purposes of checking parametric constraints in flow.

After "MANANAL" is executed, "HMPB" is called. This routine calculates sizes for the major components in the electrolyte loops using an energy and mass balance technique. A block diagram showing the major components is shown as Figure 3-5. The net energy input consists of the D.C. input power plus the electrolyte pump power. The net energy output consists of the product enthalpy and heat losses by convection, condensation, and heat exchangers. The routine starts by finding the required anolyte and catholyte flow rates based on the input temperature difference across the electrolysis



- NOTES (1) NUMBERS REFER TO PROGRAM (COSTS) OUTPUT LOCATIONS.
 (2) OXYGEN PURIFICATION, COMPRESSION AND STORAGE SUBSYSTEMS SET AT 0 FOR ALL STUDIES.
 (3) HYDROGEN COMPRESSOR & STORAGE VESSEL SET AT 0 FOR ALL STUDIES.

FIGURE 3-5. SYSTEMS COMPONENT BLOCK DIAGRAM

module and the calculated module heat load. Given the piping pressure drop per unit length (#100), the minimum pipe size is calculated. A required piping length is estimated from the plant size and a total pressure drop is found. An additional percentage is added to account for heat exchangers and flow meters. This is then added to the module pressure drop calculated above to give the total loop pressure drop. From here it is easy to find the required pump power and size using various efficiency factors (#106, #113). At this point the routine switches to consideration of energy balances starting with sizing the gas condensers. Feed water requirements are calculated by balancing the masses of gas and uncondensed water leaving the condenser. Convective heat losses are then estimated for the electrolysis module, fluid reservoirs, and piping. Insulation thicknesses and K values are inputs (#125-131). The heat exchangers are then sized for the net remaining heat load given cooling water temperatures and overall heat transfer coefficients (#97, 132, 133). Finally, the on-board electrolyte requirements are calculated. The next routine, "CONDIT" sizes the gas handling systems including dryers, compressors, and storage tanks. Dryer calculations are based on the required gas purity (#139 and 140) and the condenser outlet temperature. Dryer power requirements are a direct function of overall size. If high pressure outlet gas is required, the routine calculates the size and number of stages of compressors. If gas storage is required as specified by a storage mass, the routine returns the displacement volume of storage.

The final design routine calculates an overall production efficiency taking into account the dryer gas losses, auxiliary power losses, module current and voltage efficiencies and power conditioning efficiencies.

3.1.2.2 Costing Routines

The costing section of the objective calculation is comprised of five subroutines, "OPCOST," "PLTCOST," "MODCOST," "LIFE," and "CAPCOST."

The first routine, "OPCOST," assigns and sums all the yearly direct and indirect costs associated with plant operation except for capital costs, taxes, and electricity. Items addressed include cooling water, feed water, electrolyte, consumable parts, and labor. Overhead costs are assigned as a simple percentage of labor while general and administrative costs are a percentage of labor, overhead and "materials."

"PLTCOST" assigns original costs to all plant subsystems except for the electrolysis module. Most components are costed using an order of magnitude approximation of the form:

$$\frac{C_x}{C_1} = \left(\frac{S_x}{S_1} \right)^N$$

where C_1 and S_1 refer to a standard size (S_1) component and its cost (C_1), while S_x refers to an arbitrary size component, C_x to its cost. The exponential factor is generally less than one reflecting the economics of scale up. All major components are essentially treated this way excluding control systems, cooling water piping, feedwater subsystem and purge gas subsystems which are treated as constants. The exact values of the coefficients and exponents are input parameters. For fluid and gas exposed systems the costs are multiplied by material correction factors so that the additional expense of higher cost materials can be modeled.

The module costing is handled in much greater detail in subroutine "MODCOST." This routine breaks down the cost of the module into individual components. Structural parts include end plates, tie rods and associated hardware, cell frames, and seals.

Internal components include bipolar plates, anolyte and catholyte flow distribution members, anodes, cathodes, and interelectrode separators. With each of the internal members there is associated a material stock cost per unit size, a stock utilization factor to allow for scrap and waste, and a processing cost. In addition, there is a catalyst cost input for each electrode. Cell frames are costed according to the amount of plastic required, the price of the frame mold and its expected parts yield, and a processing cost per piece. End plates are costed according to their mass and material prices per unit mass and a machining cost. The bolts are costed in proportion to their mass also, with an additional factor for hardware. Assembly costs follow the equation:

$$\text{Mod. Assy. Cost} = K1 \times \text{area} \times \# \text{ of cells} + K2 \times \text{area},$$

where K1 and K2 are input constants (#261, 262). These factors are all summed to arrive at a module cost, MODCOST.

At this point in execution, the module life is calculated as a function of operating temperature. Two specified lifetimes are input (#224, 226), one at low temperature, one at high. The subroutine "LIFE" interpolates between these using an Arrhenius-type curve, i.e.:

$$\text{LOG}_e (\text{LIFE}) \propto \left(\frac{1}{T_{\text{abs}}} \right)$$

where T_{abs} is in °Kelvin.

The total original capital cost of the system is calculated in subroutine "CAPCOST." For ease of calculation, all modules required during the life of the plant are considered to be bought at year zero. This does not introduce a large error if the discount rate and inflation rates are not widely divergent. In addition, refund values for all returned modules are estimated and credited to the original capital cost, thereby "avoiding" the

capital gains taxes. The original capital cost is then made up of the sum of plant and module costs. A spare parts inventory is tacked on as a percentage of plant cost. Design and engineering costs are also estimated but only a fraction is assigned to the plant cost assuming more than one plant of a given design will be built. Then, a gross profit margin for components is added on to the sum of the above. This completes the components price or cost to the customer but there are two other capital costs addressed in this routine, the installation and checkout costs and the building and facilities costs. Both of these scale with the plant size using some exponent less than unity as above. Different profit margins can be associated with each of the three divisions, components, facilities, and installation.

3.1.2.3 Revenue Requirement Routine

The last subroutine, GASCOST, uses the previously generated total capital cost, yearly operating costs, and power consumption to do a revenue requirement calculation for the levelized and first year gas prices. Levelized prices are an important concept used throughout the subroutine. In essence, this concept allows one to take an irregular cash flow distributed over time and compute a present worth. This then is distributed as an even payment cash flow which has the same economic force as the original cash flow. These evened out payments (or credits) are called the "levelized" payments. In the prediction of prices in inflationary times, this concept generates a much more useful number for comparison purposes. It should not be compared to costs or prices at a single point in time, however. The details of the calculation were taken from and are discussed in a study guide prepared by the Electric Power Research Institute (Ref. 6). In this calculation the effects of different rates of inflation on operating and power costs can be addressed. In addition, this routine calculates tax rates, accelerated depreciation

allowances, and investment tax credits. The initial investment can be broken into debt and equity financing and different interest rates can be assigned to each. Finally, there is a provision for a "retirement dispersion allowance" to add a safety factor for random differences in actual plant life.

This routine ends the objective function calculation and control is returned to the main program which tests for a lower levelized gas price than calculated in previous cases. Also returned are on the order of 200 other values such as design parameters, efficiencies, component sizes, and cost breakdowns. A list of these is given in Appendix B. Program execution notes are listed in Appendix C and a complete Fortran listing is contained in Appendix D. Figure 4-10 shows a sample final output optimum case. This run tested the sensitivity of three parameters, cell area (#5), current density (#6), and module temperature (#3) using a 4 x 8 x 4 grid or 128 function evaluations. Execution time was 0.9 C.P.U. seconds and the cost was \$2.00 for daytime priority execution. This run was executed on a C.D.C. Cyber 76 computer operated by Itel, Inc. at their Dallas, Texas facility.

3.2 TEST OR BENCHMARK CASE STUDIES

3.2.1 Input

To evaluate the model's predictive power and to debug the program, a particularly interesting test case was tried, this being an 80 KW D.C., dual irriguous (i.e., anolyte and catholyte) system sized for electric power generator cooling. Appendix A lists the specific input parameters used for this case, while Appendix B lists the total output results. The following is a generalized discussion of the input.

The first major input parameter is, of course, the input module D.C. power. For this example, the required maximum hydrogen gas output is ~250 SLM which translates to ~50 KW or 11,000 Kg H_2 /yr. Using a 62.5% D.C. to gas efficiency, this means a D.C. input requirement of 80 KW. Having selected a particular D.C. input, if a higher efficiency value for the module is subsequently calculated, then the output gas flow would be greater than required. It is possible to design the computer code to use a constant, specified gas output as the size parameter but this would require an expensive reiterative procedure to converge simultaneously on current efficiency, voltage efficiency, number of cells, and input power.

The other parameters can be grouped loosely into three divisions, (1) technical, (2) manufacturer, and (3) operator. Technical parameters include diverse items such as cell polarization characteristics, operating temperature and pressure, electrolyte concentration, module design and tie rod design parameters, flow curves, fluid systems and thermal systems design parameters, gas conditioning and storage systems design parameters, etc. The second grouping includes specific components cost vs. size curves, manufacturing and materials costs, catalyst costs, design and engineering costs, installation, test and facilities costs, etc. Also included in this set are profit margins on three general areas, components, installation and facilities. The third grouping includes both cost and technical items. Technical input from the system operator includes cooling water temperature and maximum flow rate, plant ambient temperature, gas storage requirements and outlet pressure. Economic input is comprised of items like power cost, duty factor, capitalization methods and interest rates, tax credits, accounting method, inflation rates, manpower costs, cooling water costs, etc.

For the baseline case, the cell polarization curves were taken from previous test results in this and preceding contracts. Baseline electrodes were nickel-200 wire screens and asbestos was used as a separator. Costs for this cell technology are fairly

well established since commercial systems produced by TES utilize the same materials in a similar design. Module design parameters (fluidics and mechanics) were also taken in large part from commercial system data although there is the major difference that the commercial system operates in the "single irriguous" mode (single flowing electrolyte) whereas this baseline system uses two electrolyte streams. Cold rolled 18-8 stainless steel characteristics define the tie bolt parameters and 316 stainless steel was used in the end plate design (Ref. 9). Fluid manifolds were chosen from previous studies done for EPRI. Cell frame parameters were taken from UDEL[®] polysulfone design literature (Ref. 10).

System temperatures chosen are representative of those encountered in practice. An operating temperature of 60°C and an ambient of 25°C was selected. A module temperature rise of 8.33°C defines the electrolyte flow rate when coupled with the module heat load. The heat exchanger and condenser heat transfer coefficients as well as the various efficiencies are taken from the commercial design. Many of the numbers are arbitrary such as heat exchanger outlet temperatures, reservoir and filter sizes, etc. Educated guesses are the "rule of thumb" here. Gas conditioning system design parameters are based on molecular sieve dryer design (Ref. 11) and standard compressor design curves.

Cost curves were generated from commercial systems design and wherever available, standard cost vs. size exponents were used. The numbers represent mid-1979 prices and are the latest available to the author. Other economic factors such as capitalization methods and interest rates also are somewhat arbitrary and will vary widely from case to case. A power cost of \$0.025/KWH was selected along with an inflation rate of 10%.

3.2.2 Results of Test/Benchmark Case

NOTE: In this section, the numbers in parentheses are referenced to the position in the output list in Appendix B.

The detail output results from the benchmark case are tabulated in Appendix B.

The predicted levelized gas price (#1) is \$6.99/Kg H₂ and the first year (#16) price \$4.03/Kg H₂ or \$0.96/100 SCF. These prices reflect the revenue required to cover capital, power and operating expenses, with return on internal investment and taxes included in capital charges. The gas output mass (#10) is 9,554 Kg/yr at an 85% duty factor or translated to peak flow, 0.0214 Kg/min (9.01 SCF/min). Levelized total costs per year (#21) are \$66,835 which are factored into levelized capital cost per year (#24) of \$16,152, levelized power cost per year (#22) of \$35,879, and levelized operating costs per year (#23) of \$14,803. These three costs will be further subdivided and discussed in the following paragraphs.

The total capital price (#7) for the system is \$87,013 and includes the original selling price for the components (system and all electrolysis modules used over the 20-year book life), the cost of installation and startup, and building and facilities costs. Original design and engineering charges are also accounted for separately. For this case, module plus components costs (#28) amounted to \$34,186 which includes credits for returned electrolysis modules. This cost was then incremented by 75% to allow for vendor gross margin. Installation and startup costs (#27) were \$3,417, again to be incremented by 75% for profit margins. Finally, the building and facilities (#26) were estimated to cost \$17,108 with no profit assumed. Design and engineering costs (#200) were \$410,000, of which 1% was charged to this plant (i.e., amortize D & E over 100 plants). This sums finally to the total capital price (#7) of \$87,013.

For a 20-year book life system capitalized at a 11.4% discount rate (#17), capital costs must be recovered (#20) at 12.89% per year, i.e., 12.89% of the original capital cost must be paid back each of the 20 years to cover the original debt plus interest. An additional 5.4% is required for income taxes (#153) on equity return and 2% was required for property tax and insurance (input #172). An accelerated depreciation allowance (#152) of 2.5% can be taken, however. Another 0.75% for retirement dispersion (#155) must be allowed. The sum of all these costs yields a 18.56% yearly fixed charge rate (#25) on the original capital or \$16,152/yr (#24). This is a leveled number but it should not change dramatically over time.

The components costs (#28) of \$34,186 can be broken into \$17,913 for non-electrolysis module components (#11) plus 1% (\$180) for original spare parts inventory (input #187), and \$16,094 for two electrolysis modules (#13) to last an estimated (#12) 10 years each. The cost for non-module components is further broken down in Table 3-1.

The estimated module cost (#66) of \$10,258 can be attributed to costs for cell components, end plates, tie rods, and assembly. The baseline module requires 90 cells (#15) of 670 cm^2 area (0.72 ft^2) (input #5) which operate at a current density of 6000 A/M^2 (557 ASF). More will be said about the predicted module design later in this section. Module costs are broken down in Table 3-2. As mentioned before, these costs relate to nickel screen electrodes, asbestos separators, polysulfone cell frames, and stainless steel end plates. Material utilization factors for die cut parts are taken into account, in this case a 1.4 M^2 stock (square) size is required for a 1 M^2 (round) part.

A replacement module for this system costs \$5,836 (#118). This smaller cost comes from the assumption that the end plates and tie rods are reusable but only an

Table 3-1. Components Cost - Baseline Case: 255 SLM H₂ OutFluid Systems Costs (Including Subassembly, Labor, and Burden)

	<u>Catholyte</u>	<u>Anolyte</u>
Plumbing	\$ 464.00 (#172)	\$ 464.00 (#171)
Filter	77.64 (#176)	82.67 (#175)
Pump	769.60 (#180)	769.60 (#179)
Heat Exchanger	665.50 (#178)	659.90 (#177)
Reservoir/Phase Separator	<u>904.90 (#182)</u>	<u>904.90 (#181)</u>
	\$2881.84	\$2881.07

Gas Systems Costs (Including Subassembly, Labor, and Burden)

	<u>Hydrogen</u>	<u>Oxygen</u>
Plumbing	\$ 219.90 (#174)	\$219.90 (#173)
Condenser	228.70 (#185)	314.60 (#184)
Dryer	1736.00 (#187)	-- (#186)
Compressor	-- (#194)	-- (#193)
Bottle	<u>-- (#196)</u>	<u>-- (#195)</u>
	\$2184.60	\$534.50

Other Costs (Including Subassembly, Labor, and Burden)

Purge Gas Plumbing	\$ 130.00 (#183)
Insulation	-- (#188)
Cooling Water Plumbing	220.00 (#189)
Feed Water Plumbing	200.00 (#190)
Ventilation	210.80 (#191)
Structures	1732.00 (#192)
Control and Instrumentation	3400.00 (#199)
Power Supply	2685.00 (#197)
Unassigned (5% of subtotal)	<u>853.00 (#198)</u>
	\$9430.80

TOTAL

\$17,913 (#11)

Table 3-2. Module Cost Breakdown

	<u>Cost Per Cell</u>	
Cell Internal		
Bipolar Plate	\$ 8.550	(#64)
Flow Members (2)	5.783	(#65)
Anode	6.778	(#162)
Cathode	6.778	(#163)
Separator	1.169	(#63)
Cell Structural		
Cell Frames (2)	17.66	(#168)
Cell Seals (2)	<u>7.231</u>	(#169)
	\$53.95	x 90 cells (#33) = \$4855.50
Tie Rods	\$188.80	(#166) x 8 (input #49) = \$1510.40
End Plates (pair)		\$2984.00 (#165)
Assembly (L + B)		<u>\$ 907.50</u> (#170)
TOTAL MODULE COST (#66)		\$10,257.40

effective small fraction of the cell internal and structural members are reusable. An additional 50% disassembly charge is tacked onto the returned module as a reassembly cost.

The yearly operating cost for the system, excluding power cost is broken into four categories: material, labor, overhead, and general and administrative. The yearly materials allotments are for cooling water, feed water, consumable parts, electrolyte, and purge gas, for a total of \$1493/year. Labor cost is estimated at \$2524/year (#159) (0.18 man year @ \$14,000/yr). The input overhead rate of 100% is applied to this labor cost to yield \$2524 (#161), while no G & A is charged (#160). The cooling and feed water requirements reflect the 85% duty cycle input, while the other material factors and labor requirements do not. The total is \$6,541 (#9) for the first year while the levelized figure (#23) is \$14,803 reflecting a 10% inflation rate (input #166) and 11.4% (#17) discount rate.

The yearly power cost is simply calculated from the A.C. power requirements (85.2 KW), duty factor (input #169) (85%) and power cost (input #167) (2.5¢/KWH). This cost turns out to be \$15,855/yr (#8) for the first year or \$35,879 (#22) for the levelized cost. The A.C. power of 85.2 KW (#2) is the sum of 877.6 watts for auxiliary systems (#137) and 84.3 KW for the electrolysis circuit. The overall system efficiency is 59.28% (#3) for A.C. in to gas out based on the heat of formation of water:



Module efficiency is 63.9% (current efficiency = 95.49% (#34), voltage efficiency = 66.92% (#35)). Gas purification efficiency is 98.66% (#37) and rectifier efficiency was input at 95%.

Not only are the costs described above returned by the program, but also several design requirements for the electrolysis module, fluid loops, and gas conditioning systems. For the baseline case, the model predicted a 90-cell electrolysis module is required. The end plate dimensions are 57.7 cm (diam) x 9.8 cm (thickness (#51). The cell frame annular width is 11 cm (#46) and tie rod diameter is 2.2 cm (#49). Using heat exchangers with an overall heat transfer coefficient (U) of $568 \text{ W/M}^2\text{C}$ and 35°C cooling water, the program predicts heat exchanger areas of 1.183 and 1.196 M^2 for anolyte and catholyte, respectively (#100, #101). Heat loads here are on the order of 14 KW each (#41, #102, #103). Condenser areas are 0.061 and 0.098 M^2 for oxygen and hydrogen (#86, #87). The total water mass flow rate is predicted to be 0.835 Kg/sec (#88) (12.9 gpm). The gas output mass flow rate for this case is 9554 Kg/year (#10) or using the 85% duty cycle, a peak output of $3.5609 \times 10^{-4} \text{ Kg/sec}$ (#123) (255.1 SLM or 540.5 SCFH).

Although many of the inputs were arbitrary and more than a few were educated guesses, the values returned for this case do reflect believable quantities based on past experience. It is important to remember though that this type of study yields price estimates with only limited ($\pm 40\%$) accuracy and should not be treated as project control estimates, much less final values. It is extremely useful for comparison of alternatives when the same values of economic variables are utilized, and even more useful as a tool for gauging the true sensitivity of design alternatives.

3-26

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

4.0 SENSITIVITY STUDIES

The initial computer runs conducted as part of this task were arranged into four studies. Study One tests the sensitivity of the gas price to overall system size measured in terms of module input power. Two electrode technologies were evaluated, the first utilizing baseline nickel-200 screen electrodes, the second utilizing the C-AN advanced cathode and nickel-200 screen anode. As suggested by BNL at the start of the task, four sizes were employed, 80 KW, 250 KW, 500 KW, and 1000 KW (1 MW). Study Two tests the effect of operating temperature on the prices of the two electrode technologies. Study Three is a deeper effort based on Study Two and tests the effects of current density, temperature and module size on both technologies. The last study requested by BNL, Study Four, shows the effect of system duty factor and the electricity rates upon the gas price, again for both electrode technologies.

4.1 STUDY ONE. EFFECT OF PLANT SIZE

To ascertain the magnitude of the economies of scale on alkaline water electrolysis systems, the program was run for four sizes ranging from 80 to 1000 KW D.C. input power. For each size the computer picked an optimum cell area but the current density was set at 6000 amp/M^2 and the operating temperature at 60°C . Most of the inputs were the same as the baseline case, although a few estimates were required to be input for the bigger systems in the few areas where the model will not solve for the required size. Figure 4-1 shows a plot of gas price vs. size for the baseline technology. The model predicts a reasonably linear behavior for the price when plotted versus the logarithm of power, a slope of about $-\$1.30/\text{Kg H}_2$ per decade power. The price shown here is the 20-year levelized value. Figure 4-2 gives a similar plot for first year prices. The cost of electricity for all sizes was 2.5¢/KWH as in the baseline case. Also shown on




FIGURE 4-1. LEVELIZED GAS PRICE VS. SIZE: BASELINE TECHNOLOGY




FIGURE 4-2. FIRST YEAR GAS PRICE VS. SIZE: BASELINE TECHNOLOGY

these plots are the proportion of yearly costs going to fixed capital costs, power costs, and to other operating costs. It is interesting to note that in the 80 KW system the capital and power costs share equal magnitude only when considering first year costs. Since capital is a (relatively) fixed value whereas power is inflationary, the levelized numbers reflect a much greater sensitivity to power costs. For larger plants, this dominance is increased since in the absence of size-dependent electricity rates, power costs show no economies of scale.

Figure 4-3 is a log-log plot of the major costs calculated for the baseline technology in this study. The first year power cost curve has a 45° slope in reference to the axes, again because of no economies of scale for power. The top curve is the total capital price of the system including installation and facilities. For the 80 KW system, the price is ~\$88K and increases to \$480K for the 1 MW (input) system. As indicated in the figure, the slope is much less than 45° . Whether the trend continues or not can not be predicted by this study since, as mentioned above, the cost curves utilized are accurate only in low power regimes. The indication is, though, that the price of hydrogen decreases dramatically with increasing system size and further study, including obtaining more accurate cost data, is warranted.

Similar runs were made using cost and current-voltage data for the C-AN advanced cathode technology. These are presented in Figures 4-4, 4-5, and 4-6. Comparing Figure 4-1 (baseline technology) and 4-4 (C-AN cathode technology), the levelized price curves, one notes that the cost ratio curves are almost superimposable. This may seem strange until the reader remembers that the model is comparing plants of similar input power and the C-AN containing plant would then use the same power to produce more gas. As indicated, the advanced technology results in a lower cost




FIGURE 4-3. PRICE VS. SIZE FOR BASELINE TECHNOLOGY, 2.5¢/KWH




FIGURE 4.4. LEVELIZED GAS PRICE VS SIZE: C-AN CATHODE TECHNOLOGY




FIGURE 4-5. FIRST YEAR GAS PRICE VS. SIZE: ADVANCED CATHODE TECHNOLOGY




FIGURE 4-6. PRICE VS. SIZE: ADVANCED CATHODE TECHNOLOGY, 2.5¢/KWH

of hydrogen. Table 4-1 makes a comparison of the two technologies for the 80 and 1000 KW cases.

There is a small difference between the baseline case described in Section 3.2 and the 80 KW system here. This is because in this set of runs, the computer selected the optimum cell size of 0.15 M^2 , over twice the area of the baseline cell. Figure 4-7 shows the effect of nickel-200 technology cell area on gas price for the four plant sizes. In the larger plants the effect is remarkably flat except in the low area region. For the 80 KW system, the effect is more pronounced, due mainly to the greater proportional price of end plates in the smaller modules. The minimums for all these curves will vary when other parameters are allowed to vary, particularly the cell current density as will be seen in the third study.

4.2 STUDY TWO. EFFECTS OF TEMPERATURE: 80 KW UNIT

This study consisted of two computer runs, the first for baseline nickel screen cell technology, the second for C-AN cathode technology. Temperature was varied from 55 to 125°C and while the other input parameters were kept at the baseline case values, the principal units being 85% utilization, 80 KW size and 2.5¢/KWH. Figure 4-8 summarizes the results from this study. The levelized price of hydrogen does, indeed, decrease with increasing temperature. Each of the curves here is made up of segments from a family of curves describing systems requiring 2, 3, or 4 electrolysis modules over the 20-year book life of the plant. Recalling that part of the input information is the module life at two temperatures, in this case, module life was estimated to be 10 years at 50°C and 5 years at 125°C. The program interpolated between these two lifetimes using an Arrhenius type behavior and calculated the number of modules required over the plant life, rounding to an integral number. A more detailed calculation may not

**Table 4-1. Study One: C-AN vs Ni Screen Technologies,
80 and 1000 KW Plants @ 60°C, 6000 A/M²**

Size		<u>Nickel Screen Cathode</u>		<u>C-AN Cathode</u>	
		<u>80 KW</u>	<u>1000 KW</u>	<u>80 KW</u>	<u>1000 KW</u>
Levelized gas price	(\$/Kg)	6.73	5.29	5.91	4.623
First year gas price	(\$/kg)	3.879	2.936	3.44	2.41
Gas output	(Kg/yr)	10,100	124,500	11,300	141,500
Efficiency	(%)	61.6	61.7	69.8	70.2
Cell voltage	(V)	2.213	2.213	1.948	1.948
Cell area	(M ²)	0.15	0.75	0.15	0.75
Cell cost	(\$)	91	370	95	387
Number of cells		41	101	46	115
Module cost	(\$K)	12	97	13	105
Capital price	(\$)	87,848	479,890	90,257	505,900




FIGURE 4-7. GAS PRICE VS. CELL AREA: BASELINE TECHNOLOGY




FIGURE 4-8. LEVELIZED H₂ PRICE FROM 80KW SYSTEM VS. MODULE TEMPERATURE
85% UTILIZATION, 2.5 /KWH

round this way but instead calculate the remaining life in the last module and take a resale credit for it, thus smoothing out the curve. It is interesting to note that because of this effect the minimum for the C-AN technology is at 105°C although the value at 125°C is very close. One additional reason for this can be seen by considering the values presented in Figure 4-9, a plot of current and voltage efficiency versus temperature. The voltage efficiencies of both technologies are increasing with temperature at close to the same rate. The current efficiencies are almost identical. (Not plotted are the gas purification efficiencies, 98.7% in all cases, and the rectifier efficiencies, 95% in all cases.) Therefore, from 55°C to 125°C the overall efficiency in the baseline system changes from 58.8% to 66.7%, an absolute increase of 7.96% and a relative increase of 13.55%. For the advanced technology, the absolute increase is 7.72% but the relative increase is only 11.65% since the low temperature efficiency is a higher value to begin with. This means that one does not gain as much going to higher temperatures in the advanced system case which explains part of the lower curve in Figure 4-8. Again, the significant conclusion is both curves indicate that operation at higher temperatures is economically advantageous if the module life (and system life) is not substantially diminished at higher temperatures.

4.3 STUDY THREE. OPTIMIZATION OF CELL SIZES AND CURRENT DENSITIES:

80 KW UNIT

This study was basically an expansion of Study Two in which temperature, current density, and cell area were allowed to vary, temperature from 50°C to 125°C in 25°C steps, current density from 3000 to 10,000 A/M² in 1000 A/M² steps, and cell area from 0.05 M² to 0.55 M² in 0.1 M² steps. This optimization was run for both technologies. Figure 4-10 is a plot of the levelized price of hydrogen versus cell current




FIGURE 4-9. MODULE EFFICIENCY VALUES VS. OPERATING TEMPERATURE
80 KW UNIT




FIGURE 4-10. LEVELIZED GAS PRICE VS. TEMPERATURE & CURRENT DENSITY FOR BASELINE (Ni-200) CATHODE/ASBESTOS TECHNOLOGY. OPTIMUM CELL AREA IS 0.25 M², 80KW, 2.5¢/KWH

density at the four temperatures for baseline technology electrodes. There is a rather broad minimum in all cases ranging from 3000 A/M² at 50°C to 5000 A/M² at 125°C. The program predicts a small area module (0.15 M²) for higher current densities. The optimum cell area increases as current density decreases and the dashed lines on Figure 4-10 show which cell area is optimum. Figure 4-11 gives the same information for the C-AN cathode technology module and as before, significant savings are predicted independent of the operating conditions. The optimum current density is generally higher than in the baseline case. It is interesting to note that in the advanced technology case there were three combinations of parameters disallowed by the model due to thermal instability. They all were at 125°C, and 3000 A/M² and large module size. This is the reason that the lower curve in Figure 4-11 rises at the left side and actually crosses the 100°C curve. It is possible that insulation could be added to maintain 125°C operation, but since the optimum is at ~6000 A/M² anyway, this option was not pursued. The overall conversion for both technologies is shown as a function of temperature in Figure 4-12.

For this 80 KW case the minimum levelized gas price for baseline technology was \$5.92/Kg (\$1.40/100 SCF) and the first year price was \$3.60/Kg (\$0.85/100 SCF) occurring at a current density of 5000 A/M², cell area of 0.25 M² and at 125°C. For the advanced technology, the optimum levelized price was \$5.35/Kg (\$1.27/100 SCF) and the first year price was \$3.25/Kg (\$0.77/100 SCF) occurring at the same temperature and cell area but at 6000 A/M².

4.4 STUDY FOUR. EFFECT OF ELECTRICITY COSTS AND UNIT UTILIZATION (DUTY FACTOR): 80 KW UNIT

This study was conducted to test the sensitivity of the two technologies to the cost of electricity and the system duty factor. All other inputs were the same as the




FIGURE 4-11. LEVELIZED GAS PRICE VS. TEMPERATURE & CURRENT DENSITY FOR ADVANCED CATHODE (C-AN)/ASBESTOS TECHNOLOGY. OPTIMUM CELL AREA IS $\sim 0.25 M^2$, 80KW, 2.5 /KWH




FIGURE 4-12. OVERALL EFFICIENCY VS. TEMPERATURE, 80KW UNIT

baseline case so these do not represent optimized modules at any given point, but serve to illustrate the cost trends. Figure 4-13 is a carpet plot of the results from the baseline technology run. As one would expect, the lowest gas costs occur for a 100% duty factor and lowest electricity cost. There is not a direct increase in gas cost as the duty factor decreases however. At 3¢/KWH the cost of hydrogen goes from \$7.30/Kg to \$8.90/Kg when the duty factor is decreased from 100% to 60%. Figure 4-14 is a similar plot for the advanced technology case. In order to facilitate direct comparison, Figure 4-15 presents the same two plots on one page.

Previous studies have emphasized the plant utilization or duty factor would have a significant influence on the cost of hydrogen. What is indicated in this study is that with use of 10% inflation as applied to the major cost factors in hydrogen economies, namely the power to the module and the other operating costs, duty factor, which only controls the capitalization expense, is not as significant an influence. What the proper value for inflation should be, remains for future studies. The selection of 10% may even be considered incredibly low at this report time.




FIGURE 4-13. LEVELIZED GAS PRICE VS. ELECTRICITY COSTS & DUTY FACTOR,
BASELINE TECHNOLOGY




FIGURE 4-14. LEVELIZED GAS PRICE VS. ELECTRICITY COST & DUTY FACTOR, ADVANCED CATHODE TECHNOLOGY




FIGURE 4-15. LEVELIZED GAS PRICE VS. ELECTRICITY COST & DUTY FACTOR, TWO TECHNOLOGIES

5.0 DISCUSSION

5.1 MODEL FOR ALKALINE WATER ELECTROLYSIS SYSTEMS: "MAWES"

5.1.1 General

By far the major amount of effort during this task went into the development of the "MAWES" computer program. It was not until near the end of the task period that the program was considered to be effectively "debugged." As shown in the previous section, several cases have been run using it and some of the program's strong points and drawbacks have become apparent.

On the positive side, the computer program is relatively flexible and easy to operate. Although it is structured for the alkaline electrolysis systems, it is flexible enough to allow many variations within normal configurations by only changing a few data cards. The main program also has no limitations with respect to plant size and operating temperature save the previously mentioned limitations in accuracy based on cost estimation and lifetime data.* The other major point is that while generating fairly detailed design and cost information, the program is rather rapid and therefore cheap to operate. If used in a compiled form, each case requires on the order of one cent to execute, and detailed output for a case only doubles that price. Finally, based on historical values, the model generates numbers that are in credible ranges and so the program becomes very useful for sensitivity studies and preliminary cost estimates.

There are some drawbacks, however, that deserve mention. As discussed in Section 3.1.1, the optimization technique used is limited to points on a user supplied grid. Considering the speed of execution using a more sophisticated "simplex" technique is certainly viable. It would also be advisable to develop another subroutine which would

* Added in proof: At present several of the subroutines do have constraints. Modifications to these subroutines would be fairly easy to make to allow calculations of larger plant economics.

allow the user to manipulate groups of variables in concert rather than independently. While this has not been necessary to date, there are several cases where one might wish to recalculate an input value based on other inputs, for example, the price curve for a heat exchanger based on its overall heat transfer coefficient. Another helpful addition would be an output subroutine which reports the results in a more convenient format such as in Tables 3-1 and 3-2, for example. As it stands now, the program possibly reports "too much," i.e., one can be deluged with data that, while interesting, is probably not necessary for every user.

5.1.2 The Objective Calculation

As mentioned above, the present objective calculation can be considered very powerful and certainly accurate within the constraints of available data. This is not to say that it should be considered in its final form. As design techniques improve these should continually be incorporated into the calculation. There are several places where the calculation could be improved and even speeded-up, and there are several points where more detailed analysis is warranted. In addition, since so much of the accuracy is dependent on accurate cost versus size curves, it is imperative that these curves be updated on at least an annual basis, especially in light of today's inflation. The module lifetime/temperature curves should be updated reflecting the results from ARIES testing. Areas where improved algorithms are advisable are (1) heat exchanger overall heat transfer coefficient calculation, (2) electrolyte reservoir design, (3) electrolyte filter sizing, (4) gas dryer design, (5) manifold electrolysis loss estimation, and (6) power conversion efficiency estimation. It may be advisable to eliminate the module internal fluid distribution calculation or replace it with a more flexible module pressure drop calculation. In the costing routines, one area that could be made more flexible is the calculation of the total capital price, especially

with respect to vendor profit. As it presently stands, a simple gross profit margin is used but it may be advisable to estimate this number instead based on plant size, return on capital, projected sales and company profit goals. One final suggestion which deserves consideration is the choice of D.C. module power as an input and gas production rate as an output. In many cases one would rather have gas output fixed and calculate the required input power instead. This means, though, a time consuming reiterative technique would have to be used since the efficiency calculations flow most directly from the input power, current density and module parameters. It would also be advantageous to structure the program so the user can select either mode of calculation.

There are two additional "final" subroutines which could make the program more flexible and more realistic but should be considered only for single case, i.e., optimized plant, calculations since they are quite detailed. The first would be the development of a detailed year-by-year revenue requirement calculation. The levelized technique is very fast but it makes several argumentative assumptions such as constant rates of inflation, lumped (year zero) capitalization, fixed tax rates, etc. By using a year-by-year formal accounting procedure, one might more accurately predict product costs and time effects. The second development would be to employ a variable power and power cost factor. With this type of input, one could more accurately estimate the economics of operating an electrolyzer coupled to a variable power source, for example a solar array or off-peak power.

It must be reiterated that as it stands, the computer model is a powerful and effective tool for prediction and estimation. The above suggested improvements would serve to make it more so.

5.2 THE STUDY: A DISCUSSION OF FINDINGS

5.2.1 Baseline Findings

The most important result issuing from the baseline study was that the first year cost of hydrogen for a 80 KW, 60°C, proven technology electrolyzer is ~\$4/Kg or \$0.96/100 SCF. Remembering that this case used 2.5¢/KWH power and 11.4% cost of money (discount rate), the price is competitive with merchant gas rates in many parts of the country. When considering levelized values, the hydrogen from an on-site generator becomes a better bargain. For example, if merchant gas is \$0.96/100 SCF at the end of year zero, and 10%/yr inflation is forecast over 20 years with the discount rate at 11.4% then the levelized cost of merchant gas is \$2.17/100 SCF compared to the levelized cost of electrolytic gas of \$1.66/100 SCF. These costs reflect only one set of economic conditions, a certain amount of prognostication and a non-optimized system but the trend is certainly encouraging for small scale, on-site electrolytic hydrogen.

A second result of the baseline case study was the conclusion that the gas price tends to be energy intensive even for these small systems. It is important to remember that as a different set of economic assumptions can easily change the sensitivities, although increases in efficiency are justified, capital costs cannot be neglected. The first year price tends to emphasize capital cost over that of power but levelized prices indicate power and operating costs become more important. Most modern companies would tend to choose among economic alternatives based on the levelized price.

5.2.2 Sensitivity Study Findings

Several results of the four sensitivity studies tend to substantiate the baseline results.

First, the C-AN cathode technology does offer a real savings over nickel screen technology. Of course, this is a rather inexpensive technology, adding only \$21/M² for catalysts and yielding a significant (~300 mV @ 5000 A/M²) voltage reduction, so the benefits appear intuitively obvious. For a 80 KW system (Study Four, 80% duty factor) the levelized savings range from 55¢/Kg at 1¢/KWH electricity to \$1.24/Kg at 5¢/KWH electricity or for all electricity rates, about 11% savings in gas cost.

Second, in all the trials, operation at as high a temperature as possible yielded the lowest gas price except for the previously discussed case shown in Figure 4-8. It is important to realize that these results are very sensitive to temperature/life data. If a module has more drastic limitations in life at high temperature than used in these studies, the optimum operating temperature could decrease significantly. The same holds true for component life effects and maintenance rate versus temperature effects. However, the results obtained thus far indicate that higher temperature operation is definitely worth pursuing.

Third, the current density chosen for ARIES testing was 4500 A/M². The current density sensitivities yielded in most cases a rather broad minimum centered in the 4000-6000 A/M² region for small plants. For larger plants, higher temperatures or more expensive cells, this value tends to become higher. However, there was no lifetime versus current density information built into the model. If such correlations exist then that information should be included and will affect the optimum current density accordingly. Perhaps more surprising was the tendency to optimize at larger cell areas. There are several assumptions implicit in the model which may have significantly influenced this result, e.g., the assembly and electrode costs proportional to cell area. This is another area where further study is warranted.

5.3 ADVANCED ALKALINE WATER ELECTROLYSIS PROGRAM DIRECTION, SOME SUGGESTIONS

Thus far, the MAWES computer model has served to reinforce the previous statements made by TES personnel relative to the advanced alkaline water electrolysis program. There are two possible explanations for this. First, we are excellent prognosticators, or second, our technical biases have been built into the computer code and input data. In view of the absence of hard data in so many areas, the second explanation is more likely. Since cell component life data probably has the largest bias, we recommend as a top priority the continued evaluation of materials and cell components in the ARIES system and other test fixtures in order to establish meaningful lifetime and performance data at elevated temperatures. It is also necessary to continue the development of the "Model for Alkaline Electrolysis Systems" in order to increase its flexibility and reliability. There are two aspects to this development, that of the model itself and that of its data base. Several improvements to the model have been discussed in Section 5.1.1 but these are not inclusive. The model should never be treated as a final version but should be continually improved. The same holds true for the data base. As mentioned previously, the order of magnitude cost estimation method yields at best 10% accuracy. This is obtainable only if the data is current and not too far removed in size from the systems under investigation.

Given these caveats, one can suggest a direction for the technology in general. First, since the studies to date indicate the levelized gas cost is energy intensive, efforts should be directed to finding higher efficiency cell components, concentrating on lowering the cell internal resistance and possibly the anode polarization without incurring overwhelming cell component cost increases. Second, high temperature operation should be pursued for the same reasons, keeping in mind that current efficiency effects cannot

be neglected. Third, in order to keep capital costs from escalating, the module life and, in general, component reliability as functions of temperature should not be neglected. Fourth, novel approaches to cell and system design which could be less expensive should be encouraged. Since the predicted price of hydrogen for smaller systems indicates an edge over merchant gas, the market for such systems should make such efforts worthwhile to the developer.

For larger systems, there are possibly some overlooked uses that should be studied. First, it is not too early to investigate the economics of coupling solar photovoltaic power generation to electrolytic hydrogen production. Rapid strides are being made in the former while the problem of efficiently utilizing such a variable power source remains to be adequately addressed. Second, one should reinvestigate the economics of electrolytic hydrogen as a peak power shaving technology, this time for large coal-fired baseload plants. It may be advisable to build high efficiency baseload systems to cover peak demand while using the excess off-peak energy to produce hydrogen.

5.4 A PRELIMINARY COMPARISON OF ADVANCED ALKALINE (AAWE) AND SOLID POLYMER (SPE) ELECTROLYSIS: 1 MW SYSTEM

It is possible at this time to do a preliminary comparison of these two leading water electrolysis technologies. The MAWES program was used to predict the prices for advanced alkaline technology as it has been demonstrated to date and for a future goal technology. Data for the SPE case is taken from the latest General Electric Reports (Ref. 12 and 13). There, too, there are two cases, these being demonstrated and goal technologies. The same economic conditions should apply to each system and these are listed in Table 5-1.

Table 5-1. Economic Input Variables for SPE/AAWE Comparison*

Plant size	1 MW (thermal equivalent output)
Power cost	3.0 ¢/KW
Rate of inflation	0%
Cost of capital	10%
Percent debt financed	100%
Book life	6 years
Module life	6 years
Oxygen credit	None
Duty factor	90%
Investment tax credit	None
Capital recovery factor (calc.)	23%
Fixed charge rate (calc.)	23-3/4%

* SPE - Solid Polymer Electrolysis

AAWE - Advanced Alkaline Water Electrolysis

The demonstrated technology for alkaline water electrolysis consists of the best technology demonstrated to date using the ARIES test system. This is the C-AN cathode coupled with nickel screen anodes and asbestos separators. The SPE technology consists of the best reported performance of the 2-1/2 ft² G.E. technology. Table 5-2 is a comparison of the economic output values. The advanced alkaline data was obtained from the model for alkaline water electrolysis systems (MAWES), the SPE data from the G.E. reports. Zero inflation, although impossible, was used to equate the G.E. values of 1975 or 1980 constant dollars. In several places the reported SPE numbers are subject to variable interpretation but based on our understanding of the reports and limited conversations with BNL personnel, the comparison is valid. It is very interesting to note the closeness of the total system capital price. This is somewhat surprising in view of the report fact that the SPE design calls for titanium plumbing whereas the alkaline system is stainless steel. It is also intriguing to see a lower module cost predicted for the SPE technology than for the existing technology. This probably indicates either underestimation on the part of the SPE designers or overestimation on ours, or both. No further breakdown of the capital price is known for the SPE system but it would be enlightening to see how these separate items contribute to the overall price. One last factor that is extremely different is the yearly operating cost of the two systems. Although the use of the lower operating cost would be more advantageous, the higher value would appear to be more realistic considering that it involves burdened labor, cooling water, feed water and maintenance spares.

Examination of goals of both parties was made and the data are presented in Table 5-3. The goal technology for advanced alkaline water electrolysis incorporates the following features: (1) C-AN cathode, (2) a high temperature separator with half the

Table 5-2. Existing Technology - 1 MW Electrolyzer**(As Demonstrated in Applied Research Testing)**

		<u>SPE</u>	<u>AAWE</u>
Gas output	(Kg/yr)	2.00×10^5	2.02×10^5
Peak output	(watts)	1.00×10^6	1.01×10^6
Current density	(A/M ²)	10,760	6,000
Operating temperature	(°C)	88	125
Cell area	(M ²)	0.23	0.90
Number of cells		~300	130
Cell voltage		1.85	1.68
Overall efficiency	(%)	72 (?)	81
Module cost	(\$)	100,000	140,000
Cell cost	(\$/M ²)	588	489
Total capital price	(\$)	460,000*	468,000
Total yearly cost	(\$/yr)	466,000	454,500
Yearly power cost	(\$/yr)	328,600	293,700
Yearly operating cost	(\$/yr)	28,000	49,800
Yearly capital cost	(\$/yr)	109,200	111,000
Non-module plant cost	(\$)	?	101,000
Components cost	(\$)	?	240,900
Gross profit on components	(\$)	?	180,700
Building and facilities cost	(\$)	?	33,500
Gross profit on B & F	(\$)	?	0
Installation and standard cost	(\$)	?	6,700
Gross profit on I & S	(\$)	?	5,000
Design and engineering cost	(\$)	?	801,200
D & E per system	(\$)	0 (?)	801
Levelized cost of hydrogen	(\$/Kg)	2.33	2.25
	(\$/MBTU)	17.35	16.75
	(\$/GJ)	16.46	15.90

* "Installed cost" @ \$460/KW (Ref. 13).

Table 5-3. Goal Technology - 1 MW Electrolyzer

		<u>SPE</u>	<u>AAWE</u>
Gas output	(Kg/yr)	2.00×10^5	2.09×10^5
Peak output	(MW)	1.00	1.04
Current density	(A/M ²)	10,760	10,000
Operating temperature	(°C)	150 (?)	125
Cell area	(M ²)	0.23	0.5
Number of cells		271	146
Cell voltage	(V)	1.60	1.55
Overall efficiency	(%)	87.5	87.4
Module cost	(\$)	65,000	66,700
Cell cost	(\$/M ²)	194	459
Total capital price	(\$)	400,000*	329,400
Total yearly cost	(\$)	388,700	406,650
Yearly power cost	(\$)	270,308	282,300
Yearly operating cost	(\$)	23,379	46,200
Yearly capital cost	(\$)	95,000	78,200
Non-module plant cost	(\$)	?	94,600
Total component cost	(\$)	?	162,200
Gross profit on components	(\$)	?	121,700
Building and facilities cost	(\$)	?	33,150
Gross profit on B & F	(\$)	?	0
Installation and startup cost	(\$)	?	6,611
Gross profit on I & S	(\$)	?	4,958
Design and engineering cost	(\$)	?	793,300
D & E per system	(\$)	?	793
Levelized cost of hydrogen	(\$/Kg)	1.944	1.947
	(\$/MBTU)	14.51	14.53
	(\$/GS)	13.76	13.78

* "Installed cost" @ \$400/KW (Ref. 13).

resistance of the present chrysotile asbestos, (3) a lower overpotential anode, (4) single seal, single frame cell construction, and (5) a less costly end plate design. These advances are quite possible based on results reported by others working with this technology. The G.E., SPE announced goal technology remains as the 1975 data (Ref. 12, 13). The similarity in final prices was completely unexpected and many of the points raised concerning Table 5-2 above are visible here again.

All things considered, there is one inescapable conclusion. That is that advanced alkaline water electrolysis is a viable alternative to solid polymer electrolysis. Those who are familiar with both technologies and more importantly who are able to estimate the probability of success in achieving the goals in each cannot but help but conclude that alkaline water electrolysis should be an equal contender for the future market in water electrolysis technology.

6.0 ACKNOWLEDGMENTS

I would like to acknowledge and am grateful for the continuing support of this effort by the Department of Energy and the staff at BNL, specifically S. Srinivasan, A. Mezzina, G. Kissel and F. Salzano. At Teledyne Energy Systems, several people contributed to the MAWES program. Michael Miller wrote the original version of the fluid distribution, heat and mass balance codes. Marc Saltzman wrote the original module design and manifold losses routines. Saul Zuckman helped in our understanding of the levelized revenue requirement concept. Special thanks to E. Tilmes, M. Braczynski and D. Barrett who operate the company computer center, and to M. Gembarosky, F. Fahdt, and L. Mickle who prepare the text and artwork.

7.0 REFERENCES

1. Fiacco, A. V., McCormick, G. P., "Nonlinear Programming: Sequential Unconstrained Minimization Techniques," Wiley, NY, 1968.
2. Box, M. J., "Computer Journal," Vol. 8, 42, 1965.
3. Perry, R. H., and Chilton, C. H., "Chemical Engineers" Handbook, 5th Edit., McGraw Hill, Inc., 1973
4. N-69-41206, Walker, R. D. Jr., Sixth Semi-Annual Report, NASA Research Grant NGR 10-005-022, Feb. 1969.
5. Bajura, R. A., and Jones, E. H., Jnl. of Fluids Engineering, pp 659-666, Dec. 1976.
6. EPRI: PS-1201-SR, "Technical Assessment Guide," Electric Power Research Institute, Palo Alto, CA, July 1979; EPRI-PS-866-SR, "Technical Assessment Guide," June 1978.
7. TES-BNL-12, "Advanced Component Testing in the Applied Research Industrial Electrolysis System (ARIES)," Task 1 Summary Report, Contract BNL-480421-S, Teledyne Energy Systems, March 1980.
8. TES-BNL-26, "Electrolysis Cell Material Development," Task Order 2 Final Report, Contract BNL-380750-S, Teledyne Energy Systems, 10 June 1978.
9. Roark, R. J., and Young, W. C., "Formulas for Stress and Strain," 5th Edit., McGraw Hill, Inc., 1975.
10. Technical Data Sheets, Union Carbide Corp., Chemicals and Plastics Div., Bound Brook, NJ 08805.
11. Hersh, C. K., "Molecular Sieves," Reinhold Publishing Corp., NY, 1961.
12. CONF-781142, "Proceedings of the DOE Chemical/Hydrogen Energy Systems Contractor Review, November 27-30, 1978, Washington, DC," pp 13-25, U.S.A. Department of Energy, May 1979.
13. CONF-791127, "Proceedings of the DOE Chemical Energy Storage and Hydrogen Energy Systems Contracts Review, November 13 and 14, 1979, Reston, VA," pp 7-10, U.S.A. Department of Energy, Feb. 1980.

APPENDIX A

INPUT PARAMETERS: Run No. 4, 3 March 1980

APPENDIX A COMMON BLK1

A-2

INPUT PARAMETERS: Run No. 4, 3 MAR '80

#	MEMORIC	ITEM	UNITS	BASLINE DATA
1	DCPWR	NOMINAL D.C. BUS POWER	W	80000.0
2	PTAMB	PLANT AMBIENT TEMPERATURE	°C	25.0
3	PTMOD	PLANT WORKING TEMPERATURE (MODULE)	°C	60.0
4	PLIFE	PLANT BOOK LIFE	Yr	20.0
5	CAR	CELL ACTIVE GROSS AREA	M ²	0.067
6	CCD	CELL GROSS CURRENT DENSITY	A/M ²	6000.0
7	CTHK	CELL THICKNESS	M	8.62 E-3
8	ELON	} POLARIZATION PARAMETERS AT TLOW	V	1.287
9	SLOW		V/DECADE	0.191
10	RLOW		Ω	4.26 E-5
11	TLOW	EXPT. TEMPERATURE FOR #8, #9, #10	°C	50.4
12	EMED	} POLARIZATION PARAMETERS AT TMED	V	1.068
13	SMED		V/DECADE	0.233
14	RMED		Ω	3.00 E-5
15	TMED	EXPT. TEMPERATURE FOR #12, #13, #14	°C	76.0
16	ETHH	} POLARIZATION PARAMETERS AT THIGH	V	1.039
17	SHIGH		V/DECADE	0.179
18	RHIGH		Ω	3.00 E-5
19	THIGH	EXPT. TEMPERATURE FOR #16, #17, #18	°C	121.0
20	CCOMP	CELL COMPRESSION	Pa	2.413 E6
21	ELCON	ELECTROLYTE AVERAGE CONC. (MASS FRACTION)	—	0.25
22	ELDELC	CONC. CATHOLYTE - CONC. ANOLYTE	—	0.08
23	AMPRES	MODULE PRESSURE	Pa (gauge)	8.619 E5
24	AMDELP	PRESS. H ₂ - PRESS. O ₂	Pa	0.0
25	AMDELT	TEMP. MODULE OUTLET - TEMP. MODULE INLET	°C	8.33

APPENDIX A
COMMON BLK1
INPUT PARAMETERS

A-3

#	MEMORIC	ITEM	UNITS	BASLINE DATA
26	PCNTRL	CONTROL SYSTEMS POWER	W	500.0
27	—	—	—	—
28	—	—	—	—
29	—	—	—	—
30	—	—	—	—
31	AMSTY	MODULE STYLE FLAG	—	1.0
32	EPSTY	ENDPLATE STYLE FLAG	—	1.0
33	AMXCEL	MAXIMUM CELLS PER MODULE	—	150.0
34	AMASP	ASPECT RATIO (HORIZONTAL/VERTICAL)	—	1.0
35	EPDEF	ALLOWABLE ENDPLATE DEFLECTION	M	7.62E-5
36	EPMOD	ENDPLATE ELASTIC MODULUS @ 25°C	Pa	200.E9
37	EPMODT	TEMPERATURE COEFFICIENT FOR # 36	Pa/C	0.0
38	EPRAO	ENDPLATE DENSITY	Kg/m ³	7950
39	EPNU	ENDPLATE POISSON'S RATIO	—	0.3
40	—	—	—	—
41	—	—	—	—
42	SLTHK	SEAL THICKNESS (PER CELL)	M	5.E-4
43	SLLD	SEALING LOAD @ 25°C	Pa	10.34E6
44	SLLDT	TEMPERATURE COEFFICIENT FOR # 43	Pa/C	0.0
45	SLMDIS	MINIMUM SEAL DISTANCE BETWEEN MANIFOLDS	M	0.05
46	—	—	—	—
47	—	—	—	—
48	—	—	—	—
49	TRNO	NUMBER OF TIE RODS	—	8.0
50	TRMOD	TIE ROD MODULUS OF ELASTICITY @ 25°C	Pa	200.E9

APPENDIX A
COMMON BLK1
INPUT PARAMETERS

A-4

#	MEMORIC	ITEM	UNITS	BASLINE DATA
51	TRMODT	TEMPERATURE COEFFICIENT FOR #50	$\text{Pa}/^\circ\text{C}$	0.0
52	TRCTE	TIEROD COEFFICIENT OF THERMAL ELASTION	$^\circ\text{C}^{-1}$	$1.85 \text{E}-5$
53	TRYLD	TIEROD YIELD TENSILE STRENGTH @25°C	Pa	$1.138 \text{E}9$
54	TRYLDT	TEMPERATURE COEFFICIENT FOR #53	$\text{Pa}/^\circ\text{C}$	0.0
55	TRSF	TIEROD SAFETY FACTOR	—	0.33
56	TRRHO	TIEROD DENSITY	Kg/M^3	7950.0
57	TRNU	TIEROD POISSON'S RATIO	—	0.3
58	—	—	—	—
59	CFRHO	CELL FRAME PLASTIC DENSITY	Kg/M^3	$1.24 \text{E}3$
60	CFMTS	CELL FRAME MAXIMUM TENSILE STR. @25°C	Pa	$16.8 \text{E}6$
61	CFMTST	TEMPERATURE COEFFICIENT FOR #61	$\text{Pa}/^\circ\text{C}$	$-1.02 \text{E}5$
62	CFMAN	MINIMUM ANNULAR WIDTH	M	0.03
63	—	—	—	—
64	AINMAN	NUMBER OF INLET MANIFOLDS	—	1.0
65	OUTMAN	NUMBER OF OUTLET MANIFOLDS	—	1.0
66	AINDIAM	INLET MANIFOLD DIAMETER	M	0.04
67	OUTDIAM	OUTLET MANIFOLD DIAMETER	M	0.04
68	AINPL	INLET PORT LENGTH	M	0.04
69	OUTPL	OUTLET PORT LENGTH	M	0.04
70	AINPDR	INLET PORT DIAMETER TO CELL THICKNESS RATIO	—	0.233
71	OUTPDR	OUTLET PORT DIAMETER TO CELL THICKNESS RATIO	—	0.233
72	AINEL	INLET ENTRANCE LENGTH	M	0.2
73	OUTEL	OUTLET ENTRANCE LENGTH	M	0.2
74	—	—	—	—
75	—	—	—	—

APPENDIX A
COMMON BLK1
INPUT PARAMETERS

A-5

#	MNEMONIC	ITEM	UNITS	BASELINE DATA
76	—	—	—	—
77	—	—	—	—
78	—	—	—	—
79	—	—	—	—
80	SCFMNR	SINGLE CELL FLOW MINIMUM TO AVERAGE RATIO	—	0.6
81	SCFMX2	SINGLE CELL FLOW MAXIMUM TO AVERAGE RATIO	—	1.4
82	SCFX	SINGLE CELL FLOW CURVE EXPONENT	—	1.536
83	SCFC	SINGLE CELL FLOW CURVE COEFFICIENT	—	6.72E-8
84	THTA1	MOMENTUM COEFFICIENT #1	—	1.05
85	THTA2	MOMENTUM COEFFICIENT #2	—	1.6
86	EPIX	END PLATE INLET FLOW CURVE EXPONENT	—	1.832
87	EPIC	END PLATE INLET FLOW CURVE COEFFICIENT	—	14.35E-6
88	EPOX	END PLATE OUTLET FLOW CURVE EXPONENT	—	1.832
89	EPOC	END PLATE OUTLET FLOW CURVE COEFFICIENT	—	14.35E-6
90	AFF	ANALYTE FLOW TO TOTAL FLOW RATIO	—	0.5
91	ETD	END PLATE EFFECTIVE TUBE DIAMETER	M	0.4
92	—	—	—	—
93	—	—	—	—
94	—	—	—	—
95	—	—	—	—
96	—	—	—	—
97	CWT	COOLING WATER TEMPERATURE	°C	35.0
98	CWMF	COOLING WATER MAXIMUM FLOW LIMIT	kg/s	1.89
99	FWT	FEED WATER TEMPERATURE	°C	25.0
100	DPDL	PRESSURE DROP PER UNIT LENGTH	Pa/m	2.26E3

APPENDIX A COMMON BLK1 INPUT PARAMETERS

A-6

#	MECHONIC	ITEM	UNITS	BASELINE DATA
101	PLMIN	MINIMUM LENGTH OF ELECTROLYTE TUBING	M	2.0
102	PLK	TUBE LENGTH TO PLANT SIZE COEFFICIENT	M/W ^{1/3}	0.18
103	FPDPPD	FILTER TO TUBING PRESSURE DROP RATIO	—	1.6
104	FSRC	FLOW SWITCH RESISTANCE COEFFICIENT	—	20.0
105	HXPDPD	HEAT EXCHANGER TO TUBING PRESSURE DROP RATIO	—	0.4
106	ETAPMOT	ELECTROLYTE PUMP MOTOR EFFICIENCY	—	0.8
107	PKTH	TUBING THERMAL CONDUCTIVITY	W/MC	15.0
108	ELFH	ELECTROLYTE FILTER HEIGHT	M	0.4
109	ELFD	ELECTROLYTE FILTER DIAMETER	M	0.165
110	RESH	ELECTROLYTE RESERVOIR HEIGHT	M	1.22
111	RES D	ELECTROLYTE RESERVOIR DIAMETER	M	0.19
112	ELPWT	ELECTROLYTE TUBE WALL THICKNESS	M	7.016E-3
113	ETAPVM	ELECTROLYTE PUMP VOLUMETRIC & MECHANICAL η	—	0.8
114	TLOO	OXYGEN CONDENSER GAS OUTLET TEMPERATURE	C	50.0
115	TLOH	HYDROGEN CONDENSER GAS OUTLET TEMPERATURE	C	41.0
116	DTOO	OXYGEN CONDENSER WATER TEMP. RISE	C	8.5
117	DTOH	HYDROGEN CONDENSER WATER TEMP. RISE	C	8.5
118	—	—	—	—
119	OCH EF	OXYGEN CONDENSER EFFECTIVE H	W/MC	57.0
120	HCH EF	HYDROGEN CONDENSER EFFECTIVE H	W/MC	114.0
121	EIAWP	WATER PUMP SHAFT & FLUID EFFICIENCY	—	0.6
122	ETAWPM	WATER PUMP MOTOR EFFICIENCY	—	0.8
123	—	—	—	—
124	—	—	—	—
125	EPKTH	END PLATE THERMAL CONDUCTIVITY	W/MC	15.0

APPENDIX A
COMMON BLK1
INPUT PARAMETERS

A-7

#	MECHANIC	ITEM	UNITS	BASELINE DATA
126	AMINST	MODULE INSULATION THICKNESS	M	0.0
127	AMINSK	MODULE INSULATION THERMAL CONDUCTIVITY	W/MC	0.01
128	CEKTH	CELL FRAME THERMAL CONDUCTIVITY	W/MC	0.26
129	RESHEF	RESERVOIR EFFECTIVE H	W/M ² C	4000.0
130	RESINST	RESERVOIR INSULATION THICKNESS	M	0.0
131	RESINSK	RESERVOIR INSULATION THERMAL COND.	W/MC	0.01
132	UHX A	ANOLYTE HEAT EXCHANGER U.	W/M ² C	568.0
133	UHX C	CATHOLYTE HEAT EXCHANGER U.	W/M ² C	568.0
134	VOIDFR	CELL VOID FRACTION	—	0.5
135	—	—	—	—
136	—	—	—	—
137	HIDMR	O ₂ IN H ₂ MASS RATIO	—	0.002
138	OIMANCL	EFFECTIVE MANIFOLD CELLS	—	2.0
139	OPUR	REQ'D OXYGEN PURITY	—	0.98
140	HPUR	REQ'D HYDROGEN PURITY	—	0.9995
141	DONO	NUMBER OF OXYGEN DRYERS	—	2.0
142	DHNO	NUMBER OF HYDROGEN DRYERS	—	2.0
143	DOCYC	OXYGEN DRYER CYCLE TIME	sec	14400.0
144	DHCYC	HYDROGEN DRYER CYCLE TIME	sec	14400.0
145	DSMWR	WATER TO DRYER SEIVE MASS RATIO	—	0.15
146	DSVOID	DRYER SEIVE VOID VOLUME	—	0.15
147	DSCP	DRYER SEIVE HEAT CAPACITY	Joule/KgC	1046.0
148	DTCHG	RECHARGE TEMPERATURE	C	300.0
149	DSDEN	DRYER SEIVE DENSITY	Kg/M ³	714.0
150	DLDR	DRYER LENGTH TO DIAMETER RATIO	—	5.0

APPENDIX A
COMMON BLK1
INPUT PARAMETERS

A-B

#	MEMONIC	ITEM	UNITS	BASLINE DATA
151	DWTHK	DRYER WALL THICKNESS	M	3.4E-3
152	DWDENS	DRYER WALL DENSITY	Kg/M ³	7950.0
153	DWCP	DRYER WALL HEAT CAPACITY	J/KgC	500.0
154	PHS	HYDROGEN STORAGE PRESSURE	Pa	0.0
155	POS	OXYGEN STORAGE PRESSURE	Pa	0.0
156	ETACOMP	COMPRESSOR EFFICIENCY	—	0.5
157	RATCOMP	MAXIMUM COMPRESSION RATIO	—	7.0
158	OMASR	REQ'D OXYGEN MASS STORAGE	Kg	0.0
159	HMASR	REQ'D HYDROGEN MASS STORAGE	Kg	0.0
160	DRPURG	DRYER PURGE FACTOR	—	0.2
161	CSR	COMMON STOCK EQUITY RATIO	—	0.30
162	RCR	RESERVE CAPITAL EQUITY RATIO	—	0.40
163	CSCOS	COMMON STOCK COST	—	0.08
164	RCCOS	RESERVE CAPITAL COST	—	0.15
165	DCOS	DEBT COST	—	0.10
166	AINF	INFLATION RATE	—	0.10
167	PCOS	POWER COST	\$/kWh	0.025
168	PCER	POWER COST ESCALATION RATE	—	0.00
169	DUFAC	DUTY FACTOR	—	0.85
170	TXR	INCOME TAX RATE	—	0.46
171	TLR	TAX LIFE RATIO	—	0.667
172	TXCR	INVESTMENT TAX CREDIT RATE	—	0.00
173	PTXIR	PROPERTY TAX AND INSURANCE RATE	—	0.02
174	ACCTFLG	ACCOUNTING FLAG	—	1.0
175	CRVRZ	CELL RETURN VALUE RATIO (450)	—	0.75

APPENDIX A COMMON BLK1 INPUT PARAMETERS

A-9

#	MNEMONIC	ITEM	UNITS	BASELINE DATA
176	ZRVY	ZERO RETURN VALUE YEAR	YR	10
177	PSV	PLANT SCRAP VALUE	\$	0.0
178	CWSPCOS	COOLING WATER SPECIFIC COST	\$/kg	0.582E-4
179	FWSPCOS	FEED WATER SPECIFIC COST	\$/kg	1.321E-3
180	AMNTRT	MAINTENANCE RATE	YR ⁻¹	2.0
181	P6SVCOS	PURGE GAS COST	\$/m ³	0.53
182	ALBERT	LABOR RATE	\$/YR	14000
183	OHEATE	OVERHEAD RATE	—	1.00
184	GARATE	GENERAL & ADMINISTRATIVE RATE	—	0.00
185	CASPCOS	CAUSTIC POTASH (45%) SPECIFIC COST	\$/kg	0.48
186	OPERTAU	OPERATING PERIOD	DAYS	14.0
187	AINVEN	INVENTORY FACTOR	—	0.01
188	DNEK	DESIGN & ENGINEERING COST	\$/W ^{1/4}	2.4E4
189	DNEFACT	D & E AMORTIZATION (# of SYSTEMS)	—	100.0
190	GMARGC	GROSS MARGIN ON COMPONENTS	—	0.75
191	AINSTK	INSTALLATION & STARTUP CONSTANT	\$/W ^{1/4}	200.0
192	GMARG I	GROSS MARGIN ON INSTAL. & STARTUP	—	0.75
193	BLDG K	BUILDING CONSTANT	\$/m ²	25.0
194	FACIL K	FACILITIES CONSTANT	\$/W ^{1/4}	1000.0
195	GMARGBF	GROSS MARGIN ON BLDG. & FACILITIES	—	0.0
196	PLASCST	CELL FRAME PLASTIC COST	\$/kg	8.422
197	CELDMLD	CELL FRAME YIELD PER MOLD SET	—	2.0E5
198	AMOPCOS	MOLD OPERATING COST PER OPERATION	\$	3.0
199	FRPCEL	FRAMES PER CELL	—	2.0
200	SLPCEL	SECS PER CELL	—	2.0

APPENDIX A
COMMON BLK1
INPUT PARAMETERS

A-10

#	MEMORIC	ITEM	UNITS	BASELINE DATA
201	SLMCOS	SEAL MATERIAL COST	\$/m ²	11.50
202	SLPCOS	SEAL PROCESSING COST	\$	0.60
203	ANSCOS	ANODE STOCK COST	\$/m ²	69.60
204	ANCCOS	ANODE CATALYST COST	\$/m ²	0.00
205	ANPRCOS	ANODE PROCESSING COST	\$	0.25
206	CASCOS	CATHODE STOCK COST	\$/m ²	69.60
207	CACOS	CATHODE CATALYST COST	\$/m ²	0.00
208	CAPRCOS	CATHODE PROCESSING COST	\$	0.25
209	SEPCOS	SEPARATOR STOCK COST	\$/m ²	5.00
210	SEPPCOS	SEPARATOR PROCESSING COST	\$	0.70
211	BP THK	BIPOLAR THICKNESS	M	4.572 E-4
212	BP DENS	BIPOLAR DENSITY	Kg/m ³	8900.0
213	BPMSCOS	BIPOLAR MATERIAL SPECIFIC COST	\$/Kg	13.23
214	BPPCOS	BIPOLAR PROCESSING COST	\$	3.50
215	FM THK	FLOW MEMBER THICKNESS	M	1.60 E-3
216	FMSPCOS	FLOW MEMBER MATERIAL SPECIFIC COST	\$/m ³	1.66 E+4
217	FMPCOS	FLOW MEMBER PROCESSING COST	\$	0.40
218	EP MSCOS	ENDPLATE MATERIAL SPECIFIC COST	\$/Kg	6.93
219	EP MFGCS	ENDPLATE MANUFACTURING COST	\$/SET	650.0
220	TRMCOS	TIE ROD MATERIAL COST	\$/Kg	6.24
221	TRPCOS	TIE ROD PROCESSING COST	\$	1.10
222	TRHCOS	TIE ROD HARDWARE COST (DIAMETER)	\$/M	900.0
223	—	—	—	—
224	AMLFL	MODULE LIFE AT TMLLOW	Yr	10.
225	TMLLOW	TEMPERATURE FOR #224	C	50.

APPENDIX A COMMON BLK1 INPUT PARAMETERS

A-11

#	MMEMONIC	ITEM	UNITS	BASELINE DATA
226	AMLFH	MODULE LIFE AT THIGH	Yr	5.
227	TMLHIGH	TEMPERATURE FOR # 226	C	125.
228	AMCF	ANOLYTE MATERIAL COST FACTOR	—	1.
229	CMCF	CATHOLYE MATERIAL COST FACTOR	—	1.
230	DMCF	OXYGEN MATERIAL COST FACTOR	—	1.
231	HMCF	HYDROGEN MATERIAL COST FACTOR	—	1.
232	ELPBK1	FLUID PLUMBING PRICE COEFFICIENT	\$/M ³	4.764E5
233	ELPBK2	FLUID PLUMBING EXPONENT	—	0.5
234	GSPBK1	GAS PLUMBING PRICE COEFFICIENT	\$/W	5.3
235	GSPBK2	GAS PLUMBING EXPONENT	—	0.33
236	FILK1	FILTER PRICE COEFFICIENT	\$/ (M ³ /SEC)	1.739E5
237	FILK2	FILTER EXPONENT	—	1.0
238	HXK1	HEAT EXCHANGER PRICE COEFFICIENT	\$/M ²	5.767E2
239	HXK2	HEAT EXCHANGER EXPONENT	—	0.8
240	PUMPK1	PUMP PRICE COEFFICIENT	\$/LOS (PWR)	384.8
241	PUMPK2	PUMP EXPONENT	—	1.0
242	RESK1	RESERVOIR PRICE COEFFICIENT	\$/M ³	4312.
243	RESK2	RESERVOIR EXPONENT	—	0.5
244	RESK3	RESERVOIR MINIMUM PRICE	\$	250.0
245	CONK1	CONDENSER AREA PRICE COEFFICIENT	\$/M ²	5956.0
246	CONK2	CONDENSER MASS FLOW PRICE COEFFICIENT	\$/ (KG/SEC)	3.63E5
247	CONK3	CONDENSER EXPONENT	—	0.8
248	AINSK1	INSULATION PRICE COEFFICIENT	\$/M ³	93.0
249	CWPK1	COOLING WATER PLUMBING COST	#	220.0
250	FWPK1	FEED WATER PLUMBING COST	#	200.0

A-12

[illegible]

APPENDIX B

OUTPUT PARAMETERS: Run No. 4, 3 March 1980

APPENDIX B
COMMON BLK2

B-2

OUTPUT PARAMETERS: RUN No. 4, 3 Mar '80

#	NEURONIC	ITEM	UNITS	BASLINE RESULTS
1	ALVGPRX	LEVELIZED GAS PRICE	\$/Kg	6.995
2	ACPNR	A.C. BUS POWER	W	8.517 E+4
3	ETATOT	OVERALL EFFICIENCY	—	0.5928
4	CVOLT	CELL VOLTAGE	V	2.713
5	BEV	BUS BAR VOLTAGE	V	199.2
6	BBI	BUS BAR CURRENT	A	402.0
7	CAPPRX	CAPITAL PRICE	\$	8.701 E+4
8	APCOS	ANNUAL POWER COST	\$	1.586 E4
9	AD COS	ANNUAL OPERATING COST	\$	6541.0
10	GASOUT	ANNUAL GAS OUTPUT	Kg	9554.0
11	PLTCOS	COMPONENTS COST (NO MODULE)	\$	1.791 E4
12	AMLF	MODULE LIFE	yr	8.954
13	THODCOS	MODULE COSTS (TOTAL OVER LIFE)	\$	1.609 E4
14	SYSAREA	SYSTEM FLOOR AREA	M ²	.9945
15	TOTCEL	NO. OF CELLS PER SYSTEM	—	90.0
16	SPGPRX	1ST YEAR GAS PRICE	\$/Kg	4.03
17	RDISC	DISCOUNT RATE	—	0.1140
18	DEBTRAT	PORTION OF CAPITAL FINANCED BY DEBT	—	0.30
19	WCC	WORKING CAPITAL COST	—	0.1140
20	CRFB	CAPITAL RECOVERY FACTOR (BOOK)	—	0.1789
21	ALATC	LEVELIZED ANNUAL TOTAL COST	\$	6.68 E+4
22	ALAPC	LEVELIZED ANNUAL POWER COST	\$	3.588 E+4
23	ALAPC	LEVELIZED ANNUAL OPERATING COST	\$	1.480 E+4
24	ALACC	LEVELIZED ANNUAL CAPITAL & TAX COST	\$	1.615 E+4
25	ALAFOR	LEVELIZED ANNUAL FIXED CHARGE RATE	—	.1856

APPENDIX B
COMMON BLK2
OUTPUT PARAMETERS

B-3

#	MNEEMONIC	ITEM	UNITS	BASLINE RESULTS
26	BLDGFC	BUILDING & FACILITIES COST	\$	1.711E4
27	AINSTL	INSTALLATION & STARTUP COST	\$	3417.0
28	COMPPOS	COMPONENTS COST	\$	3.419E4
29	WIDUT	GAS OUTPUT, HIGHER HEATING VALUE	W	5.05E+4
30	EFFI	EFFECTIVE AMP-CELLS	A	3.455E+4
31	CELLUR	CELL CURRENT	A	402.0
32	PMOD	MODULES PER PLANT	—	1.0
33	AMCEL	CELLS PER MODULE	—	90.0
34	ETAV	VOLTAGE EFFICIENCY	—	0.669
35	ETAI	CURRENT EFFICIENCY	—	0.9549
36	ETAR	RECTIFIER EFFICIENCY	—	0.9500
37	ETAP	PURIFICATION EFFICIENCY	—	0.9866
38	PPWR	ACTUAL D.C. POWER	W	8.008E+4
39	ETAM	MODULE EFFICIENCY	—	0.6391
40	VTH	ISOTHERMAL CELL VOLTAGE	V	1.481
41	AMODQ	MODULE HEAT LOAD	W	2.890E+4
42	AMLEN	MODULE LENGTH	M	0.971
43	CFMAS	CELL FRAME MASS	Kg	1.345
44	CFVOD	CELL FRAME VERTICAL O.D.	M	0.512
45	CFHOD	CELL FRAME HORIZONTAL O.D.	M	0.512
46	CFAN	CELL FRAME ANNULAR WIDTH	M	0.110
47	CF SAR	CELL FRAME SEAL AREA	M ²	0.1336
48	TRLEN	TIE ROD LENGTH	M	1.145
49	TRDIAM	TIE ROD DIAMETER	M	2.17E-2
50	TRMAS	TIE ROD MASS (PER ROD)	Kg	26.96

APPENDIX B
COMMON BLK2
OUTPUT PARAMETERS

B-4

#	MEMORIC	ITEM	UNITS	BASLINE RESULTS
51	EPTAK	END PLATE THICKNESS	M	9.261E-2
52	EPAR	END PLATE AREA	M ²	0.2617
53	EPVOL	END PLATE VOLUME	M ³	2.554E-2
54	EPMAS	END PLATE MASS	Kg	203.1
55	AMMFL	MODULE MASS FLOW RATE	Kg/SEC	1.119
56	AMVFL	MODULE VOLUMETRIC FLOW RATE	M ³ /SEC	9.240E-4
57	VELIN	INLET MANIFOLD VELOCITY	M/SEC	0.3676
58	VELOUT	OUTLET MANIFOLD VELOCITY	M/SEC	0.3676
59	PDSTK	STACK PRESSURE DROP	Pa	703.0
60	PDMOD	MODULE PRESSURE DROP	Pa	1860.0
61	CFMAX	MAXIMUM SINGLE CELL FLOW	M ³ /SEC	5.133E-6
62	CFMIN	MINIMUM SINGLE CELL FLOW	M ³ /SEC	4.796E-6
63	SEPCOS	SEPARATOR COST PER CELL	\$/CELL	1.169
64	BPCOS	BIPOLAR COST PER CELL	\$/CELL	8.550
65	FMCOS	FLOW MEMBERS COST PER CELL	\$/CELL	5.783
66	OMODCOS	ORIGINAL SINGLE MODULE COST	\$	1.026E+4
67	PIDA	ANOLYTE TUBING I.D.	M	2.0E-2
68	PIDC	CATHOLYTE TUBING I.D.	M	2.0E-2
69	PODA	ANOLYTE TUBING O.D.	M	2.10E-2
70	PODC	CATHOLYTE TUBING O.D.	M	2.10E-2
71	PHDA	ANOLYTE PUMP HEAD	Pa	4.025E+4
72	PHDC	CATHOLYTE PUMP HEAD	Pa	4.853E+4
73	PIPA	ANOLYTE PUMP INPUT POWER	W	100.0
74	PIPC	CATHOLYTE PUMP INPUT POWER	W	100.0
75	QOCON	OXYGEN CONDENSER HEAT LOAD	W	64.89

APPENDIX B
COMMON BLK2
OUTPUT PARAMETERS

B-5

#	MLEMORIC	ITEM	UNITS	BASCLINE RESULTS
76	QHCON	HYDROGEN CONDENSER HEATLOAD	W	172.5
77	OMFL	OXYGEN MASS FLOW RATE TO DRYER	Kg/sec	2.864 E-3
78	HMFL	HYDROGEN MASS FLOW RATE TO DRYER	Kg/sec	3.609 E-4
79	WMFLO3	WATER MASS FLOW TO O ₂ DRYER	Kg/sec	1.922 E-5
80	WMFLH3	WATER MASS FLOW TO H ₂ DRYER	Kg/sec	2.389 E-5
81	FWMFL	FEED WATER MASS FLOW RATE	Kg/sec	3.268 E-3
82	PSPA	ANOLYTE PUMP SHAFT POWER	W	44.62
83	PSPC	CATHOLYTE PUMP SHAFT POWER	W	50.53
84	CWFLOC	OXYGEN CONDENSER COOLING WATER FLOW	Kg/sec	1.823 E-3
85	CWFLHC	HYDROGEN CONDENSER COOLING WATER FLOW	Kg/sec	4.847 E-3
86	OCAR	OXYGEN CONDENSER AREA	M ²	6.438 E-2
87	HCAR	HYDROGEN CONDENSER AREA	M ²	12.76 E-2
88	CWMFL	TOTAL COOLING WATER MASS FLOW	Kg/sec	0.8354
89	FWPP	FEED WATER PUMP POWER	W	100.0
90	OMODCV	MODULE CONVECTIVE HEAT LOSS	W	74.20
91	PLENA	LENGTH OF ANOLYTE TUBING	M	4.863
92	PLENC	LENGTH OF CATHOLYTE TUBING	M	4.863
93	NMFLO2	WATER MASS FLOW, O ₂ CONDENSER RETURN	Kg/sec	1.111 E-5
94	WMFLH2	WATER MASS FLOW, H ₂ CONDENSER RETURN	Kg/sec	2.095 E-5
95	WMFLO1	WATER MASS FLOW INTO O ₂ CONDENSER	Kg/sec	3.0328 E-5
96	WMFLH1	WATER MASS FLOW INTO H ₂ CONDENSER	Kg/sec	4.484 E-5
97	STKLEN	MODULE STACK LENGTH	M	0.7753
98	QRESCV	RESERVOIR CONVECTIVE HEAT LOSS	W	219.4
99	QPIPECV	PIPING CONVECTIVE HEAT LOSS	W	189.5
100	AHXAR	ANOLYTE HEAT EXCHANGER AREA	M ²	1.183

APPENDIX B
COMMON BLK2
OUTPUT PARAMETERS

B-6

#	MNEMONIC	ITEM	UNITS	BASELINE RESULTS
101	CHXAR	CATHOLYTE HEAT EXCHANGER AREA	M ²	1.196
102	CWFLAHX	COOLING WATER FLOW, ANOLYTE H.X.	Kg/sec	0.426
103	CWFLCHX	COOLING WATER FLOW, CATHOLYTE H.X.	Kg/sec	0.403
104	QAHX	ANOLYTE H.X. HEAT LOAD	W	1.414E4
105	QCHX	CATHOLYTE H.X. HEAT LOAD	W	1.414E4
106	DTC AHX	COOLING WATER ΔT, ANOLYTE H.X.	°C	7.932
107	DTC CHX	COOLING WATER ΔT, CATHOLYTE H.X.	°C	8.380
108	AVOL	ONBOARD ANOLYTE VOLUME	M ³	4.0371E-2
109	CVOL	ONBOARD CATHOLYTE VOLUME	M ³	4.0371E-2
110	PNAT	ONBOARD WATER MASS (100% H ₂ O)	Kg	73.21
111	PKOH	ONBOARD KOH MASS (100% KOH)	Kg	24.57
112	PMFL	PLANT ELECTROLYTE MASS FLOW	Kg/sec	1.115
113	PAMFL	ANOLYTE MASS FLOW	Kg/sec	0.5576
114	PCMFL	CATHOLYTE MASS FLOW	Kg/sec	0.5576
115	PAVFL	ANOLYTE VOLUME FLOW	M ³ /sec	4.754E-4
116	PCVFL	CATHOLYTE VOLUME FLOW	M ³ /sec	4.465E-4
117	GVOL	GAS VOLUME	M ³	3.885E-2
118	RHODCOS	REPLACEMENT MODULE COST	\$	5836.0
119	—	—	—	—
120	OMFLH	OXYGEN MASS FLOW IN H ₂	Kg/sec	7.219E-7
121	HMFLD	HYDROGEN MASS FLOW IN O ₂	Kg/sec	3.408E-5
122	OMFOUT	OXYGEN MASS FLOW TO COMPRESSOR	Kg/sec	2.574E-3
123	HMFOU	HYDROGEN MASS FLOW TO COMPRESSOR	Kg/sec	3.561E-4
124	WMFLO5	WATER MASS FLOW TO O ₂ COMPRESSOR	Kg/sec	5.188E-5
125	WMFLH5	WATER MASS FLOW TO H ₂ COMPRESSOR	Kg/sec	1.804E-7

APPENDIX B
COMMON BLK2
OUTPUT PARAMETERS

B-7

#	MMEMONIC	ITEM	UNITS	BASLINE RESULTS
126	WMFLO4	WATER MASS FLOW, O ₂ DRYER VENT	Kg/DWL	0.0
127	WMFLH4	WATER MASS FLOW, H ₂ DRYER VENT	Kg/DWL	2.371 E-5
128	DSMO	OXYGEN DRYER SEIVE MASS	Kg	0.0
129	DSMH	HYDROGEN DRYER SEIVE MASS	Kg	1.138
130	DDO	OXYGEN DRYER DIAMETER	M	0.0
131	DDH	HYDROGEN DRYER DIAMETER	M	5.0 E-2
132	DLO	OXYGEN DRYER LENGTH	M	0.0
133	DLH	HYDROGEN DRYER LENGTH	M	.4059
134	DPO	OXYGEN DRYER POWER	W	0.0
135	DPH	HYDROGEN DRYER POWER	W	38.82
136	DPN	NET DRYER POWER	W	77.64
137	AUXPWR	TOTAL AUXILIARY SYSTEMS POWER	W	877.6
138	OC PWR	OXYGEN COMPRESSOR POWER	W	0.0
139	HC PWR	HYDROGEN COMPRESSOR POWER	W	0.0
140	OCOMPS	OXYGEN COMPRESSOR STAGES	-	0.0
141	HCOMPS	HYDROGEN COMPRESSOR STAGES	-	0.0
142	OSTOR	OXYGEN STORAGE VOLUME	M ³	0.0
143	HSTOR	HYDROGEN STORAGE VOLUME	M ³	0.0
144	EMPTY	-	-	-
145	EMPTY	-	-	-
146	PCLF	POWER COST LEVELIZING FACTOR	-	2.263
147	GINLF	INFLATION LEVELIZING FACTOR	-	2.263
148	SLDEPR	STRAIGHT LINE DEPRECIATION	-	5.0 E-2
149	ATDEPR	ACCELERATED TAX DEPRECIATION	-	7.93 E-2
150	PLFT	PLANT LIFE FOR TAX PURPOSES	Yr	13.0

APPENDIX B
COMMON BLK2
OUTPUT PARAMETERS

B-8

#	MNEMONIC	ITEM	UNITS	BASLINE RESULTS
151	CRFT	CAPITAL RECOVERY FACTOR (TAX)	—	0.1511
152	ALANDA	LEVELIZED ACCEL. DEPR. TAX ALLOWANCE	—	2.496 E-2
153	ALAIT	LEVELIZED INCOME TAX	—	5.422 E-2
154	ALAITCA	LEVELIZED INVESTMENT TAX CREDIT	—	0.0
155	RDA	RETIREMENT DISPERSION ALLOWANCE	—	7.5 E-3
156	ACWCOST	ANNUAL COOLING WATER COST	\$	1304.0
157	AFWCOST	ANNUAL FEED WATER COST	\$	115.8
158	AMATCOS	ANNUAL MATERIALS COST	\$	1593.0
159	ALBRCOS	ANNUAL LABOR COST	\$	2524.0
160	AGACOST	ANNUAL G & A COST	\$	0.0
161	ADHCOST	ANNUAL OUT-HEAD COST	\$	2524.0
162	ANCOST	ANODE COST	\$	6.778
163	CACOST	CATHODE COST	\$	6.778
164	CELCOST	TOTAL CELL COST	\$	53.95
165	EPCOST	ENDPLATE COST (PAIR)	\$/MODULE	2984
166	TRCOST	TIE ROD COST - TOTAL ASSY	\$/TIEROD	118.8
167	MOLDCOS	MOLD COST	\$	6.625 E+4
168	CFCOST	CELL FRAME COST	\$/CELL	17.66
169	SLCOST	SEAL COST	\$/CELL	7.23
170	ASSYCOS	MODULE ASSY COST	\$/MODULE	907.5
171	ANPBCOS	ANOLYTE PLUMBING COST	\$	464.0
172	CAPBCOS	CATHOLYTE PLUMBING COST	\$	464.0
173	OXPBCOS	OXYGEN PLUMBING COST	\$	219.9
174	HYPBCOS	HYDROGEN PLUMBING COST	\$	219.9
175	ANFLCOS	ANOLYTE FILTER COST	\$	82.67

APPENDIX B
COMMON BLK2
OUTPUT PARAMETERS

B-9

#	MNEMONIC	ITEM	UNITS	BASELINE RESULTS
176	CAFLCOS	CATHOLYTE FILTER COST	\$	77.64
177	ANHXCOS	ANOLYTE H.X. COST	\$	659.9
178	CAHXCOS	CATHOLYTE H.X. COST	\$	665.5
179	ANPM COS	ANOLYTE Pump Cost	\$	769.6
180	CAPM COS	CATHOLYTE Pump Cost	\$	769.6
181	ANRSCOS	ANOLYTE RESERVOIR COST	\$	904.9
182	CARSCOS	CATHOLYTE RESERVOIR COST	\$	904.9
183	PURGCOS	PURGE SYSTEM COST	\$	130.0
184	OXCNCOS	OXYGEN CONDENSER COST	\$	314.6
185	HYCNCOS	HYDROGEN CONDENSER COST	\$	228.7
186	OXDR COS	OXYGEN DRYER COST	\$	0.0
187	HYDR COS	HYDROGEN DRYER COST	\$	1736.0
188	AINSCOS	INSULATION COST	\$	0.0
189	CWPBCOS	COOLING WATER PLUMBING COST	\$	220.0
190	FWPBCOS	FEED WATER PLUMBING COST	\$	200.0
191	VENTCOS	VENT SYSTEM COST	\$	210.8
192	STRTCOS	STRUCTURAL COST	\$	1732.0
193	OXCMCOS	OXYGEN COMPRESSOR COST	\$	0.0
194	HYCMCOS	HYDROGEN COMPRESSOR COST	\$	0.0
195	OXBOTCOS	OXYGEN BOTTLE COST	\$	0.0
196	HYBOTCOS	HYDROGEN BOTTLE COST	\$	0.0
197	PSCOS	POWER SUPPLY COST	\$	2685.0
198	UNASCOS	UNASSIGNED COSTS	\$	853.0
199	CNIN COS	CONTROL & INSTRUMENTATION COST	\$	3400.0
200	DNE COS	PLANT DESIGN & ENGINEERING COST (TOTAL)	\$	410 E75

B-10

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

APPENDIX C

DATA DECK STRUCTURE

TITLE

MAWES INPUT DECK FORMAT

ANALYST

M. Gaff

1

1

JOB NO.

DATE _____

3/19/80

SHEET

OF

OF _____

[illegible]

SAMPLE DECK

NOTES

1. X = Alphanumeric
D = Digit
2. I.0 flag (card 2) allows for extended output
If last digit = 1 then extended output for all cases
If last digit = 0 then extended output for optimum case
If 4th digit = 0 then compact output format
If 4th digit = 1 then open output format
3. # of parameters (card 4) should correspond to number of parameter cards (cards 5-8)
4. # of active loops (card 10) should correspond to number of loop cards \div 2 (cards 11-16)
5. In parameter cards (card 5), 1st digit field is parameter #, alpha field is parameter name, 2nd digit field is value
6. In 1st loop card (card 11), 1st digit field is parameter #, alpha field is parameter name, 2nd digit field is minimum value, 3rd digit field is maximum value
7. In 2nd loop card (card 12), 1st digit field is number of values to be tried, min and max included, 2nd digit field is loop output flag. If "0", then skip I.0 at this level, if "1", then print optimum result at this level

INPUT DECK

```

1      RUN #                00025
2      I/O FLAG              00010
3      1MW OUTPUT, GOAL TECH., 6YR. LIFE, 10% COST OF MONEY
4      # OF INPUT PARAMETERS 00040
5      PARAM # 00001        DCPAR = +1.13000E+006
6      PARAM # 00004        PLIFE = +6.0
7      PARAM # 00008        ELON = +1.292
8      PARAM # 00009        SLOW = +0.073
9      PARAM # 00010        RLOW = +2.67900E-005
10     PARAM # 00011        TLOW = +50.4
11     PARAM # 00012        EMED = +1.261
12     PARAM # 00013        SMED = +0.065
13     PARAM # 00014        RMED = +1.97400E-005
14     PARAM # 00015        TMED = +76.0
15     PARAM # 00016        EHIGH = +1.207
16     PARAM # 00017        SHIGH = +0.056
17     PARAM # 00018        RHIGH = +1.33400E-005
18     PARAM # 00019        THIGH = +121.0
19     PARAM # 00203        ANSCOS = 85.00
20     PARAM # 00204        ANCCOS = 20.00
21     PARAM # 00207        CACCOS = +21.5
22     PARAM # 00208        CAPRCOS = +1.00
23     PARAM # 00218        EPMSCOS = 3.46
24     PARAM # 00219        EPMEGCOS = 100.0
25     PARAM # 00199        FRFCEL = +1.0
26     PARAM # 00200        SLPCEL = +1.0
27     PARAM # 00216        FMSPCOS = +0.00
28     PARAM # 00217        FMPRCOS = +0.00
29     PARAM # 00261        ASSK1 = +17.34
30     PARAM # 00066        AINDIAM = +0.08
31     PARAM # 00067        OUTDIAM = +0.08
32     PARAM # 00068        CLMF = +30.0
33     PARAM # 00111        RESD = +0.38
34     PARAM # 00189        DNEFACT = +1000.0
35     PARAM # 00049        TRNO = +16.0
36     PARAM # 00167        PCOS = +0.03
37     PARAM # 00166        AIAF = +0.0
38     PARAM # 00161        CSR = +0.0
39     PARAM # 00162        RSR = +0.0
40     PARAM # 00165        DCCS = +0.10
41     PARAM # 00169        DUFAC = +0.90
42     PARAM # 00176        ZRVY = +6.0
43     PARAM # 00224        AMLFL = +6.0
44     PARAM # 00226        APLFH = +6.0
45     OPTIMIZE W.R.T. CAR, DELT, CCD, & PTMOD
46     # OF ACTIVE LOOPS      00004
47     PARAM # 00025        AMDELT = 5.0          TO 10.0
48     IN 00003 STEPS        00000 OUTPUT
49     PARAM # 00005        CAR = 0.5             TO 1.0
50     IN 00006 STEPS        00000 OUTPUT
51     PARAM # 00006        CCD = 5000.0          TO 10000
52     IN 00011 STEPS        00001 OUTPUT
53     PARAM # 00003        PTMOD = 75.0          TO 125.0
54     IN 00006 STEPS        00001 OUTPUT
55     END

```


APPENDIX D

"MAWES" LISTING

```

1      PROGRAM MAWES (INPUT,OUTPUT,DEBUG=OUTPUT)
2      C MODEL FOR THE DESIGN AND ECONOMIC ANALYSIS OF ALKALINE WATER ELECTROLYSIS
3      C SYSTEMS, WRITTEN 12/19/79 BY M.R. YAFFE, CODED IN FORTRAN EXTENDED VERSION
4      C VERSION 4, CDC-CYBER 76, NOS/BE 1 OP. SYS.
5      C COMMENT CARDS HAVE "C" IN COLUMN 1, DEBUG CARDS HAVE "CS" IN COLUMNS 1&2
6      COMMON/ELK1/PARAM(300)/BLK2/ESTOUT(200)
7      COMMON/ELK3/PNAME(300),ENAME(200),TITLE1(8),TITLE2(8)
8      COMMON/BLK4/PMEM(15,31)/BLK5/IFLAG(32)/BLK6/ESTMEM(500)
9      COMMON/ELK7/NLOOP,DLOOP(15,2),MLOOP(15,3)
10     FORMAT(30X,15,1X)
11     101  FORMAT(10X,15,15X,E13.5,1X)
12     102  FORMAT(10X,15,15X,E13.5,12X,E13.5,1X)
13     103  FORMAT(10X,15,15X,15,1X)
14     104  FORMAT(8(A10))
15     105  FORMAT(80X)
16     C BEGIN MAIN PROGRAM: READ RUN NUMBER, READ EXTENDED I/O FLAG
17     READ 100, NPUN
18     READ 100, IOFLAG
19     READ 104, (TITLE1(I), I=1, 8)
20     READ 100, NPAR
21     C READ NUMBER OF INPUT PARAMETERS, THEN READ PARAMETERS
22     IF (NPAR.EQ.0) GO TO 20
23     DO 1 I=1, NPAR
24     1     READ 101, I2, PARAM(I2)
25     READ 104, (TITLE2(I), I=1, 8)
26     CALL HEADING(NRUN)
27     C READ NUMBER OF LOOPS USED
28     READ 100, NLOOP
29     IF (NLOOP.EQ.0) 5, 2
30     DO 3 I=1, NLOOP
31     C READ VARIABLE NUMBER, MINIMUM VALUE, MAXIMUM VALUE, # OF STEPS, OUTPUT FLAG
32     READ 102, MLOOP(I,1), DLOOP(I,1), DLOOP(I,2)
33     3     READ 103, NLOOP(I,2), MLOOP(I,3)
34     READ 105
35     4     GO TO 215
36     C IF NO OPTIMIZATION LOOPS, THEN CALL "ESTIM" AND GO TO OUTPUT
37     5     CALL ESTIM
38     READ 104
39     GO TO 14
40     C BEGIN OPTIMIZATION LOOPS HERE

```

```

41      215      PMEM(15,1)=1.0E10
42      DO 2015 I=2,30
43      2015      PMEM(15,1)=0.0
44      M15=ML00P(15,2)
45      DO 2215 N15=1,M15
46      IF (ML00P(15,2).EQ.1) 2315,2415
47      2315      PARAM(ML00P(15,1))=DL00P(15,1)
48      GO TO 214
49      2415      PARAM(ML00P(15,1))=DL00P(15,1)+(N15-1)*
50      2(DL00P(15,2)-DL00P(15,1))/(ML00P(15,2)-1)
51      214      PMEM(14,1)=1.0E10
52      DO 2014 I=2,30
53      2014      PMEM(14,1)=0.0
54      M14=ML00P(14,2)
55      DO 2214 N14=1,M14
56      IF (ML00P(14,2).EQ.1) 2314,2414
57      2314      PARAM(ML00P(14,1))=DL00P(14,1)
58      GO TO 213
59      2414      PARAM(ML00P(14,1))=DL00P(14,1)+(N14-1)*
60      2(DL00P(14,2)-DL00P(14,1))/(ML00P(14,2)-1)
61      213      PMEM(13,1)=1.0E10
62      DO 2013 I=2,30
63      2013      PMEM(13,1)=0.0
64      M13=ML00P(13,2)
65      DO 2213 N13=1,M13
66      IF (ML00P(13,2).EQ.1) 2313,2413
67      2313      PARAM(ML00P(13,1))=DL00P(13,1)
68      GO TO 212
69      2413      PARAM(ML00P(13,1))=DL00P(13,1)+(N13-1)*
70      2(DL00P(13,2)-DL00P(13,1))/(ML00P(13,2)-1)
71      212      PMEM(12,1)=1.0E10
72      DO 2012 I=2,30
73      2012      PMEM(12,1)=0.0
74      M12=ML00P(12,2)
75      DO 2212 N12=1,M12
76      IF (ML00P(12,2).EQ.1) 2312,2412
77      2312      PARAM(ML00P(12,1))=DL00P(12,1)
78      GO TO 211
79      2412      PARAM(ML00P(12,1))=DL00P(12,1)+(N12-1)*
80      2(DL00P(12,2)-DL00P(12,1))/(ML00P(12,2)-1)

```

```

81 211 PMEM(11,1)=1.0E10
82 DO 2011 I=2,30
83 2011 PMEM(11,I)=0.0
84 M11=MLOOP(11,2)
85 DO 2211 N11=1,M11
86 IF (MLOOP(11,2).EQ.1) 2311,2411
87 2311 PARAM(MLOOP(11,1))=DLOOP(11,1)
88 GO TO 210
89 2411 PARAM(MLOOP(11,1))=DLOOP(11,1)+(N11-1)*
90 2(DLOOP(11,2)-DLOOP(11,1))/(MLOOP(11,2)-1)
91 210 PMEM(10,1)=1.0E10
92 DO 2010 I=2,30
93 2010 PMEM(10,I)=0.0
94 M10=MLOOP(10,2)
95 DO 2210 N10=1,M10
96 IF (MLOOP(10,2).EQ.1) 2310,2410
97 2310 PARAM(MLOOP(10,1))=DLOOP(10,1)
98 GO TO 209
99 2410 PARAM(MLOOP(10,1))=DLOOP(10,1)+(N10-1)*
100 2(DLOOP(10,2)-DLOOP(10,1))/(MLOOP(10,2)-1)
101 209 PMEM(09,1)=1.0E10
102 DO 2009 I=2,30
103 2009 PMEM(09,I)=0.0
104 M09=MLOOP(09,2)
105 DO 2209 N09=1,M09
106 IF (MLOOP(09,2).EQ.1) 2309,2409
107 2309 PARAM(MLOOP(09,1))=DLOOP(09,1)
108 GO TO 208
109 2409 PARAM(MLOOP(09,1))=DLOOP(09,1)+(N09-1)*
110 2(DLOOP(09,2)-DLOOP(09,1))/(MLOOP(09,2)-1)
111 208 PMEM(08,1)=1.0E10
112 DO 2008 I=2,30
113 2008 PMEM(08,I)=0.0
114 M08=MLOOP(08,2)
115 DO 2208 N08=1,M08
116 IF (MLOOP(08,2).EQ.1) 2308,2408
117 2308 PARAM(MLOOP(08,1))=DLOOP(08,1)
118 GO TO 207
119 2408 PARAM(MLOOP(08,1))=DLOOP(08,1)+(N08-1)*
120 2(DLOOP(08,2)-DLOOP(08,1))/(MLOOP(08,2)-1)

```

```

121 207 PMEM(07,1)=1.0E10
122 DO 2007 I=2,30
123 2007 PMEM(07,I)=0.0
124 M07=MLOOP(07,2)
125 DO 2207 N07=1,M07
126 IF (MLOOP(07,2).EQ.1) 2307,2407
127 2307 PARAM(MLOOP(07,1))=DLOOP(07,1)
128 GO TO 208
129 2407 PARAM(MLOOP(07,1))=DLOOP(07,1)+(N07-1)*
130 2(DLOOP(07,2)-DLOOP(07,1))/(MLOOP(07,2)-1)
131 206 PMEM(06,1)=1.0E10
132 DO 2006 I=2,30
133 2006 PMEM(06,I)=0.0
134 M06=MLOOP(06,2)
135 DO 2206 N06=1,M06
136 IF (MLOOP(06,2).EQ.1) 2306,2406
137 2306 PARAM(MLOOP(06,1))=DLOOP(06,1)
138 GO TO 205
139 2406 PARAM(MLOOP(06,1))=DLOOP(06,1)+(N06-1)*
140 2(DLOOP(06,2)-DLOOP(06,1))/(MLOOP(06,2)-1)
141 205 PMEM(05,1)=1.0E10
142 DO 2005 I=2,30
143 2005 PMEM(05,I)=0.0
144 M05=MLOOP(05,2)
145 DO 2205 N05=1,M05
146 IF (MLOOP(05,2).EQ.1) 2305,2405
147 2305 PARAM(MLOOP(05,1))=DLOOP(05,1)
148 GO TO 204
149 2405 PARAM(MLOOP(05,1))=DLOOP(05,1)+(N05-1)*
150 2(DLOOP(05,2)-DLOOP(05,1))/(MLOOP(05,2)-1)
151 204 PMEM(04,1)=1.0E10
152 DO 2004 I=2,30
153 2004 PMEM(04,I)=0.0
154 M04=MLOOP(04,2)
155 DO 2204 N04=1,M04
156 IF (MLOOP(04,2).EQ.1) 2304,2404
157 2304 PARAM(MLOOP(04,1))=DLOOP(04,1)
158 GO TO 203
159 2404 PARAM(MLOOP(04,1))=DLOOP(04,1)+(N04-1)*
160 2(DLOOP(04,2)-DLOOP(04,1))/(MLOOP(04,2)-1)

```

```

161 203 PMEM(03,1)=1.0E10
162 DO 2003 I=2,30
163 2003 PMEM(03,I)=0.0
164 M03=MLCOP(03,2)
165 CO 2203 N03=1,M03
166 IF (MLCOP(03,2).EQ.1) 2303,2403
167 2303 PARAM(MLOOP(03,1))=DL0OP(03,1)
168 GO TO 202
169 2403 PARAM(MLOOP(03,1))=DL0OP(03,1)+(M03-1)*
170 2(DL0OP(03,2)-DL0OP(03,1))/(MLOOP(03,2)-1)
171 202 PMEM(02,1)=1.0E10
172 DO 2002 I=2,30
173 2002 PMEM(02,I)=0.0
174 M02=ML0OP(02,2)
175 DO 2202 N02=1,M02
176 IF (ML0OP(02,2).EQ.1) 2302,2402
177 2302 PARAM(MLOOP(02,1))=DL0OP(02,1)
178 GO TO 201
179 2402 PARAM(MLOOP(02,1))=DL0OP(02,1)+(N02-1)*
180 2(DL0OP(02,2)-DL0OP(02,1))/(MLOOP(02,2)-1)
181 201 PMEM(01,1)=1.0E10
182 DO 2001 I=2,30
183 2001 PMEM(01,I)=0.0
184 M01=ML0OP(01,2)
185 DO 2201 N01=1,M01
186 IF (ML0OP(01,2).EQ.1) 2301,2401
187 2301 PARAM(MLOOP(01,1))=DL0OP(01,1)
188 GO TO 200
189 2401 PARAM(MLOOP(01,1))=DL0OP(01,1)+(N01-1)*
190 2(DL0OP(01,2)-DL0OP(01,1))/(MLOOP(01,2)-1)
191 C CALL MAIN CALCULATION SUB. "ESTIM" TO GENERATE DESIGN DATA, SYSTEM COSTS,
192 C AND RESULTING GAS PRICES.
193 200 CALL ESTIM
194 C SAVE RESULTS IF BETTER THAN PREVIOUS RESULTS AT EACH LEVEL
195 DO 8 I=1,NLOOP
196 IF (ESTOUT(1).GE.PMEM(I,1)) GO TO 8
197 DO 10 I1=1,16
198 10 PMEM(I,I1) = ESTOUT(I1)
199 DO 9 I1=1,NLOOP
200 9 PMEM(I,16+I1)=PARAM(MLOOP(I1,1))

```

D-1

```
201      8      CONTINUE
202          IF (ESTOUT(1).GE.ESTMEN(1))GO TO 13
203          DO 11 I=1,200
204      11      ESTMEN(I)= ESTOUT(I)
205          DO 12 I=1,300
206      12      ESTMEN(I-200)= PARAM(I)
207      13      IF((IOFLAG.EQ.0).OR.(IOFLAG.EQ.10)) GO TO 14
208          CALL LIMOUT1
209      14      ESTOUT(1)=1.0E10
210          DO 15 I=2,200
211      15      ESTOUT(I)=0.0
212          IF (MLOOP(1,3).EQ.0)2201,2501
213      2501      K=1
214          CALL LIMOUT2(K)
215      2201      PMEN(1,1)=1.0E10
216          IF (MLOOP(2,3).EQ.0)2202,2502
217      2502      K=2
218          CALL LIMOUT2(K)
219      2202      PMEN(2,1)=1.0E10
220          IF (MLOOP(3,3).EQ.0)2203,2503
221      2503      K=3
222          CALL LIMOUT2(K)
223      2203      PMEN(3,1)=1.0E10
224          IF (MLOOP(4,3).EQ.0)2204,2504
225      2504      K=4
226          CALL LIMOUT2(K)
227      2204      PMEN(4,1)=1.0E10
228          IF (MLOOP(5,3).EQ.0)2205,2505
229      2505      K=5
230          CALL LIMOUT2(K)
231      2205      PMEN(5,1)=1.0E10
232          IF (MLOOP(6,3).EQ.0)2206,2506
233      2506      K=6
234          CALL LIMOUT2(K)
235      2206      PMEN(6,1)=1.0E10
236          IF (MLOOP(7,3).EQ.0)2207,2507
237      2507      K=7
238          CALL LIMOUT2(K)
239      2207      PMEN(7,1)=1.0E10
240          IF (MLOOP(8,3).EQ.0)2208,2508
```

D-1

```

241      2508 K=8
242          CALL LIMOUT2(K)
243      2208 PMEM(8,1)=1.0E10
244          IF (MLOOP(9,3).EQ.0)2209,2509
245      2509 K=9
246          CALL LIMOUT2(K)
247      2209 PMEM(9,1)=1.0E10
248          IF (MLOOP(10,3).EQ.0)2210,2510
249      2510 K=10
250          CALL LIMOUT2(K)
251      2210 PMEM(10,1)=1.0E10
252          IF (MLOOP(11,3).EQ.0)2211,2511
253      2511 K=11
254          CALL LIMOUT2(K)
255      2211 PMEM(11,1)=1.0E10
256          IF (MLOOP(12,3).EQ.0)2212,2512
257      2512 K=12
258          CALL LIMOUT2(K)
259      2212 PMEM(12,1)=1.0E10
260          IF (MLOOP(13,3).EQ.0)2213,2513
261      2513 K=13
262          CALL LIMOUT2(K)
263      2213 PMEM(13,1)=1.0E10
264          IF (MLOOP(14,3).EQ.0)2214,2514
265      2514 K=14
266          CALL LIMOUT2(K)
267      2214 PMEM(14,1)=1.0E10
268          IF (MLOOP(15,3).EQ.0)2215,2515
269      2515 K=15
270          CALL LIMOUT2(K)
271      2215 PMEM(15,1)=1.0E10
272      17 DO 18 I=1,200
273      18 ESTOUT(I)=ESTMEM(I)
274      DO 19 I=1,300
275      19 PARAM(I)=ESTMEM(I+200)
276      16 CALL EXCUT1 (IOFLAG,NRUN)
277      STOP
278      END

```



```

1      BLOCK DATA
2      C THE BASELINE CASE IN "BLOCK DATA" REPRESENTS 80.0 KW(DC) DUAL IRRIG. SYSTEM
3      COMMON/BLK1/PARAM(300)
4      COMMON/BLK2/ESTOUT(200)
5      COMMON/BLK3/PNAME(300),ENAME(200)
6      COMMON/BLK4/PMEM(15,31)
7      COMMON/BLK5/IFLAG(32)
8      COMMON/BLK6/ESTMEM(500)
9      COMMON/BLK7/NLOOP,DLOOP(15,2),MLOOP(15,3)
10     DATA (ESTOUT(I),I=1,200)/1.0E10,199*0.0/
11     DATA ((PMEM(I,I1),I=1,15),I1=1,31)/15*1.0E10,450*0.0/
12     DATA (IFLAG(I),I=1,32)/32*0/
13     DATA (ESTMEM(I),I=1,500)/1.0E10,499*0.0/
14     DATA NLOOP/0/
15     DATA ((DLOOP(I,I1),I=1,15),I1=1,2)/30*0.0/
16     DATA ((MLOOP(I,I1),I=1,15),I1=1,3)/15*300,15*1,15*0/
17     DATA (PNAME(I),I= 1,100)/
18     7HDCPWR ,7HPTAMB ,7HPTMOD ,7HPLIFE ,7HCAR ,7HCCD , 1- 6
19     7HCTHK ,7HELOW ,7HSLOW ,7HRLW ,7HTLOW ,7HEMED , 7- 12
20     7HSMED ,7HAMED ,7HTMED ,7HSHIGH ,7HSHIGH ,7HFRIGH , 13- 18
21     7HTHIGH ,7HCCOMP ,7HELCON ,7HLDLFC ,7HAMPRES ,7HAMDELP , 19- 24
22     7HAMDELT ,7HPCNTRL ,7HEMPTY ,7HEMPTY ,7HEMPTY ,7HEMPTY , 25- 30
23     7HAMSTY ,7HEPSTY ,7HAMXCEL ,7HAMASP ,7HEPDCF ,7HEPMOD , 31- 36
24     7HEPMODT ,7HEPRHO ,7HEPNU ,7HEMPTY ,7HEMPTY ,7HSLTHK , 37- 42
25     7HSLLO ,7HSLLOT ,7HSLMODIS ,7HEMPTY ,7HEMPTY ,7HEMPTY , 43- 48
26     7HTRNO ,7HTRMOD ,7HTRMODT ,7HTRCTE ,7HTRYLD ,7HTPYLDT , 49- 54
27     7HTRSF ,7HTRRHO ,7HTRNU ,7HEMPTY ,7HCFRHO ,7HCFMIS , 55- 60
28     7HCFMTST ,7HCFMAN ,7HEMPTY ,7HAINMAN ,7HOUTMAN ,7HAINDIAM , 61- 66
29     7HOUTDIAM ,7HAINPL ,7HOUTPL ,7HAINPDR ,7HOUTPDR ,7HAINEL , 67- 72
30     7HOUTEL ,7HEMPTY ,7HEMPTY ,7HEMPTY ,7HEMPTY ,7HEMPTY , 73- 78
31     7HEMPTY ,7HSCFMNR ,7HSCFMXR ,7HSCFX ,7HSCFC ,7HTHTA1 , 79- 84
32     7HTHTA2 ,7HEPIX ,7HEPOX ,7HEPIC ,7HEPQC ,7HAFF , 85- 90
33     7HEID ,7HEMPTY ,7HEMPTY ,7HEMPTY ,7HEMPTY ,7HEMPTY , 91- 96
34     7HCWT ,7HCWME ,7HFWT ,7HDPDL / 97-100
35     DATA (PARAM(I),I= 1,100)/
36     880000. ,25. ,60. ,20. ,0.067 ,6000. , 1- 6
37     88.62E-3 ,1.2872 ,0.191 ,4.26E-5 ,50.4 ,1.0E8 , 7- 12
38     20.233 ,3.00E-5 ,76. ,1.039 ,0.179 ,3.00E-5 , 13- 18
39     121. ,2.413E6 ,0.25 ,0.08 ,8.619E5 ,0. , 19- 24
40     88.33 ,500. ,0.0000000 ,0.0000000 ,0.0000000 ,0.0000000 , 25- 30

```

41	81.	,1.	,150.	,1.	,7.62E-5	,200.E9	,	31- 36
42	80.	,7950.	,0.3	,0.0000000	,0.0000000	,5.E-4	,	37- 42
43	810.34E6	,0.	,0.05	,0.0000000	,0.0000000	,0.0000000	,	43- 48
44	88.	,200.E9	,0.	,1.85E-5	,1.138E9	,0.0	,	49- 54
45	80.33	,7950.	,0.3	,0.0000000	,1.24E3	,16.8E6	,	55- 60
46	8-1.02E5	,0.03	,0.0000000	,1.	,1.	,0.04	,	61- 66
47	80.04	,0.04	,0.04	,0.233	,0.233	,0.2	,	67- 72
48	80.2	,0.0000000	,0.0000000	,0.0000000	,0.0000000	,0.0000000	,	73- 78
49	80.0000000	,0.6	,1.4	,1.536	,6.72E-8	,1.05	,	79- 84
50	81.6	,1.832	,14.35E-6	,1.832	,14.35E-6	,0.5	,	85- 90
51	80.4	,0.0000000	,0.0000000	,0.0000000	,0.0000000	,0.0000000	,	91- 96
52	835.	,1.89	,25.	,2.26E3	/			97-100
53	DATA (PNAME(I),I=101,200)/							
54	87HPLMIN	,7HPLK	,7HFPDPPE	,7HFSRC	,7HHXPOPPD	,7HETAPMOT	,	101-106
55	87HPKTH	,7HELPH	,7HELFD	,7HRESH	,7HRESO	,7HELPWT	,	107-112
56	87HETAPVM	,7HTCOO	,7HTCOH	,7HDT00	,7HOTOH	,7HEPTY	,	113-118
57	87HOCHEF	,7HHCHEF	,7HETAWP	,7HETAWPM	,7HEPTY	,7HEPTY	,	119-124
58	87HEPKTH	,7HAMINS	,7HAMINS	,7HCFKTH	,7HRESHEF	,7HRESINST	,	125-130
59	87HRESINSK	,7HUHXA	,7HUHXC	,7HVCIDFR	,7HEPTY	,7HEPTY	,	131-136
60	87HHIOMR	,7HOIMANCL	,7HOPUR	,7HFPUR	,7HONO	,7FCHNO	,	137-142
61	87HDOCYC	,7HHCYC	,7HDSMUR	,7HDSVOID	,7HOSCP	,7HOTCHG	,	143-148
62	87HDSDEN	,7HDLOR	,7HDSWTHK	,7HDSWDENS	,7HDSWCP	,7HDSFS	,	149-154
63	87HPOS	,7HETACOMP	,7HRATCOMP	,7HMASR	,7HHMASR	,7HORFURG	,	155-160
64	87HCSR	,7HRCR	,7HCSCOS	,7HRCCOS	,7HDCOS	,7FAINF	,	161-166
65	87HPCOS	,7HPCR	,7HUFACI	,7HTXR	,7HTLR	,7HTXCP	,	167-172
66	87HPTXIR	,7HACCTFLG	,7HCRVRZ	,7HZRVY	,7HPSV	,7PCVSPCOS	,	173-178
67	87HFWSPCOS	,7HAMNTR	,7HGPSVCCS	,7HALBRPT	,7HGHATE	,7HGAPATE	,	179-184
68	87HCASPCOS	,7HOPERTAU	,7HAINVEN	,7HDNEK	,7HONEFACT	,7HGMARGC	,	185-190
69	87HAINSTK	,7HGMARGE	,7HBLK	,7HCLK	,7HGMARGBF	,7HPLASCSI	,	191-196
70	87HCFPLPLMD	,7HMOPCOST	,7HFRPCEL	,7HSLPCEL	/			197-200
71	DATA (PARAM(I),I=101,200)/							
72	82.	,0.18	,1.6	,20.	,0.4	,0.8	,	101-106
73	815.	,0.4	,0.165	,1.22	,0.19	,1.016E-3	,	107-112
74	80.8	,50.	,41.	,8.5	,8.5	,0.0000000	,	113-118
75	857.	,114.	,0.6	,0.8	,0.0000000	,0.0000000	,	119-124
76	815.	,0.	,0.01	,0.26	,4000.	,0.	,	125-130
77	80.01	,568.	,568.	,0.5	,0.0000000	,0.0000000	,	131-136
78	80.002	,2.	,0.98	,0.9995	,2.	,2.	,	137-142
79	814400.	,14400.	,0.15	,0.15	,1046.	,300.	,	143-148
80	8714.	,5.	,3.40E-3	,7950.	,500.	,0.	,	149-154

81	80.	.0.5	.7.	.3.	.0.0	.0.2		155-160
82	80.30	.0.40	.0.08	.3.15	.0.10	.0.10		161-166
83	80.025	.0.00	.0.85	.3.46	.0.667	.0.00		167-172
84	80.02	.1.0	.0.75	.10.0	.0.0	.0.582E-4		173-178
85	81.321E-3	.2.0	.0.53	.14000.	.1.0	.0.0		179-184
86	80.48	.14.	.0.01	.2.4E4	.100.0	.0.75		185-190
87	8200.	.0.75	.25.	.1000.	.0.0	.8.422		191-196
88	8200000.	.3.0	.2.	.2.	/			197-200
89	DATA (PNAME(I),I=201,300)/							
90	87HSLMCOS	87HSLPCOS	87HANSCOS	87HARCCOS	87HAMPRCOS	87HCASCOS		201-206
91	87HCACCOS	87HCAPRCOS	87HSEPCOS	87HSEPPCOS	87HRPTHK	87HBPDCNS		207-212
92	87HBPMSCOS	87HPPPCOS	87HFMTHK	87HFMSPCOS	87HFMPCOS	87HEPMSCOS		213-218
93	87HEPMFGCS	87HTRMCOS	87HTRPCOS	87HTRHCO	87HEPTY	87HAMLFL		219-224
94	87PTMLLOW	87HAMLFH	87PTMLHIGH	87HAMCF	87HCMCF	87FCMCF		225-230
95	87HHMCF	87HELPRK1	87HELPRK2	87HGS9PK1	87HGS9PK2	87PFILK1		231-236
96	87HFILK2	87HHXK1	87HHXK2	87HPUMPK1	87HPUMPK2	87HRESK1		237-242
97	87HRESK2	87HRESK3	87HCONK1	87HCONK2	87HCONK3	87HAINSK1		243-248
98	87PCWFBK1	87HFUPRK1	87HCNIK1	87HPURGK1	87HORYK1	87HORYK2		249-254
99	87HVENK1	87HSTRK1	87HCONK1	87HDTK1	87HPSK1	87HUNASK1		255-260
100	87HASSYK1	87HASSYK2	87HEPTY	87HEPTY	87HEPTY	87HEPTY		261-266
101	87HEPTY	87HEPTY	87HEPTY	87HEPTY	87HEPTY	87HEPTY		267-272
102	87HEPTY	87HEPTY	87HEPTY	87HEPTY	87HEPTY	87HEPTY		273-278
103	87HEPTY	87HEPTY	87HEPTY	87HEPTY	87HEPTY	87HEPTY		279-284
104	87HEPTY	87HEPTY	87HEPTY	87HEPTY	87HEPTY	87HEPTY		285-290
105	87HEPTY	87HEPTY	87HEPTY	87HEPTY	87HEPTY	87HEPTY		291-296
106	87HEPTY	87HEPTY	87HEPTY	87HDUMMY	/			297-300
107	DATA (PARAM(I),I=201,300)/							
108	811.50	.0.60	.69.6	.0.0	.0.25	.69.6		201-206
109	80.0	.0.25	.5.00	.0.70	.4.572E-4	.8900.		207-212
110	813.23	.3.50	.0.16E-2	.1.66E4	.0.40	.6.93		213-218
111	8650.	.6.24	.1.10	.900.	.0.0000000	.10.		219-224
112	850.0	.5.0	.125.0	.1.	.1.	.1.		225-230
113	81.	.4.764E5	.0.5	.5.3	.0.33	.1.735E5		231-236
114	81.0	.5.767E2	.0.8	.384.8	.1.	.4312.		237-242
115	80.5	.250.	.5956.	.3.63E5	.0.8	.93.0		243-248
116	8220.	.200.	.3400.	.130.	.3.00E6	.0.7		249-254
117	8212.	.1742.	.5.0E7	.7000.	.3.356E-2	.0.05		255-260
118	828.9	.867.0	.0.08000000	.0.00000000	.0.00000000	.0.00000000		261-266
119	80.00000000	.0.00000000	.0.00000000	.0.00000000	.0.00000000	.0.00000000		267-272
120	80.00000000	.0.00000000	.0.00000000	.0.00000000	.0.00000000	.0.00000000		273-278

121	80.0000000,0.0000000,0.0000000,0.0000000,0.0000000,0.0000000,	279-284
122	80.0000000,0.0000000,0.0000000,0.0000000,0.0000000,0.0000000,	285-290
123	80.0000000,0.0000000,0.0000000,0.0000000,0.0000000,0.0000000,	291-296
124	80.0000000,0.0000000,0.0000000,0.0000000,0.0000000,0.0000000,	297-300
125	DATA (ENAME(I),I=1,100)/	
126	87HALVGRX,7HACPR,7HETATOT,7HCVOLT,7HBBV,7HBP1,	1- 6
127	87HCAPPRX,7HAPCOS,7HAOCOS,7HGASOUT,7HPLTCOS,7HAMLIFE,	7- 12
128	87HTMDCOS,7HSYSAREA,7HTOTCEL,7HSPGRX,7HDRISC,7HDEFTRAT,	13- 18
129	87HWCC,7HCRFB,7HALATC,7HALAPC,7HALAOC,7HALACC,	19- 24
130	87HALAFCR,7HBLGFL,7HAINSTL,7HCOMPCOS,7HWOUT,7HEFFI,	25- 30
131	87HCELCUR,7HPMD,7HAMCEL,7HETAV,7HETAI,7HETAP,	31- 36
132	87HETAP,7HPPVR,7HETAM,7HVT,7HAMODG,7HAMLEN,	37- 42
133	87HCFMAS,7HCFVOD,7HCFHOD,7HCFAN,7HCFSA,7HTPLEN,	43- 48
134	87HTRODAM,7HTRMAS,7HPTHK,7HEPAR,7HEPVOL,7HEPMAS,	49- 54
135	87HAMFEL,7HAMFEL,7HVELIN,7HVELOUT,7HPDSTK,7HPDMOD,	55- 60
136	87HCFMAX,7HCFMIN,7HSEPCOS,7HPCOS,7HMCOS,7HMODCOS,	61- 66
137	87HPIDA,7HFIDC,7HPDA,7HPDC,7HPDC,	67- 72
138	87HPIPA,7HPIPC,7HPCON,7HPCOM,7HOMFL,7HMF,	73- 78
139	87HWMFLO3,7HWMFLH2,7HWMFL,7HPSA,7HSPC,7HCFLOC,	79- 84
140	87HCWFLHC,7HOCAP,7HHCAR,7HCWFL,7HFWPP,7HMODCV,	85- 90
141	87HPLENA,7HPLENC,7HWMFLO2,7HWMFLH2,7HWMFLO1,7HWMFLH1,	91- 96
142	87HSTKLEN,7HGRESV,7HPIPECV,7HAHXAR /	97-100
143	DATA (ENAME(I),I=101,200)/	
144	87HCHXAR,7HCWFAHX,7HCWFCHX,7HQAHX,7HCHX,7HCTAHX,	101-106
145	87HCTCHX,7HAVOL,7HCVOL,7HPWAT,7HPKH,7HPMFL,	107-112
146	87HPAMFL,7HCFMFL,7HPAVFL,7HPCVFL,7HGVOL,7HMODCOS,	113-118
147	87HEPTY,7HOMFLH,7HMFLO,7HOMFLOUT,7HMFLOUT,7HMFLO5,	119-124
148	87HWMFLH5,7HWMFLO4,7HWMFLH4,7HDSMO,7HDSMH,7HDC,	125-130
149	87HDDH,7HDL,7HDLH,7HDP,7HCPH,7HDPN,	131-136
150	87HAUXPWR,7HCPWR,7HCPWR,7HCOMPS,7HCOMPS,7HOSTOR,	137-142
151	87PHSTOR,7HEPTY,7HEPTY,7HPCLF,7HGINLF,7HSLCEPR,	143-148
152	87HATDEPR,7HPLFT,7HCPFT,7HALAADA,7HALAIT,7HALAITCA,	149-154
153	87HPDA,7HACWCOS,7HAFWCOST,7HAMATCOS,7HALBRCCOS,7HACACOS,	155-160
154	87HAOHCOS,7HANCOST,7HACOST,7HCELCOST,7HEPCOST,7HTRCOST,	161-166
155	87HMOLOCOS,7HCFCCOST,7HSLCOST,7HASSYCOS,7HAMPCOS,7HAPPCOS,	167-172
156	87HOXPBCOS,7HHYPCOS,7HANFLCOS,7HCAFLCOS,7HANHXCOS,7HCAHXCOS,	173-178
157	87HANPHCOS,7HAPPCOS,7HANRSCOS,7HARSCOS,7HPURGCOS,7HXCNCOS,	179-184
158	87HHYCNCOS,7HOXDFCOS,7HHYDCOS,7HAINSCOS,7HCWPCOS,7HFWPCOS,	185-190
159	87HVENTCOS,7HSTRTCOS,7HOXCMCOS,7HHYCMCOS,7HOXRTCOS,7HHYFTCOS,	191-196
160	87HPSCOS,7HUNASCOS,7HCNINCOS,7HDNECOS /	197-200

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

```

1  SUBROUTINE HEADING(NRUN)
2  COMMON/BLK1/PARAM(300)
3  COMMON/BLK3/PNAME(300),ENAME(200),TITLE1(8),TITLE2(8)
4  CALL DATE(TODAY)
5  PRINT 100
6
7  100  FORMAT(1H1/
8      & 10X,48HX      X      XX      XX      XX      XXXXXXXX      XXXXXXXX/
9      & 10X,48HXX      XX      XX>X      XX      XX      XX      XX      /
10     & 10X,48HXXX      XXX      XX      XX      XX      XX      XX      /
11     & 10X,48HXXXXXXXXX >X      XX      XX      XX      X>      XXXXXXXX/
12     & 10X,48HXX XX XX >X      XX      XX      XX      XXXX      XXXXXXXX/
13     & 10X,48HXX      X> >XXXX>XXX XXXXXXXX XX      >X/
14     & 10X,48HXX      X> >X      XX      >XX      XXX      XX      XX/
15     & 10X,48HXX      X> >X      XX      X      X      XXXXXXXX XXXXXXXX)
16  PRINT 106,NRUN,TODAY
17  106  FORMAT(1H0,10X,10H-RUN NUMBER,I3,14H. EXECUTED ON ,A10)
18  PRINT 102,(TITLE1(I),I=1,8),(TITLE2(I),I=1,8)
19  102  FORMAT(11X,8A10/8A10)
20  PRINT 103,(I,PNAME(I),PARAM(I),I=1,262)
21  103  FORMAT (60(2X,5(I3,1H.,A7,1H=,1PG11.4,2X)/))
22  RETURN
23  END

```

```

1      SUBROUTINE ESTIM
2      CS   DEBUG
3      CS   CALLS
4      CS   FUNCS
5      CS   TRACE
6      C1   STORES(DCPWR,PPWR,AMCEL,CI,PMOD)
7      C SUBROUTINE "ESTIM" IS TRAFFIC CONTROL CENTER FOR DESIGN & COST ESTIMATION
8      C SEE REFERENCE TABLE FOR MNEMONIC DEFINITIONS AND UNITS
9      COMMON/BLK1/DCPWR,PT,PTMOD,X3,CAR,CCD,X6(24),AMSTY,EPSTY,AMXCEL,
10     2X33(190),AMFL,TLCW,AMLFH,THIGH
11     COMMON/BLK2/ALGPRX,ACPWR,ETATGT,CV,BBV,BBI,CAPCOS,APCOS,AOCOS,AGO,
12     2PLTCOSZ,AMLF,AMCOSZ,SAR,PCEL,Y15(15),CI,PMOD,AMCEL,ETAV,ETAI,ETAP,
13     3ETAP,PPWR,ETAM,VTH,AMODG,AMLEN,Y42(2),CFHOD
14     COMMON/BLK5/IFLAG(32)
15     DIMENSION AMES(32,4)
16     DATA ((AMES(I,J),J=1,4),I=1,5)/
17     110H1-ENDOTHER,10HMC AVERAG,10HE CELL VOL,10HTAGE ,
18     210H2-INLET MA,10HAIFOLDS OV,10HERSIZED ,10H ,
19     310H3-OUTLET M,10HANIFOLDS O,10HVERSIZED ,10H ,
20     410H4-SUPMINIM,10HUM FLOW IN,10H ONE OR MO,10HRE CELLS ,
21     510H5-OVERMAXI,10HMUM FLOW I,10HN ONE OR M,10HORE CELLS ,
22     610H6-REQ'D CO,10HOLING WATE,10HR FLOW TOO,10H LARGE ,
23     710H7-HEAT LOS,10HS AT CONDE,10HNSER TOO L,10HARGE ,
24     810H8-HEAT LOS,10HS BY CONVE,10HCTION TOO ,10HLARGE ,
25     910H9-NET HEAT,10H LOSS TOO ,10HLARGE ,10H /
26     100  FORMAT(29HONEXT CASE IS OUT OF RANGE ON)
27     101  FOR'AT(1X,4A10)
28     DO 200 I=1,32
29     200  IFLAG(I)=0
30     CALL VOLTCLC , RETURNS(1000)
31     CI =CAR*CCD
32     PPWR=DCPWR
33     PCEL=PPWR/(CV*CI)
34     PMOD=PCEL/AMXCEL
35     PMOD=AIMT(PMOD)+1.0
36     AMCEL=AIMT(PCEL/PMOD) +1.0
37     PCEL = AMCEL*PMOD
38     PPWR = PCEL*CI *CV
39     BBV = AMCEL*CV
40     BBI = CI *PMOD

```

```

41      VTH=1.4813+1.638E-4*(PT-25.)
42      ETAV= VTH/CV
43      CALL ETAREC
44      I=IFIX(AMSTY)
45      IF(1.EQ.2) GO TO 202
46      CALL CFRMO,RETURNS(1000)
47      GO TO 205
48      202 CALL RFRMO,RETURNS(1000)
49      205 CALL ETACUR
50      ETAM= ETA1 *ETAV
51      AMODQ=(1.0-ETAM)*CI*BBV
52      CALL MANANAL,FETURNS(1000)
53      CALL HMPE ,RETURNS(1000)
54      SAR= 2.*PMOD*AMLEN*CFHCD
55      CALL CONDTT
56      CALL ETANET
57      CALL PLTCOST
58      CALL LIFE(TLOW,AMLFL,THIGH,ARLFH,PTMDD,AMLF)
59      CALL MODCOST
60      CALL CAPCOST
61      CALL OPCOST
62      CALL GASCOST
63      RETURN
64      1000 PRINT 100
65      DO 206 N=1,32
66      IF (IFLAG(N).EQ.0) GO TO 206
67      PRINT 101,AMES(N,1),AMES(N,2),AMES(N,3),AMES(N,4)
68      206 CONTINUE
69      ALSPRX =1.0E10
70      RETURN
71      END

```



```

1  SUBROUTINE EXOUT1(IOFLAG,NRUN)
2  COMMON/ELK1/PARAM(300)
3  COMMON/BLK2/ESTOUT(200)
4  COMMON/BLK3/PNAME(300),ENAME(200),TITLE1(8),TITLE2(8)
5  COMMON/BLK7/NLOOP,DLOOP(15,2),MLOOP(15,3)
6  100  FORMAT (2X,8A10/PA10)
7  101  FORMAT (18H1 OPTIMUM FOR RUN -,I4,6H WITH ,I2,16H LOOP PARAMETERS)
8  102  FORMAT (20H0 INPUT PARAMETERS )
9  103  FORMAT (60(2X,5(I3,1H.,A7,1H=,1PG11.4,2X)/))
10  104  FORMAT (20H0 OUTPUT PARAMETERS )
11  105  FORMAT (15(3X,I3,1H.,A7,1H=,1PG11.4,4H TO ,1PG11.4,4H IN ,I5,
12      19H STEPS, OPTIMUM AT ,1PG11.4/))
13  106  FORMAT (150(1H0,2(I3,1H.,A7,1H=,1PG11.4,42X)/))
14  PRINT 101,NRUN,NLOOP
15  PRINT 100,(TITLE1(I),I=1,8),(TITLE2(I),I=1,8)
16  PRINT 105,(MLOOP(I,1),PNAME(MLOOP(I,1)),DLOOP(I,1),DLOOP(I,2),
17      MLOOP(I,2),PARAM(MLOOP(I,1)),I=1,NLOOP)
18  IF ((IOFLAG.EQ.10).OR.(IOFLAG.EQ.11)) GO TO 1
19  PRINT 102
20  PRINT 103,(I,PNAME(I),PARAM(I),I=1,262)
21  PRINT 104
22  PRINT 103,(I,ENAME(I),ESTOUT(I),I=1,200)
23  GO TO 2
24  1  PRINT 102
25  PRINT 105,(I,PNAME(I),PARAM(I),I=1,262)
26  PRINT 104
27  PRINT 105,(I,ENAME(I),ESTOUT(I),I=1,200)
28  2  RETURN
29  END

```

```

1      SUBROUTINE ETACUR
2      CS  DEBUG
3      COMMON/BLK1/X0(2),PTMCD,X3,CAR,X5,CTHK,X7(13),ELCON,ELDELC,AMPRES,
4      2AMDELP,AMDELT,>25(38),AMN(2,5)
5      COMMON/BLK2/Y0(3),CV,Y4(26),CI,PMOD,AMCEL,ETAV,ETAI
6      DIMENSION R1(2,2),R2(2,2),R4(2,2),ALOS(2,2)
7      C    L=IN,OUT, K=H,C
8      RHO(T,C)=1./((12.02-.4358*T+10.05*T*C+195.9*C-14.08*T*C*C
9      S-414.5*C*C)
10     Z=CV/CI
11     DO 1 K=1,2
12     DO 1 L=1,2
13     TMAN=PTMOD+(FLOAT(L)-1.5)*AMDELT
14     CMAN=ELCON +(1.5-FLOAT(K))*ELDELC
15     R=RHO(TMAN,CMAN)*(1.+1.25*(L-1)*(3-K))
16     R1(L,K)=(R *AMN(L,3))/(0.7854*CTHK*AMN(L,4))*2)
17     R2(L,K)=(R *CTHK)/(0.7854*AMN(L,2))*2)
18     R4(L,K)=(R *AMN(L,5))/(0.7854*AMN(L,2))*2)
19     1    CALL LOS(CI,AMCEL,7,R1(L,K),R2(L,K),R4(L,K),ALOS(L,K))
20     TOTLOS= AMN(1,1)*(ALOS(1,1)+ALOS(1,2))+AMN(2,1)*(ALOS(2,1)+ALOS(2,
21     22))
22     ETAI= 1.0-TOTLOS/(CI*AMCEL*CV)
23     RETURN
24     END

```

```

1      SUBROUTINE LOS(I1,AN,Z,R1,R2,R4,ALOS)
2      C$  DEBUG
3      C$  AREA (*,50),(300,*)
4      C$  STGRFS (I1,AN,Z,R1,R2,R4,ALOS,I,F1,D1,E1,D,E)
5      REAL I1
6      DIMENSION A(200),P(200), I(202),P(201)
7      DOUBLE PRECISION A,B,I,P,D,E,D1,E1,S1,S2
8      N1=IFIX(AN)
9      N2=N1+1
10     D1=Z/(R2+2.0*R1+Z)
11     E1=R1/(R2+2.0*R1+Z)
12     A(1)=1.0
13     A(2)=0.0
14     B(1)=0.0
15     B(2)=1.0
16     D=-Z/R1
17     E=(P1+R4+Z)/R1
18     A(3)=D
19     B(3)=E
20     S1=0.0
21     S2=1.0
22     E=(Z+2.0*R1+R2)/R1
23     DO 100 N=3,N1
24     A(N+1)=A(N)*E-A(N-1)+D
25     B(N+1)=B(N)*E-B(N-1)
26     S1=S1+A(N)
27     S2=S2+B(N)
28 100  CONTINUE
29     S1=S1+A(N2)
30     S2=S2+B(N2)
31     F1=(D1+E1*A(N1)-A(N2))/(B(N2)-E1*B(N1))
32     I(1)=AN*I1/(N1-S1-S2+F1)
33     I(2)=F1*I(1)
34 50   DO 200 J=3,N2
35     I(J)=A(J)*I(1)+B(J)*I(2)
36 200  CONTINUE
37     P(1)=I(2)
38     I(N1+2)=0.0
39     DO 300 J=2,N2
40     P(J)=I(J+1)-I(J)

```

```
41      300  CONTINUE
42          ALOS=(I(1)-I1)+AN
43          RETURN
44          END
```

```

1      SUBROUTINE VOLTCLC, RETURNS(N)
2      COMMON/BLK1/X0,X1, T, X3,X4,CCD,X6,CVP(4,3)
3      COMMON/BLK2/Y0(3),CV/PLK5/IFLAG(32)
4      I=3
5      IF (T.LE.CVP(4,2)) I=1
6      T1=(T-CVP(4,1))/(CVP(4,2)-CVP(4,1))
7      R= (CVP(3,2)-CVP(3,1))*T1+CVP(3,1)
8      S= (CVP(2,2)-CVP(2,1))*T1+CVP(2,1)
9      E= (CVP(1,2)-CVP(1,1))*T1+CVP(1,1)
10     CV= E+ S*(ALOG10(CCD))+ R*CCD
11     IF (CV.GT.1.48) GO TO 1
12     IFLAG(1)=1
13     RETURN N
14     RETURN
15     END

```

```
1 SUEROUTINE ETAREC  
2 COMMON/PLK2/Y1(35),ETAR  
3 ETAR=0.95  
4 RETURN  
5 END
```

```

1      SUBROUTINE CFRMO, RETURNS(N)
2      CS  DEBUG
3      COMMON/ELK1/X0,X1,PTMOD,X3,CAR,X5,CTHK,X7(12),CCOMP,X20(2),AMPRES,
4      2X23(8),EPSTY,X32,AMASP,EPDEF,EPMOD,EPMODT,EPRHO,EPNU,X39(2),SLTHK,
5      3SLLO,SLLOT,SLMDIS,SLDCDIS,X46(2),TRNO,TRMOD,TRMODT,TRCTE,TRUITS,
6      4TRUTST,TRSF,TRRHO,TRNU,X57,CFRHO,CFMTS,CFMTST,CFMAN,X62,AMN(2,5)
7      COMMON/BLK2/Y0(41),AMLEN,CFMAS,CFVOD,CFHOD,CFAN,CFSAR
8      COMMON/BLK5/IFLAG(32)
9      R=SQRT(CAR/3.14159)
10     ARC=(R+AMN(1,3)+AMN(1,2)/2.0)*1.5708
11     HOLE=AMN(1,1)+AMN(1,2)*2.0+(2.0*AMN(1,1)-1.0)*SLMDIS
12     IF (HOLE.GT.ARC) IFLAG(2)=1
13     ARC=(R+AMN(2,3)+AMN(2,2)/2.0)*1.5708
14     HOLE=AMN(2,1)+AMN(2,2)*2.0+(2.0*AMN(1,1)-1.0)*SLMDIS
15     IF (HOLE.GT.ARC) IFLAG(3)=1
16     IF (IFLAG(2)+IFLAG(3).GT.0) RETURN N
17     TS=(CFMTS-(PTMOD-25)*CFMTST)
18     SAND= AMAX1((AMN(1,2)+AMN(1,3)),(AMN(2,2)+AMN(2,3)))
19     AND =AMPRES*(R+SAND)/TS
20     IF (AND.LE.CFMAN) AND=CFMAN
21     CFAN= SAND*AND
22     CFHOD= 2*(CFAN+R)
23     CFVOD=CFHOD
24     CFSAR=.7834*(CFHOD**2-4.*R**2-2.*(AMN(1,1)+AMN(1,2))+2*AMN(2,1)
25     +AMN(2,2)+2))
26     CFMAS=CFSAR*(CTHK-SLTHK)*CFRHO
27     I=IFIX(EPSTY)
28     IF (I.EQ.2) GO TO 102
29     101  CALL CEPS1
30         RETURN
31     102  CALL CEPS1
32         RETURN
33     END

```

```

1      SUBROUTINE CEPST
2      CS  DEBUG
3      COMMON/PLK1/X0,X1,PTMOD,X3,CAR,X5,CTHK,X7(12),CCOMP,X20(2),AMPRES,
4      2X23(8),EPSTY,X32,AMASP,FPDEF,EPMOD,EPMODT,EPRHO,EPNU,X39(2),SLTHK,
5      3SLLO,SLLDT,SLMDIS,SLOCDS,X46(2),TRNO,TRMOD,TRMODT,TRCTE,TRUTS,
6      4TRUTST,TRSF,TRRHO,TRNU,X57,CFRHO,CFMTS,CFMTST,CFMAN,X62,AMN(2,5)
7      COMMON/BLK2/Y0(32),AMCEL,Y33(8),AMLEN,CFMAS,CFVOD,CFHOD,CFAN,
8      2CFSAR,TRLEN,TRDIAM,TRMAS,EPTHK,EPAR,EPVOL,EPMAS
9      SLP=(SLLO+(PTMOD-25.)*SLLDT)
10     E=(EPMOD+(PTMOD-25.)*EPMODT)
11     P=AMPRES+CCOMP
12     TRTS=TRSF*(TRUTS+(PTMOD-25.)*TRUTST)
13     AM=1.0/EPNU
14     RO=SQRT(CAR/3.14159)
15     AO=CFHOD/2.
16     F1=(12*AM+4.0)*AO*AO/(AM+1.0)
17     F2=+4.0*PC*RO*ALOG(RO/AO)
18     F3=-(7.*AM+3.)*RO*RO/(AM+1.0)
19     F=0.1875*AMPRES*(AM*AM-1.)*RO*RO*(F1+F2+F3)/(E*AM*AM)
20     AL17=0.25*(1.-.25*(1.0-EPNU)*(1.-(RC/AO)**4)-(RO/AO)**2*(1.0-
21     8(1.0+EPNU)*ALOG(RO/AO)))
22     AL11=0.015625*(1.0+4.0*((RO/AO)**2)-5.0*((RO/AO)**4)+4.0*((RO/AO)
23     8**2)*(2.0+((RO/AO)**2))*ALOG(RO/AO))
24     G=(SLP*(AO**4)/(2.0*E))*[AL17/(1.+EPNU)-2.*AL11]*12.*(1.0-EPNU**2)
25     EPTHK=((F+G)/EPDEF)**.333
26     AMLD=(0.7854*AO**2-CFSAR)*P+CFSAR*SLP
27     TRDIAM=SQRT(AMLD/(TRNO*0.7854*TRTS))
28     EPAR=3.14159*((AO**2)+1.5*TRDIAM)**2
29     EPVOL=EPAR*EPTHK
30     EPMAS=EPVOL*EPRHO
31     AMLEN=AMCEL*CTHK+2.0*EPTHK
32     TRLEN=AMLEN+8.0*TRDIAM
33     TRNO=TRNO
34     TRRHO=TRRHO
35     TRMAS=TRLEN*TRNO*TRRHO*0.7854*TRDIAM**2
36     RETURN
37     END

```



```

1      SUBROUTINE RFRMO, RETURNS(N)
2      COMMON/BLK1/X0,X1,PTMOD,X3,CAR,X5,CTHK,X7(12),CCOMP,X20(2),AMPRES,
3      2X23(8),EPSTY,X32,AMASP,FPDEF,EPMOD,EPMODT,EPRH0,EPNU,X39(2),SLTHK,
4      3SLLD,SLLDI,SLMDIS,SLDCCIS,X46(2),TRNO,TRMOD,TRMODTTTRCTE,TRUTS,
5      4TRUTST,TRSE,TRRH0,TRNU,X57,CFRH0,CFMIS,CFMTST,CFMAN,X62,AMN(2,5)
6      COMMON/BLK2/Y0(41),AMLEN,CFMAS,CFVOD,CFHOD,CFAN,CFSAR
7      COMMON/BLK5/IFLAG(32)
8      VIL= SORT(CAR/AMASP)
9      HIL=CAR/VIL
10     HOLE= AMN(1,1)*AMN(1,2)+(2.*AMN(1,1)+1.0)*SLMDIS
11     IF(HOLE.GT.HIL) IFLAG(2)=1
12     HOLE= AMN(2,1)*AMN(2,2)+(2.*AMN(2,1)+1.0)*SLMDIS
13     IF(HOLE.GT.HIL) IFLAG(3)=1
14     IF(IFLAG(2)+IFLAG(3).GT.0) RETURN N
15     TS= CFMTS-(PTMOD-25.)*CFMTST
16     AND= SORT((CAR*AMPRES)/(1.33*TS))
17     IF(AND.LE.CFMAN) AND= CFMAN
18     CFVOD= VIL+ 2.*AND+ AMN(1,2)+AMN(2,2)+AMN(1,3)+AMN(2,3)
19     CFHOD = HIL+2.*AND
20     CFRAN= (CFVOD-VIL)/2.0
21     CFSAR=CFVOD*CFHOD-HIL*VIL -1.5708*(AMN(1,1)*AMN(1,2)**2+AMN(2,1)*
22     &AMN(2,2)**2)
23     CFMAS=CFSAR*(CTHK-SLTHK)*CFRH0
24     I=IFIX(EPSTY)
25     IF (I.EQ.2) GO TO 102
26     101  CALL REFSI
27         RETURN
28     102  CALL REFSI
29         RETURN
30     END

```

```

1      SUBROUTINE REPSI
2      COMMON/BLK1/X0,X1,PTMOD,X3,CAR,X5,CTHK,X7(12),CCOMP,X20(2),AMPRES,
3      2X23(8),EPSTY,X32,AMASP,EPOEF,EPMOD,EPMODT,EPRHO,EPNU,X39(2),SLTHK,
4      3SLLD,SLLDI,SLMDIS,SLDDIS,X46(2),TRNO,TRMOD,TRMODT,TRCTC,TRUTS,
5      4TRUTST,TRSF,TRRHO,TRNU,X57,CFRHO,CFMTS,CFMTST,CFMAN,X62,AMN(2,5)
6      COMMON/BLK2/Y0(32),AMCEL,Y33(8),AMLEN,CFMAS,CFVOD,A0,CFAN,CFSAR,
7      2TRLEN,TRDIAM,TRMAS,EPTHK,EPAR,EPVOL,EPMAS
8      SLP=(SLLD+(PTMOD-25.)*SLLDI)
9      E = EPMOD +(PTMOD-25.)*EPMODT
10     TRTS= TRSF*(TRJTS+(PTMOD-25.)*TRUTST)
11     P= AMPRES+CCOMP
12     Q= P-SLP
13     A2= 0.5*SQRT(CAR)
14     AMLD=CFSAR*SLP +CAR*P
15     P1=Q*A2+SLP*CFVOD
16     T= (Q*(A2**3/24.)*(4.E*CFVOD-A2)+(SLP*CFVOD**2/24.)*(3.*CFVOD**2)
17     -P1*(CFVOD**3)/3.)
18     EPTHK=ABS(12.*T/(E*EPOEF))**.333/1.52
19     TRDIAM=SQRT( AMLD/(TRNO*0.7854*TRTS))
20     EPAR= 3.14159*(A0/2)+1.5*TRDIAM)**2
21     EPVOL= EPAR*EPTHK
22     EPMAS= EPVOL*EPRHO
23     AMLEN= AMCEL*CTHK+2.0*EPTHK
24     TRLEN= AMLEN+8.0*TRDIAM
25     TRMAS= TRLEN*TRNO*TRRHO*0.7854*TRDIAM**2
26     RETURN
27     END

```

```

1      SUBROUTINE MANANAL, RETURNS(N0)
2      CS  DEBUG
3      CS  AREA (*,8),(2,*).
4      CS  TRACE
5      CS  COTOS
6      EXTERNAL DEN, VIS, CP
7      COMMON/BLK1/X0(2), PTMOD, X3, CAR, CCD, CTHK, X7(12), CCOMP, ELCON, ELDELCO,
8      2AMPRES, AMDELP, AMDELT, X25(38), AMN(2,5), X73(6), SCFMNR, SCFMXR, SCFX,
9      3SCFC, THTA1, THTA2, EPIX, EPIC, CPOX, EPOC, AFF, ETD
10     COMMON/ELK2/Y0(32), AMCEL, Y33(7), AMODG, Y41(13), AMMFL, AMVFL, VI, VO,
11     2POSTK, PDMOD, CFMAY, CFMIN, X62(34), ALEN
12     COMMON/BLK5/IFLAG(32)
13     DIMENSION GE(3), E(2), G(200), Z(200)
14     J=1
15     N=IFIX(AMCEL)
16     RHOI= DEN*(PTMOD, ELCON)
17     VISI= VIS(PTMOD, ELCON)/RHOI
18     CPI= CF(PTMOD, ELCON)
19     AMMFL= AMODG/(AMDELT*CPI)
20     AMVFL=AMMFL/RHOI
21     AVFL=AMVFL*AFF
22     ALEN=CTHK*AMCEL
23     VI= AVFL/(AMN(1,1)*0.7854*AMN(1,2)**2)
24     G1=AVFL
25     G8(2)=AVFL/AMCEL
26     ASURR=AMCEL*(CTHK*AMN(1,4)/AMN(1,2))**2
27     ARAT=(AMN(1,1)*AMN(1,2)**2)/(AMN(2,1)*AMN(2,2)**2)
28     1    G3=G8(2)
29     V1=VI
30     G9=0.0
31     V3=G3/(AMN(1,1)*0.7854*(CTHK*AMN(1,4))**2)
32     PC=(G3/SCFC)**SCFX
33     RENO= V1 *AMN(1,2)/VISI
34     FI=64./RENO
35     IF (RENO.GT.2000.) FI=0.316/RENO**25
36     RENO=RENO*AMN(2,2)/AMN(1,2)
37     FO=64./RENO
38     IF (RENO.GT.2000.) FO=0.316/RENO**25
39     8    DO 2 I=1,N
40         P=(FI/(2.0*AMN(1,1)*AMN(1,2)) + FO*ARAT**2/(2.0*AMN(2,1)*AMN(2,2))

```

```

41      2)*V1**2 -(THTA1-THTA2*ARAT**2)*V1*(ASUPR/ALEN)*V3
42      P=-(RHOI*P)*CTHK
43      G9=G9+G3
44      G(1)=G3
45      P0=P0+P
46      IF (P0.LT.0.0) GO TO 3
47      G3= SCFC*(P0**1.0/SCFX))
48      V3= G3/(AMN(1,1)*0.7854*(CTHK*AMN(1,4))**2)
49      V1= ((G1-G3)/G1)*V1
50      G1= G1-G3
51      RENO= V1      *AMN(1,2)/VIS1
52      FI=64./RENO
53      IF (RENO.GT.2000.) FI=0.316/RENO**0.25
54      RENO=RENO*AMN(2,2)/AMN(1,2)
55      F0=64./RENO
56      IF (RENO.GT.2000.) F0=0.316/RENO**0.25
57      2 CONTINUE
58      3 E(2)= G5-AVFL
59      IF (ABS(E(2)).LT.0.1) GO TO 760
60      IF (J.GT.1) GO TO 690
61      G8(1)=G8(2)
62      G8(2)=G8(2)-E(2)/AMCEL
63      GO TO 720
64      690 G8(3)=G8(2)-E(2)*(G8(2)-G8(1))/(E(2)-E(1))
65      G8(1)=G8(2)
66      G8(2)=G8(3)
67      720 E(1)=E(2)
68      Z(J)= G8(1)
69      J=J+1
70      GO TO 1
71      760 PDSTK=P0
72      PDMOD=PDSTK+(AVFL/EPIC)**EPIX+(AVFL/EPGC)**EPOX
73      C CHECK FOR OUT OF BOUNDS ON SINGLE CELL FLOW
74      CFMAX=G(1)
75      CFMIN=G(1)
76      9 DO 4 I=2,N
77      CFMAX= AMAX1(CFMAX,G(I))
78      CFMIN= AMIN1(CFMIN,G(I))
79      4 IF (CFMIN.GE.(AVFL*SCFMNR/AMCEL)) GO TO 5
80      IFLAG(4)=1

```

```
81      RETURN NO
82      5      IF(CFMAX.LE.(AVFL*SCFMXR/AMCEL)) GO TO 6
83      IFLAG(5)=1
84      RETURN NO
85      6      RETURN
86      END
```

```

1      SUBROUTINE HMPB, RETURNS(N)
2      CS  DEBUG
3      CS  TRACE
4      EXTERNAL DEN, VIS, CP
5      REAL NUS, KAIR
6      COMMON/BLK1/DCPWR, PTAMB, PTMOD, X3, CAR, X5(15), ELCON, ELDELC,
7      1AMPRES, AMDELP,
8      2AMDELT, Y25(5), AMSTY, X31(58), AFF, X90(6), CWT, CWMF, FWT, CPDL, PLMIN,
9      3PLK, FPPPPD, FSRC, HYPCFPD, ETAPHOT, PK, CLFH, ELFD, RESH, RESD, ELPW, ETAPVM
10     4, TCOO, TCOH, DTOO, DTOH, X18, OCHEF, HCHEF, ETAWP, ETAWPM, X122(2), EPKTH,
11     5AMINST, AMINSK, CFKTH, RESHEF, RESINST, RESINSK, UHXA, UHXC, VOIDFR, X134
12     COMMON/BLK2/Y0(29), EFF1, CI, PMOD, AMCEL, Y33, ETAI, Y35(5), AMODG, AMLEN,
13     2Y42, CFVOD, CFHOD, CFAN, Y46(4), EPTHK, EPAR, Y52(7), PDMOD, Y60(6), DA, DC,
14     3ODA, ODC, PHDA, FHOC, PIFA, PIPC, GCONO, GCONH, OMFL, HMFL, WMFL03, WMFLH3,
15     4FWMFL, PPA, PPC, CWOC, CWHC, DCAR, HCAR, CUMFL, WPP, QMODL, RLENA, RLENC,
16     5WMFL02, WMFLH2, WMFL01, WMFLH1, ALFN, GRFS, GPIPE, HXAAR, HXCAR, CWFHXA,
17     6CWFHXC, GHXA, Q-XC, DTA, DTC, AVOL, CVOL, PWAT, PKOH, PMFL, PAMFL, PCMFL,
18     7PAVFL, PCVFL, G4OL
19     COMMON/BLK5/IFLAG(32)
20     VISAIR(T)=1.E-6*(-4.228+.04027*(T+273.15)+ 9.342E-5*(T+273.15)**2)
21     HVAP(T)=1.E6*(2.460-9.19)E-4*T-9.609E-6*T**2)
22     VP(T,C)=133.322*EXP(1.539+.9883*C-8.906*C**2+.06512*T-.006288*C*T
23     8+-.001653*T*C**2-1.406E-4*T**2+2.207E-5*C*T**2+3.819E-6*C**2*T**2)
24     KAIR(T)=4.164E-3 +7.267E-7*(T+273)
25     CPWV(T)=8137.0-37.343*(T+273)+.0748*(T+273)**2-4.956E-5*(T+273)**3
26     CPH(T)=6441.3+63.105*(T+273)-.16838*(T+273)**2+1.521E-4*(T+273)**3
27     CPQ(T)=950.68-.4451*(T+273)+1.395E-3*(T+273)**2-8.46E-7*(T+273)**3
28     ALFA(T)=(-.2999 + 1.714E-3*(T+273))*1E-4
29     CPW=4186.7
30     C  CALC  MASS FLOWS
31     CONC= ELCON+0.5*ELDELC
32     CONA= ELCON-0.5*ELDELC
33     CFF = 1.- AFF
34     RHQA= DEN(PTMOD, CONA)
35     RHOC= DEN(PTMOD, CONC)
36     EFF1= CI*AMCEL*PMOD*ETAI
37     PMFL=AMODG*PMOD/(AMDELT*(AFF*CP(PTHOD, CONA)+CFF*CP(PTHOD, CONC)))
38     PAMFL= AFF*PMFL
39     PCMFL= CFF*PMFL
40     PCVFL= PCMFL/RHOC

```

```

41      PAVFL= PAMFL/RHOA
42      HMFL= EFFI*1.04470E-8
43      OMFL= EFFI*8.29096E-8
44      C  ELECTROLYTE PIPE SIZE SELECTION
45          DA= VA=ODA=0
46          DC= VC=ODC=0
47          IF (AFF.EQ.1.) GO TO 2
48      1  DC= 0.01 * DC
49          RE=PCMFL/(0.7854*DC*VIS(PTMOD,CONC))
50          VC=PCVFL/(0.7854*DC**2)
51          F=64./RE
52          IF (RE.GT.2000.) F=0.316/RE**.25
53          DPOLC= F*RHOA*VC**2/(2.*DC)
54          IF (DPOLC.GT.DPOL) GO TO 1
55          ODC=DC+ELPW
56      2  DA=DA+0.01
57          RE=PAVFL/(0.7854*DA*VIS(PTMOD,CONA))
58          VA=PAVFL/(0.7854*DA**2)
59          F=64./RE
60          IF (RE.GT.2000.) F=0.316/RE**.25
61          DPOLA= F*RHOA*VA**2/(2.*DA)
62          IF (DPOLA.GT.DPOL) GO TO 2
63          ODA=DA+ELPW
64      C  PRESSURE DROP/PUMP SIZING
65          PPC=PIPC=      RLENC=0
66          IF (AFF.EQ.1.) GO TO 4
67          RLENC=(PLMIN+ PLK*(DCPWR**.333))*(CFF)
68          FSPDC=(RHOA*FSRC*VC**2)/2.
69          PHOC  =(RLENC*DPOLC)*(1.0+FPDPPD+HXPDPPD)+FSPDC + PDMOD
70          ETAHOC=(1-0.8/(PCMFL*15.85)**.25)*ETAPVM
71          PPC=PHOC*PCVFL/ETAHOC
72          PIPC=PPC/ETAPMOT
73          IF (PIPC.LT.100.) PIPC=100.
74      4  RLENA=(PLMIN+PLK*(DCPWR**.333))*AFF
75          FSPDA=(RHOA*FSRC*VA**2)/2.
76          PHDA  =(RLENA*DPOLA)*(1.0+FPDPPD+HXPDPPD)+FSPDA + PDMOD
77          ETAHDA=(1-0.8/(PAMFL*15.85)**.25)*ETAPVM
78          PPA=PHDA*PAVFL/ETAHDA
79          PIPA= PPA/ETAPMOT
80          IF (PIPA.LT.100.) PIPA=100.

```

```

81 C HYDROGEN CONDENSER HEAT AND MASS BALANCE
82 T=TCOH
83 TCIH=PTMOD+0.5*AMDELT
84 IF (TCIH.LT.T) T=TCIH
85 PH=AMPRES+0.5*AMDELP
86 VPRW=VP(TCIH,CONC)
87 WMFLH1=(18.0153*VPRW+HMFL)/(2.0159*(PH-VPRW+1.01325E5))
88 VPRW=VP(T,0.0)
89 WMFLH3=(18.0153*VPRW+HMFL)/(2.0159*(PH-VPRW+1.01325E5))
90 WMFLH2=WMFLH1-WMFLH3
91 IF (WMFLH2.LT.0.0) WMFLH2=0.0
92 QCONH=(HMFL*CFH*((T+TCIH)/2.))+WMFLH1*CPW*((T+TCIH)/2.)*(TCIH-T)
93 +WMFLH2*HVP*((T+TCIH)/2.)
94 CWHC=QCONH/(DTCO*CPW)
95 HCAR=QCONH/(HCHEF*((TCIH-T-DTCO)/ALOG((TCIH-CWT-DTCO)/(T-CWT))))
96 C OXYGEN CONDENSER HEAT AND MASS BALANCE
97 T=TCOO
98 TCIO=TCIH
99 IF (TCIO.LT.T) T=TCIO
100 PO=AMPRES-0.5*AMDELP
101 VPRW=VP(TCIO,CONA)
102 WMFLO1=(18.0153*VPRW+OMFL)/(31.9988*(PO-VPRW+1.01325E5))
103 VPRW=VP(T,0.0)
104 WMFLO3=(18.0153*VPRW+OMFL)/(31.9988*(PO-VPRW+1.01325E5))
105 WMFLO2=WMFLO1-WMFLO3
106 IF (WMFLO2.LT.0.0) WMFLO2=0.0
107 TAV=(T+TCIO)/2.
108 QCONO=(OMFL*CPO(TAV)+WMFLO1*CPW(TAV))*(TCIO-T)+WMFLO2*HVP(TAV)
109 CWOC=QCONO/(DTCO*CPW)
110 QCAR=QCONO/(CHEF*((TCIO-T-DTCO)/ALOG((TCIH-CWT-DTCO)/(T-CWT))))
111 C CALCULATE NET REMAINING HEAT LOAD, SETFLAG 7 IF NEGATIVE
112 QREM=AMODQ*PMDD+PPC+PPA-QCONO-QCONH
113 IF (QREM.GT.0.) GO TO 5
114 IFLAG(7)=1
115 RETURN N
116 5 CWMFL=CWOC+CWHC
117 IF (CWMFL.LT.CWMF) GO TO 6
118 IFLAG(6)=1
119 RETURN N
120 C FEEDWATER REQUIREMENTS

```



```

121 6 FWMFL = HMFL+OMFL+WMFL03+WMFLH3
122 WPP=AMPRES*FWMFL/(997.*ETA*V*ETA*WPM)
123 IF (WPP.LT.100.) WPP=100.
124 C CONVECTIVE HEAT LOSS CALCULATIONS,RA=RALEIGH #,NU=NUSSELT #,TF=FILM T.
125 C MODULE ENDPLATES
126 TS=(PTAMB+PTMOD)/2.
127 ALC= AMSTY*CFVOD/2.
128 7 TF=(TS+PTAMB)/2.
129 RA= 9.8*(ALC**3)*(TS-PTAMB)/((TF+273.15)*VISAIR(TF)*ALFA(TF))
130 NUS= 0.59*(RA**0.25)
131 IF(RA.GT.10E9) NUS=0.1*(RA**0.33)
132 H= NUS*KAIR(TF)/ALC
133 TSN=(PTMOD/((EPHK/EPKTH)+(AMINST/AMINSK)))+(PTAMB*H)
134 & /( 1. /((EPHK/EPKTH)+(AMINST/AMINSK)))+( 1. *H))
135 IF ( ABS(TS-TSN).LT.5) GO TO 8
136 TS= TSN
137 GO TO 7
138 8 QEP= 2.*EPAR*H*(TSN-PTAMB)
139 C MODULE SIDES
140 TS=(PTMOD+ PTAMB)/2.
141 ALC=CFVOD
142 IF(AMSTY.EQ.2.) ALC=ALEN *CFVOD/(ALEN+CFVOD)
143 9 H= 1.32*(((TS-PTAMB)/ALC)**0.25)
144 TSN=(PTMOD+CFKTH/CFAN+PTAMB*H)/(CFKTH/CFAN+H)
145 IF ( ABS(TSN-TS).LT.5) GO TO 10
146 TS= TSN
147 GO TO 9
148 10 QMODL=QEP+ 3.1416*ALEN *ALC*H*(TSN-PTAMB)
149 QREM= QREM-PMOD+QMODL
150 IF(QREM.GT.0) GO TO 11
151 IFLAG(8)=1
152 RETURN N
153 11 CONTINUE
154 C RESERVOIRS
155 ANR= 1+ 2.*CFF
156 ALC= RESH
157 TS=(PTAMB+2*PTMOD)/ 3.
158 12 TF=(TS+PTAMB)/2.
159 RA= 9.8*(ALC**3)*(TS-PTAMB)/((TF+273.15)*VISAIR(TF)*ALFA(TF))
160 H=1.42*(((TS-PTAMB)/ALC)**0.25)

```

```

161      IF(RA.GT.1E9) H= 1.32*((TS-PTAMB)**.333)
162      TSN=(PTMOD/((1./RESHEF)+(RESINST/RESINSK)))+(PTAMB*H)
163      S / ( 1. / ((1./RESHEF)+(RESINST/RESINSK))+( 1. *H))
164      IF( ABS(TSN-TS).LT.5) GO TO 13
165      TS= TSN
166      GO TO 12
167 13 GRES= ANR*ALC*3.14*RESQ*H*(TSN-PTAMB)
168 C PIPING HEAT LOSSES
169      TS=PTMOD
170      TF=(PTAMB+PTMOD)/2.
171      ALC= ODA*AFF*ODC*CFF
172      RA= 9.8*(ALC**3)*(TS-PTAMB)/((TF+273.15)*VISAIR(TF)*ALFA(TF))
173      H= 1.32*((TS-PTAMB)/ALC)**.25)
174      IF(RA.GT.1E9) H=1.25*((TS-PTAMB)**.333)
175      AREA=(RENA*ODA+RENC*ODC)*3.1416
176      QPIPE= H*AREA*(TS-PTAMB)
177      QREM= QREM-QPIPE-QRES
178      IF(QREM.GT.0.) GO TO 17
179      IFLAG(9)=1
180      RETURN N
181 C HEAT EXCHANGER
182 17 HXCAR=CWFHXC =0
183      IF (CFF.EQ.0) GO TO 14
184      QHXC=QREM*CFF
185      DTC=QHXC/(PCMFL*CP(PTMOD,ELCON+ELDEL/2.))
186      CWFHXC = QHXC/(DTC*CPW)
187      HXCAR= QHXC/(UHXC* (PTMOD-DTC/2.-CWT))
188 14 QHXA=QREM*AFF
189      DTA=QHXA/(PA*FL*CP(PTMOD,ELCON+ELDEL/2.))
190      CWFHXA =QHXA/(DTA*CPW)
191      HXAAR= QHXA/(UHXA* (PTMOD-DTA/2.-CWT))
192      CWMFL=CWMFL+CWFHXA+CWFHXC
193      IF (CWMFL.LT.CWME) GO TO 15
194      IFLAG(6)=1
195      RETURN N
196 15 CONTINUE
197 C ELECTROLYTE VOLUME & MASS
198      CVOL=0
199      AVOL=.5*ALEN*CAR*VOIGR+.7854*(.5*RESQ**2*RESH+ELFD**2*ELFH)
200      IF(CFF.GT.0) CVOL=AVOL+.7854*RENC*DC**2

```

201 AVOL=AVOL+.7854*RENA*DA**2
202 GVOL=.432*RESD**2*RESH/AFF
203 PKOH=(AVOL*RHOA*CONA)+(CVOL*RHOC*CONC)
204 PWAT=(AVOL*RHOA*(1.-CONA))+(CVOL*RHOC*(1.-CONC))
205 RETURN
206 END

```

1      SUBROUTINE CONDIT
2      CS  DEBUG
3      CS  TRACE
4      COMMON/BLK1/X0,PTAMB,X2(20),AMPRES,AMDELP,X24(89),TCOC,TCOH,
5      2X115(21),HIOMR,OIMANCL,
6      3OPUR,HPUR,ONNO,DHNO,DHCYC,DHCYC,DSMWR,DSVOID,DSCLP,DTCG,DSDEN,
7      4OLDR,DWTHK,DWDEN,DWCP,PHS,POS,FTACOMP,RATCOMP,OMASR,HMASR,DRPURG
8      COMMON/BLK2/Y0(29),EFFI,CI,PMOD,AMCEL,Y33(3),ETAP,Y37(39),OMFL,
9      2HMFL,WMFLO3,WMFLH3,Y80(36),GVOL,Y117,Y118,OMFLH,HMFLO,
10     3OMFLD,HMFLO,WMFLO5,WMFLH5,WMFLO4,WMFLH4,DSMO,DSMH,DDO,DDH,DLO,
11     4DLH,DPO,DPH,DPN,Y135,CCPWF,HCPWR,CCOMPS,HCOMPS,OSTCR,FSTOR
12     WMFLH3=WMFLH3
13     WMFLO3=WMFLO3
14     PINH=AMPRES+.5*AMDELP+1.01E5
15     PINO=AMPRES-.5*AMDELP+1.01E5
16     DENO=PINO/(260. *(273.15+TCOC))
17     DENH=PINH/(4124. *(273.15+TCOH))
18     C  HYDROGEN DRYER CALCULATION-(FER DRYER)
19     CMFLH=HIOMR*HMFL
20     HMFLD=HMFL-0.1260*CMFLH
21     WMFLH5=(1-HPUR)*HMFLD
22     WMFLH4=WMFLH3-WMFLH5
23     IF (WMFLH4.LT.0) WMFLH4=0
24     DSMH= WMFLH4*DHCYC/(DSMWR+DHNO)
25     VD= DSMH/OSDEN
26     GVOL=GVOL+.25*VD*DHNO
27     HMFLD= HMFLD - DSVOID*VD*DENH/DHCYC-WMFLH4*DRPURG
28     ETAP=HMFLD/HMFL
29     DDH= (AJNT(100*(2.*VD/(3.14159*OLDR))**.333))/100.
30     IF (DDH.GT.0) GO TO 1
31     DLH=0
32     GO TO 2
33     1  DLH=2*VD/(3.14159*DDH**2)
34     2  DSM= 3.14159*DWDEN*DWTHK*(DLH*DDH+DDH**2)
35     DPH=(DTCG-TCOH)*(DWCF+DMN+DSCLP+DSMH)/DHCYC
36     C  OXYGEN DRYER CALCULATION
37     HMFLD= PMOD*(CI*AMCEL -EFFI)*OIMANCL+1.0447E-8
38     OMFLD=OMFL-7.936*HMFLD
39     WMFLO5=(1-OPUR)*OMFLD
40     WMFLO4=WMFLO3-WMFLO5

```

```

41      IF (WMFLO4.LT.0) WMFLO4=0
42      DSMO= WMFLO4*DOCYC/(DSMR*DONO)
43      VD= DSMO/DSREN
44      GVOL=GVCL+.25*VD*DONO
45      OMFLD =OMFLD- DSVOID+VD*DENO/DOCYC -WMFLO4*DRPURG
46      DDG= (AINT(100*(2.*VD/(3.14159*DLDR))**.333))/100.
47      IF (DDG.GT.0) GO TO 3
48      DLO=0
49      GO TO 4
50      3      DLO=2*VO/(3.14159*DDO**2)
51      4      DMH= 3.14159*DWDEN*DWTHK*(CLO+DDO+DDO**2)
52      DPO= (DTCHG-TCOO)*(DWCP+DMH*DSCP+DSMO)/DOCYC
53      C NET POWER & MATERIAL REQUIREMENTS
54      DPN= DPO+DONO*DFH*DHNO
55      C COMPRESSOR CALCULATION -ASSUME ADIABATIC PROCESS,K=1.395
56      C HYDROGEN
57      POUT=PHS+1.015E5
58      RAT=POUT/PIVH
59      HCPWR=0
60      HCOMPS=4.
61      IF (RAT.LE.RATCOMP**3.) HCOMPS=3.
62      IF (RAT.LE.RATCOMP**2.) HCOMPS=2.
63      IF (RAT.LE.RATCOMP ) HCOMPS=1.
64      IF (RAT.LE.1. ) HCOMPS=0.
65      IF (HCOMPS.EQ.0.) GO TO 5
66      HCPWR=HCOMPS*HMFLD*4124.*(TCOH+273.)*(RAT**(.283/HCOMPS)-1)/ETACOMP
67      C OXYGEN
68      5      POUT=POS+1.015E5
69      RAT=POUT/PIVO
70      OCPWR=0.
71      OCOMPS=4.
72      IF (RAT.LE.RATCOMP**3.) OCOMPS=3.
73      IF (RAT.LE.RATCOMP**2.) OCOMPS=2.
74      IF (RAT.LE.RATCOMP ) OCOMPS=1.
75      IF (RAT.LE.1. ) OCOMPS=0.
76      IF (OCOMPS.EQ.0 ) GO TO 6
77      OCPWR=OCOMPS*OMFLD*260*(TCOO+273.)*(RAT**(.283/OCOMPS)-1)/ETACOMP
78      C STORAGE
79      6      HSTOR = HMASR*4124*(PTAMB+273.)/(PHS+1.015E5)
80      OSTOR= OMASR*260 *(PTAMB+273.)/(POS+1.015E5)

```

81
82

RETURN
END

```
1 SUBROUTINE ETANET
2 COMMON/BLK1/X0(25),PCNTRL
3 COMMON/BLK2/Y0,ACPWR,ETATOT,CV,BBV,BRC,Y6(22),WOUT,Y29(6),ETAR,
4 2Y36(36),PIPA,PIPC,Y74(14),WPP,Y89(33),HMFLD,Y123(12),DPN,AUXPWR,
5 30CPWR,HCPWR,Y139(30)
6 WOUT=HMFLD*1.418EH
7 AUXPWR=PIPC+PIPA+WPP+DPN+0CPWR+HCPWR+PCNTRL
8 ACPWR=REC*BBV/ETAR +AUXPWR
9 ETATOT=WOUT/ACPWR
10 RETURN
11 END
```

```

1 FUNCTION DEN(T,C)
2 C= MASS FRACTION KOH, T= DEG. C ,DEN= DENSITY KOH,KG/M**3
3 DEN=1004-.1179*T-3.221E-3*T**2+918.*C-1.944*C*T+.01430*C*T**2+
4 2224.*C**2+.912*T*C**2-2.367E-2*C**2*T**2
5 RETURN
6 END

```



```

1      FUNCTION CP(T,C)
2      T IN CELCIUS, C IN MASS FRACTION , CP IN JOULE/KG-C
3      T1=T+273.15
4      X=2.1397-9.68137E-3*T1+2.68536E-5*T1**2-2.42139E-8*T1**3
5      Y= 2.921E-2+8.994E-1*C-1.62*ALOG10(C+0.25)
6      CP=X*Y*4184
7      RETURN
8      END

```

```
1 FUNCTION VIS(T,C)
2 C T IN CELCIUS, C IN MASSFRACTION, VISCOSITY IN PASCAL-SEC.
3 X=1./(T+273.15)
4 VIS=-5.372+.6604*C+2.133*C**2+1256.*X-4.096E+5*X**2+7.185E7*X**3
5 VIS=10.**VIS
6 RETURN
7 END
```

D-42

```

1      SUBROUTINE LIFE(T1,AL1,T2,AL2,T,AL)
2      C CALCULATE A LIFETIME AT T(C) GIVEN LIFE AT T1 & T2- ARRHENIUS THEORY.
3      TA=1./((T1+273.15)
4      TB=1./((T2+273.15)
5      TC=1./((T +273.15)
6      ALA= ALOG(AL1)
7      ALB= ALOG(AL2)
8      AL= ALA+(TC-TA)*(ALA-ALB)/(TA-TB)
9      AL= EXP(AL)
10     RETURN
11     END

```

```

1      SUPROUTINE OPCOST
2      C ESTIMATE 1ST YEAR OPERATING COST, INCL. MATERIALS, LABOR, OVERHEAD, G&A
3      C$  DEBUG
4      C$  STORES(CWCOS,FWCOS,AKOHCOS,APGCOS,AMATCOS,ALBRCOS,AOHCOS,
5      C$  AGACOS,AOCOS,GARATE)
6      COMMON/BLK1/XD(168),DF,X169(8),CWSPCOS,FWSPCOS,AMNTRT,PGSVCOS,
7      2ALBRRT,OHRAE,GARATE,CPSPCOS,OPERTAU
8      COMMON/PLK2/Y0,ACPWR,Y2(6),AOCOS,Y9,PLTCOSZ,Y11(69),FWMFL,Y81(6),
9      2CWMFL,Y88(22),PKOH,Y111(5),GVOL,Y117(38),ACWCOS,AFWCOS,AMATCOS,
10     3ALBRCOS,AGACOS,AOHCOS
11     C MATERIALS COST
12     GARATE=GARATE
13     ACWCOS=CWMFL*CWSPCOS*3.15576E7*DF
14     AFWCOS=FWMFL*FWSPCOS*3.15576E7*DF
15     AKOHCOS=PKOH*AMNTRT*CPSPCOS/0.45
16     APGCOS=(365./OPERTAU)*5.*GVOL*PGSVCOS
17     AMATCOS=0.001*PLTCOSZ*APGCOS+AFWCOS+AKOHCOS+ACWCOS
18     C LABOR, OVERHEAD, G&A
19     ALBRCOS=(0.25*ALOG10(ACPWR/1.E5))*ALBRRT
20     AOHCOS=OHRAE*ALBRCOS
21     AGACOS=GARATE*(AOHCOS+ALBRCOS+AMATCOS)
22     AOCOS=AOHCOS+AGACOS+ALBRCOS+AMATCOS
23     RETURN
24     END

```

```

1      SUPROUTINE MODCOST
2      CS      DEBUG
3      C CALCULATE THE ORIGINAL MODULE COST FOR ROUND OR RECTANGULAR MODULE
4      C BASED ON OVERALL SIZES
5          COMMON/BLK1/X(3),PLIFE,CAR,X5(25),AMSTY,EPSTY,X32(9),SLTHK,X42(6),
6          2TRNO,X49(125),CRVRZ,ZRVY,X176(19),
7          3PLASCST,CELPMLD,AMOPCST,FRPCEL,SLPCEL,SLMCOS,
8          4SLPCOS,ANSCOS,ANCCOS,ANPCOS,CASCOS,CACOS,CAPRCOS,SEPCOS,
9          5SEPPCOS,BPTHK,BPDENS,BPMSCOS,BPPCOS,FMTHK,FMSPCOS,FMPCOS,EPMSCOS,
10         6EPMFGCS,TRMCOS,TRPCOS,TRHCOS,X222(38),ASSYK1,ASSYK2
11         COMMON/BLK2/YO(11),AMLIFE,TMODCOS,Y13(18),PMOD,AMCEL,Y33(9),CFMAS,
12         2CFVOD,CFHOD,Y45,CFSAR,TRLEN,TRDIAM,TRMAS,Y50,EPAR,Y52,EPMAS,Y5(8),
13         3SEPCOST,EPCOST,FMPCOST,OMODCOS,Y66(51),RMODCOS,Y119(43),
14         4ANCOST,CACOST,CELCOST,EPCOST,TRCOST,AMLDCST,CFCOST,SLCOST,ASSYCOS
15     C CALCULATE CELL FRAME COSTS, (XCLDCST BASED ON HP&TD QUOTATIONS)
16         AMLDCST=100000.*ALOG(4.19*CFSAR+1.38)
17         CFCOST=CFMAS+PLASCST+AMLDCST/CELPMLD+AMOPCST+FRPCEL
18     C CALCULATE CELL SEAL COST
19         SLCOST=SLPCEL*(SLMCOS+CFVOD+CFHOD+SLPCOS)
20     C CALCULATE CELL INTERNAL PARTS COST. UF=STOCK AREA/PART AREA
21         UF=1.1
22         IF (AMSTY.EQ.1.) UF=1.4
23         ANCOST=ANSCOS*CAR*UF+ANCCOS*CAR+ANPCOS
24         CACOST=CASCOS*CAR*UF+CACOS*CAR+CAPRCOS
25         SEPCOST=SEPCOS*CAR*UF+SEPPCOS
26         BPCOST=BPTHK*CAR*UF+BPDENS*BPMSCOS+BPPCOS
27         FMPCOST=2.*FMTHK*CAR*UF+FMSPCOS+2.*FMPCOS
28     C SUM OF CELL PARTS COSTS
29         CELCOST= CFCOST+SLCOST+ANCOST+CACOST+SEPCOST+BPCOST+FMPCOST
30     C CALCULATE ENDPLATE COST
31         EPCOST=2.*EPMAS +EPMSCOS*EPMFGCS*EPAR
32     C CALCULATE TIEROD COST
33         TRCOST=TRMAS+TRMCOS+TRPCOS+TRHCOS+TRDIAM
34     C ORIGINAL MODULE COST (PARTS PLUS ASSEMBLY)
35         ASSYCOS=EPAR*(AMCEL+ASSYK1+ASSYK2)
36         OMODCOS=CELCOST+AMCEL + TRCOST+TRNO + EPCOST + ASSYCOS
37     C REPLACEMENT MODULE COST CALCULATION
38         R=AMLIFE/ZRVY
39         IF (R.GE.1.) R=1.0
40         RMODCOS = ASSYCOS*1.5 + AMCEL*CELCOST*(1.-CRVRZ*(1.-R))

```

D-45

```
41      C TOTAL LIFE MODULE COSTS
42      ANORMOD= AINT(PLIFE/AMLIFE+0.5)-1.0
43      TMODCOS = PMOD*(CMODCOS+ANORMOD*RMODCOS)
44      RETURN
45      END
```

```

1      SUBROUTINE PLTCOST
2      C CALCULATE INDIVIDUAL SUBSYSTEM COSTS AND SUM FOR TOTAL
3      C$      DEBUG
4      C$      STORFS(PLTCOS)
5      COMMON/BLK1/DCPWR,X1,PTMOD,X3(19),AMPRES,X23(2),PCNTRL,X26(63),
6      2AFF,X90(6),CWT,X97,FWT,DPDL,4100(2),FPDPPD,X103,HXPDPFD,X105(4),
7      3RESH,RESO,
8      4ELPW,X112(6),OCHEF,HCHEF,X120(5),AMINST,AMINSK,X127,X128,RESINST,
9      5RESINSK,UHXA,UHXC,X133(7),DONO,DHNO,X142(11),PHS,PCS,X155(72),
10     6AMCF,CMCF,CMCF,HMCF,ELPBK1,ELPBK2,GSPBK1,GSPBK2,FILK1,FILK2,HXK1,
11     7HXX2,PUMPK1,PUMPK2,RESK1,RESK2,RESK3,CONK1,CONK2,CONK3,AINSK1,
12     8CWPPK1,FWPSK1,CNJK1,PURGK1,DRYK1,DRYK2,VENK1,STRTK1,CONF1,BOTK1,
13     9PSK1,UNASK1
14     COMMON/BLK2/YO,ACPWR,Y2(8),FLTCOS,Y11(2),SAR,Y14(17),PPOD,
15     1Y32(9),AMLEN,Y42,CFVOD,CFHGD,Y45(6),EPAR,Y52(14),DA,DC,ODA,ODC,
16     2Y70(2),PIPA,PIPC,Y74(11),OCAR,HCAR,Y87(3),RENA,RENC,Y52(4),ALEN,
17     3Y97(2),HXAAR,HXCAR,Y101(13),PAVFL,PCVFL,Y116(5),OMFLD,HMFLD,
18     4Y123(2),WMFLD4,WMFLH4,
19     5Y127(2),ODC,DDH,DLC,DLH,Y133(3),DSMN,Y137(2),OCOMPS,HCOMPS,OSTOR,
20     6HSTOR,Y143(27),ANPECOS,CAPBCOS,OYPRCOS,HYPRCOS,ANFLCOS,CAFLCOS,
21     7ANHCOS,CAHCOS,ANPMCOS,CAPBCOS,ANRSCOS,CARSCOS,PURGCOS,OXCNCOS,
22     8HYCNCOS,OXDRCOS,HYERCOS,AINSCOS,CWPCOS,FWPPCOS,VENTCOS,STRTCOS,
23     9OXCMCOS,HYCMCOS,OXBTCOS,HYBTCOS,PSCOS,UNASCOS,CNINCOS
24     ANPRCOS= ELPBK1*(ODA**2)*RENA**ELPBK2*AMCF
25     CAPBCOS= ELPBK1*(ODA**2)*RENC**ELPBK2*CMCF
26     OYPRCOS= GSPBK1*DCPWR**GSPBK2*CMCF
27     HYPRCOS= GSPBK1*DCPWR**GSPBK2*HMCF
28     ANFLCOS= FILK1*(PAVFL)**FILK2*AMCF
29     CAFLCOS= FILK1*(PCVFL)**FILK2*CMCF
30     ANHCOS= HXK1*HXAAR**HXK2*AMCF
31     CAHCOS= HXK1*HXCAR**HXK2*CMCF
32     ANPMCOS= PUMPK1*ALOG10(PIPA)*AMCF**5
33     CAPBCOS=0.
34     IF(PIPC.EQ.0) GO TO 1
35     CAPMCOS= PUMPK1*ALOG10(PIPC)*CMCF**5
36     1     ANRSCOS= RESK1*(RESH*RESO**2)**RESK2*AMCF**5
37     CARSCOS= RESK3
38     IF(AFF.EQ.1) GO TO 2
39     CARSCOS= RESK1*(RESH*RESO**2)**RESK2*CMCF**5
40     2     OXCNCOS= (CONK1*OCAR+CONK2*OMFLD)**CONK3*OMCF

```

```

41 HYCNCOS= (CONK1*HCAR+CONK2*HMFLD)**CONK3*HMCF
42 OXDRCOS= DRY*1*WMFLD4**DRYK2*ONCF
43 HYDRCOS= DRY*1*WMFLH4**DRYK2*HMCF
44 OXCMCOS= COMK1*DMFLC*OCOMPS*OMCF
45 HYCMCOS= COMK1*HMFLD*HCOMPS*HMCF
46 OXBTCOS= BOTK1*OSTOR*OMCF
47 HYBTCOS= BOTK1*HSTOR*HMCF
48 AINSCOS= AINSK1= (3.14*RESH*RESO+.5*3.14*RESO**2)*RESINST/AFF
49      + AINSK1*PMOD*AMINST*(AMLEN*2.*(CFHOD+CFVOD)+2.*EPAR)
50 CWPBCOS=CWPEK1
51 FWPECOS= FWPEK1
52 CNINCOS= CNIM1
53 PURGCOS= PURG*1
54 VENTCOS= VENK1*SAR
55 STRTCOS=STRTK1*SAR
56 PSCOS = PSK1*DCPWR
57 PLTCOS= ANPECOS+CAPECOS+OXPCOS+HYPBCOS+ANFLCOS+CAFLCOS+ANHXCOS
58      +CAHXCOS+ANPMCOS+CAPHCOS+ANRBCOS+CARSOS+OXNCOS+HYNCOS
59      +AINSCOS+CWPBCOS+FWPECOS+CNIMCOS+PURGCOS+OXDRCOS+HYDRCOS
60      +VENTCOS+STRTCOS+OXCCOS+HYCMCOS+OXBTCOS+HYBTCOS+PSCOS
61 UNASCOS=PLTCOS*UNASK1
62 PLTCOS=PLTCOS+UNASCOS
63 RETURN
64 END

```



```

1      SUBROUTINE CAPCOST
2      C ESTIMATE ORIGINAL COST TO BE CAPITALIZED
3      COMMON/BLK1/X0(3),PLF,Y4(170),CSVZ,ESVZ,X176(10),AINV,DNEK,
4      2DNEFACT,GMARGC,AINSTK,GMARGI,BLK,FCLK,GMARGB
5      COMMON/BLK2/Y0,ACPWR,Y2(4),CAPCOS,Y7(3),PLTCOSZ,AMLF,TMDDCOS,SAR,
6      2Y14(11),BLFCL,AINST,COMPCOS,Y28(3),PMOD,AMCEL,Y33(166),DNECOS
7      SIZE=ACPWR**25
8      COMPCOS= PLTCOSZ*(1.+AINV)+TMDDCOS
9      DNECOS=DNEK*SIZE
10     AINST=(AINSTK*SIZE)
11     BLFCL=(BLK*SAR+FCLK*SIZE)
12     CAPCOS= COMPCOS*(1.+GMARGC)+AINST*(1.+GMARGI)+BLFCL*(1.+GMARGB)
13     & +DNECOS/DNEFACT
14     RETURN
15     END

```

```

1      SLBROUTINE GASCOST
2      C COST CALCULATIONS BASED ON EPRI PS-866-SR
3      REAL K1,K2
4      COMMON/ELK1/X0(3),PLF,CAR,Y5(155),CSR,PSR,CSCOS,PSCOS,DCOS,AINF,
5      2PCOS,PCER,DF,TXR,TLR,TXCR,PTXIR,ACTIFLG,CSVZ,ESVZ,PSVZ
6      COMMON/PLK2/ALGPRX,ACPWR,ETATOT,Y3(3),CAPCOS,APCOS,AOCOS,AGO,
7      2Y10,AMLF,Y12(3),SPGPRX,RDISC,DP,WCC,CRFB,ALATC,ALAPC,
8      3ALAO,ALACC,ALAFCR,Y25(6),PMOD,AMCEL,Y33(112),PCLF,
9      4GINLF,SLDPR,ATDPR,PLFT,CRFT,ALAADA,ALAIT,ALAITCA,RDA
10     DR=1.-CSR-PSR
11     WCC=CSCOS*CSR+PSCOS*PSR+DCOS*DR
12     RDISC=WCC
13     CRFB=RDISC*(1.+RDISC)**PLF/((1.+RDISC)**PLF-1.)
14     RDA=0.008775-1.05E-4*PLF
15     IF(RDA.LT.0.(075) RDA=0.0075
16     C INCOME TAX CALCULATION
17     2      SLDPR=(1.-PSV2/CAPCOS)/PLF
18     ALAIT=(CRFB+RDA-SLDPR)*(1.-DR+DCOS/WCC)*TXR/(1.-TXR)
19     PLFT=AINF*(PLF+TLR+0.5)
20     CRFT=RDISC*(1.+RDISC)**PLFT/((1.+RDISC)**PLFT-1.)
21     ATDPR=2.*CRFB*(PLFT-1./CRFT)/(PLFT*(1.+PLFT)*WCC)
22     AITCM=CAPCOS*TXCR
23     AITC=25000.+(0.6*(AITCM-25000.))
24     IF(AITCM.LT.25000.) AITC=AITCM
25     IF (ACTIFLG.EQ.2.) GO TO 3
26     ALAADA=(ATDPR-SLDPR)*TXR/(1.-TXR)
27     ALAITCA=AITC*CRFB/((1.+RDISC)*CAPCOS)
28     GO TO 4
29     3      ALAADA=(ATDPR-SLDPR)*TXR*(1.-TXR+DR+DCOS/WCC)/(1.-TXR)
30     ALAITCA=(AITC*CRFB/((1.+RDISC)*CAPCOS))*(1.-DR+DCOS/WCC)
31     4      CONTINUE
32     C LEVELIZING FACTORS
33     ALAFCR=CRFB+RDA+ALAIT-ALAITCA-ALAADA+PTXIR
34     ALACC=ALAFCR+APCOS
35     K1=(1.+AINF)/(1.+RDISC)
36     GINLF=CRFB*K1*(1.-K1**PLF)/(1.-K1)
37     ALAO=AOCOS+GINLF
38     K2=(1.+AINF)*(1.+PCER)/(1.+RDISC)
39     PCLF=CRFB*K2*(1.-K2**PLF)/(1.-K2)
40     C GAS OUTPUT & PRICE CALC

```

```
41 APCOS=ACPWR*8.760*DF*PCOS
42 ALAPC=APCOS*PCLF
43 ALATC=ALACC+ALAPC+ALACC
44 AGO=ACPWR*ETATOT*8760.*DF/39351.
45 ALGPRX=ALATC/AGO
46 SFGPRX=(ALACC+(ALAPC/PCLF)+(ALAOCC/GINLF))/AGO
47 RETURN
48 END
```

```

1      SUBROUTINE LTMOUT1
2      COMMON/BLK1/PARAM(300)
3      COMMON/BLK2/ESTOUT(200)
4      COMMON/BLK3/FNAME(300),ENAME(200)
5      COMMON/BLK7/MLOOP,DLOOP(15,2),MLCOP(15,3)
6      101  FORMAT (16H1  LOOP PARAMETERS)
7      102  FORMAT (60(3X,5(I3.1H., A7,1H=,1PG11.4,2X)/))
8      103  FORMAT (26HC OUTPUT PARAMETERS )
9      C MLOOP(X,1)=PARAM #
10     PRINT 101
11     DO 1 I=1,15
12     IF(MLCOP(I,1).EQ.300) GO TO 1
13     DO 1 I=1,15
14     IF(MLOOP(I,1).EQ.300) GO TO 1
15     PRINT 102, MLOOP(I,1),FNAME(MLOOP(I,1)),PARAM(MLOOP(I,1))
16     1 CONTINUE
17     PRINT 103
18     PRINT 102,(I,ENAME(I),ESTOUT(I),I=1,200)
19     RETURN
20     END

```

```

1      SUBROUTINE LIMCUT2(K)
2      COMMON/BLK4/PMEM(15,31)
3      COMMON/BLK3/PNAME(300),ENAME(200)
4      COMMON/BLK7/NLOOP,DLOOP(15,2),MLOOP(15,3)
5      J=16+K
6      PRINT 100,K,MLOOP(K,1),PNAME(MLOOP(K,1)),PMEM(K,J)
7      100  FORMAT (19H0 OPTIMUM FOR LEVEL,I3,6H WITH ,I3,1H.,A7,1H=,1PG11.4)
8      K1=K-1
9      PRINT 101
10     101  FORMAT (26H  DOMAIN OF OPTIMIZATION:)
11     IF (K1.EQ.0) GO TO 3
12     DO 1 I=1,K1
13     PRINT 102,MLOOP(I,1),PNAME(MLOOP(I,1)),DLOOP(I,1),DLOOP(I,2),
14     2      MLOOP(I,2),PMEM(K,16+I)
15     102  FORMAT (3X,I3,1H.,A7,1H=,1PG11.4,4H TO ,1PG11.4,4H IN ,I5,
16     *      19H STEPS, OPTIMUM AT ,1PG11.4)
17     1  CONTINUE
18     3  K1=K+1
19     IF (K1.EQ.16) GO TO 4
20     DO 2 I=K1,15
21     J=16+I
22     IF (MLOOP(I,1).EQ.300) GO TO 2
23     PRINT 103,MLOOP(I,1),PNAME(MLOOP(I,1)),PMEM(K,J)
24     103  FORMAT (3X,I3,1H.,A7,1H=,1PG11.4)
25     2  CONTINUE
26     4  PRINT 104
27     104  FORMAT (18H  OPTIMUM RESULTS)
28     PRINT 105,(I,ENAME(I),PMEM(K,I),I=1,16)
29     105  FORMAT (10(3X,5(I3,1H.,A7,1H= ,1PG11.4,2X)/))
30     RETURN
31     END

```